



City of Tenino

Honorable Mayor and Town Council

Monthly Report of Wastewater Treatment Plant Operations & Maintenance

Month: May 2021

During the month of May, the treatment plant continues to perform optimally. All testing parameters are well below permit levels.

System Maintenance

- Regular upkeep.
- Sludge being removed from waiting pond weekly by hauler.

Process Changes

- No longer decanting or transferring from EQ basin – Empty.
- Started washing down sludge in EQ Basin.

Call Outs-Emergencies

- There were no call outs or emergencies for the month of May.

Communications

Miscellaneous

- Sludge removal weekly by hauler.
- Removing of sludge from the storage lagoon remains the most urgent issue at this facility.

Flows

- Influent total flow = 2,941,128 gallons
- Average daily flow = 94,880 gallons
- Max daily flow = 10,658 gallons
- Total gallons wasted = 82,000 gallons