



City of Tenino

Honorable Mayor and Town Council

Monthly Report of Wastewater Treatment Plant Operations & Maintenance

Month: August 2019

During the month of August, the treatment plant continues to perform optimally, all testing parameters are well below permit levels.

System Maintenance

- Regular upkeep.
- Fabric that has arrived to install on effluent infiltrators will need to be returned and exchanged due to it being the incorrect type of fabric.
- Lubricant changes on all the air blowers.

Process Changes

- Decanting Biosolids lagoon to minimal levels, in preparation for dewatering.

Call Outs-Emergencies

- There were no call outs or emergencies for the month of August.

Communications

- Removal of sludge from the storage lagoon remains the most urgent issue at this facility.

Miscellaneous

Flows

- Influent total flow = 3.09 MG
- Average daily flow = 0.10 MG
- Max daily flow = 0.182 MG
- Total gallons wasted = 61,700 gallons