

## Council Report for 9-10-2019

Water: During the Month of August the wells produced 7,694,076 gallons. In 2018 the wells produced 9,213,918 gallons. The difference between 2018 to 2019 is 1,519,842 gallons. The lower well is turned off at this time due to maintenance, the 8" water line that runs out of the building has rotted and needs to be replaced. We found this by doing routine maintenance. Still working on replacing meters.

WWTP: During the month of August, the treatment plant continues to perform optimally, all testing parameters are well below permit levels. System Maintenance, regular upkeep, Lubricant changes on all the air blowers.

Flows: Influent total flow = 3.09 MG  
Average daily flow = 0.10 MG  
Max Daily Flow = .182 MG  
Total gallons wasted = 61,700 gallons

Collections System: Still Flushing sewer lines there are 60 Flushing connections within the system. Jason has completed 20.