



City of Tenino

Honorable Mayor and Town Council

Monthly Report of Wastewater Treatment Plant Operations & Maintenance

Month: June 2019

During the month of June, the treatment plant continues to perform optimally, all testing parameters are well below permit levels.

System Maintenance

- Regular upkeep.
- Fabric arrived to install on Effluent infiltrators.
- MBR #2 basin was deragged.
- Process flow for the turbidity meters has been reconfigured.
- VFD for Blower #3 was installed; all running correctly.

Process Changes

- Decanting Biosolids lagoon to minimal levels, in preparation for dewatering. Less than 1 foot of free water remains on surface.

Call Outs-Emergencies

- There were no call outs or emergencies for the month of June.

Communications

- Continuing discussions with Biosolids coordinator, Meeta Panu. Need to resubmit SAP and biosolids management plan for approval.

Miscellaneous

Flows

- Influent total flow = 2.73 MG
- Average daily flow = 0.091 MG
- Max daily flow = 0.101 MG
- Total gallons wasted = 43,710 gallons