



MONTHLY STATUS REPORT

FOR

PUBLIC WORKS

FOR THE

TOWN OF THUNDERBOLT

OCTOBER 2025





Water Distribution Reports

ENVIRONMENTAL PROTECTION DIVISION
DRINKING WATER PROGRAM
GROUND WATER OPERATION REPORT

System Name: Thunderbolt Water System

WSID #: GA- 510006

Plant Name: Well # 3

Plant ID# : _____

County: Chatham

Permit # : 510006

Summary of (MONTH) OCTOBER

(YEAR): 2025

Day of Month	Raw Water Treated* (Gallons)	Treated Water Pumped to Distribution System* (Gallons)	Amount of Fluoride Used (lb or gal)	Finished Water Analysis			Remarks
				Chlorine Free Available (mg/L)	Fluoride (mg/L)	pH Value (S.U.)	
1	0	0		0.00	0.0	0.0	No water withdrawn from the ground.
2	0	0					
3	0	0					
4	0	0					
5	0	0					
6	0	0					
7	0	0					
8	0	0					
9	0	0					
10	0	0					
11	0	0					
12	0	0					
13	0	0					
14	0	0					
15	0	0					
16	0	0					
17	0	0					
18	0	0					
19	0	0					
20	0	0					
21	0	0					
22	0	0					
23	0	0					
24	0	0					
25	0	0					
26	0	0					
27	0	0					
28	0	0					
29	0	0					
30	0	0					
31	0	0					
Total	0	0	0	0.00	0	0.00	
Days	31	31	0	1	1	1	
Avg.	0	0	0.00	0.00	0.00	0.00	
Max.	0	0	0	0	0	0	
Min.	0	0	0	0	0	0	

*Treated and/or Pumped values should be reported as a total for a 24 hour period beginning 0000-2400.

(e.g., Take reading at same time each day so that it is for 24 hours)

Type Fluoride Compound Used: n/a

Type Chlorine Compound Used: Sodium Hypochlorite

I certify that all information contained on this form is correct and true to the best of my knowledge.

Signature: 

Title: Public Works Manager

Print Name: Oscar Crosby II

Certification Class: III

Phone #: 912-644 7999

**ENVIRONMENTAL PROTECTION DIVISION
 DRINKING WATER PROGRAM
 GROUND WATER OPERATION REPORT**

System Name: Thunderbolt Water System

WSID #: GA- 510006

Plant Name: Well #4

Plant ID# :

County: Chatham

Permit # : 510006

Summary of (MONTH) OCTOBER

(YEAR): 2025

Day of Month	Raw Water Treated* (Gallons)	Treated Water Pumped to Distribution System* (Gallons)	Amount of Fluoride Used (lb or gal)	Finished Water Analysis			Remarks
				Chlorine Free Available (mg/L)	Fluoride (mg/L)	pH Value (S.U.)	
1	16,039	16,039		0.75		8.1	
2	215,017	215,017		0.92		8.0	
3	256,081	256,081		0.66		8.1	
4	194,267	194,267		0.74		8.0	
5	209,913	209,913		0.91		8.0	
6	236,536	236,536		0.71		8.0	
7	42,178	42,178		0.26		8.1	
8	50,103	50,103		0.93		8.0	
9	251,829	251,829		0.64		8.0	
10	211,870	211,870		0.54		8.0	
11	202,520	202,520		1.3		8.0	
12	194,319	194,319		1		8.1	
13	247,789	247,789		1.38		8.1	
14	126,308	126,308		1.22		8.1	
15	50,043	50,043		1.05		8.1	
16	104,161	104,161		0.81		8.0	
17	139,182	139,182		0.47		8.0	
18	82,708	82,708		0.89		8.0	
19	78,793	78,793		0.67		8.0	
20	121,535	121,535		0.72		8.0	
21	145,249	145,249		1.21		8.0	
22	157,142	157,142		1.07		8.0	
23	167,315	167,315		0.91		8.0	
24	159,876	159,876		1.26		8.1	
25	199,022	199,022		1.3		8.2	
26	148,111	148,111		0.89		8.1	
27	154,544	154,544		0.81		8.0	
28	119,040	119,040		1.3		8.0	
29	168,656	168,656		1.26		8.0	
30	141,849	141,849		1.01		8.1	
31	108,919	108,919		1.21			
Total	4,700,914	4,700,914	0	28.80	0	241.20	
Days	31	31	0	31	0	30	
Avg.	151,642	151,642	0.00	0.93	0.00	8.04	
Max.	256,081	256,081	0	1.38	0	8.2	
Min.	42,178	42,178	0	0.26	0	8	

*Treated and/or Pumped values should be reported as a total for a 24 hour period beginning 0000-2400.

(e.g., Take reading at same time each day so that it is for 24 hours)

Type Fluoride Compound Used: n/a

Type Chlorine Compound Used: Sodium Hypochlorite

I certify that all information contained on this form is correct and true to the best of my knowledge.

Signature: 

Title: Public Works Manager

Print Name: Oscar Crosby II

Certification Class: III

Phone #: 912-644 7999



Thunderbolt Meter

Public Works	2,600 gals.
Fire Department	6,300 gals.
Senior Citizens	3,850 gals.
Town Hall	11,700 gals.
Thompson Park	0 gals.
Honey Park	310 gals.
Nellie Johnson Park	25,890 gals.
Cesoroni Ball Field	0 gals.
Museum	200 gals.
Downing St. Lift Station Gross Pumped	Forthcoming
Savannah Water Usage	4,292,681 gals.
Line Flushing	0 gals.

Chlorides: Well #3 10 ppm Well #4 80 ppm



Special Interest