



MONTHLY STATUS REPORT

FOR

PUBLIC WORKS

FOR THE

TOWN OF THUNDERBOLT

JULY 2026





Water Distribution Reports

ENVIRONMENTAL PROTECTION DIVISION
DRINKING WATER PROGRAM
GROUND WATER OPERATION REPORT

System Name: Thunderbolt Water System
Plant Name: Well # 3
County: Chatham
Summary of (MONTH) JULY

WSID #: GA- 510006
Plant ID# :
Permit # : 510006
(YEAR): 2026

Day of Month	Raw Water Treated* (Gallons)	Treated Water Pumped to Distribution System* (Gallons)	Amount of Fluoride Used (lb or gal)	Finished Water Analysis			Remarks
				Chlorine Free Available (mg/L)	Fluoride (mg/L)	pH Value (S.U.)	
1	0	0		0.00	0.0	0.0	No water withdrawn from the ground.
2	0	0					
3	0	0					
4	0	0					
5	0	0					
6	0	0					
7	0	0					
8	0	0					
9	0	0					
10	0	0					
11	0	0					
12	0	0					
13	0	0					
14	0	0					
15	0	0					
16	0	0					
17	0	0					
18	0	0					
19	0	0					
20	0	0					
21	0	0					
22	0	0					
23	0	0					
24	0	0					
25	0	0					
26	0	0					
27	0	0					
28	0	0					
29	0	0					
30	0	0					
31	0	0					
Total	0	0	0	0.00	0	0.00	
Days	31	31	0	1	1	1	
Avg.	0	0	0.00	0.00	0.00	0.00	
Max.	0	0	0	0	0	0	
Min.	0	0	0	0	0	0	


*Treated and/or Pumped values should be reported as a total for a 24 hour period beginning 0000-2400.

(e.g., Take reading at same time each day so that it is for 24 hours)

Type Fluoride Compound Used: n/a

Type Chlorine Compound Used: Sodium Hypochlorite

I certify that all information contained on this form is correct and true to the best of my knowledge.

Signature: 
Print Name: Oscar Crosby II

Title: Public Works Manager

Certification Class: III **Phone #:** 912-644 7999

**ENVIRONMENTAL PROTECTION DIVISION
DRINKING WATER PROGRAM
GROUND WATER OPERATION REPORT**

System Name: Thunderbolt Water System

WSID #: GA- 510006

Plant Name: Well #4

Plant ID# :

County: Chatham

Permit # : 510006

Summary of (MONTH) JULY

(YEAR): 2026

Day of Month	Raw Water Treated* (Gallons)	Treated Water Pumped to Distribution System* (Gallons)	Amount of Fluoride Used (lb or gal)	Finished Water Analysis			Remarks
				Chlorine Free Available (mg/L)	Fluoride (mg/L)	pH Value (S.U.)	
1	293,582	293,582		0.73		8.1	
2	344,580	344,580		0.31		8.0	
3	285,658	285,658		0.93		8.0	Main Break During Initial High Usage
4	289,431	289,431		0.61		8.0	
5	266,461	266,461		0.82		8.0	
6	282,166	282,166		0.3		8.0	
7	354,073	354,073		0.71		8.0	
8	239,555	239,555		0.91		8.1	
9	285,060	285,060		0.97		8.1	
10	323,915	323,915		0.3		8.0	
11	279,653	279,653		0.98		8.0	
12	248,088	248,088		1.35		8.1	
13	263,630	263,630		0.87		8.0	
14	269,117	269,117		0.63		8.1	
15	274,353	274,353		1.07		8.0	
16	269,414	269,414		1.5		8.1	
17	310,070	310,070		1.24		8.0	
18	266,209	266,209		0.79		8.0	
19	256,908	256,908		0.64		8.0	
20	287,742	287,742		1.71		8.1	
21	287,368	287,368		1.51		8.0	
22	267,975	267,975		1.56		8.1	
23	273,094	273,094		0.67		8.0	
24	294,361	294,361		1.37		8.1	
25	273,281	273,281		1.09		8.1	
26	250,531	250,531		0.52		8.1	
27	288,517	288,517		0.52		8.0	
28	300,558	300,558		0.81		8.1	
29	291,074	291,074		0.95		8.1	
30	282,689	282,689		0.93		8.0	
31	315,163	315,163		0.75		8.1	
Total	8,814,276	8,814,276	0	28.05	0	249.40	
Days	31	31	0	31	0	31	
Avg.	284,331	284,331	0.00	0.90	0.00	8.05	
Max.	354,073	354,073	0	1.71	0	8.1	
Min.	239,555	239,555	0	0.3	0	8	


*Treated and/or Pumped values should be reported as a total for a 24 hour period beginning 0000-2400.

(e.g., Take reading at same time each day so that it is for 24 hours)

Type Fluoride Compound Used: n/a

Type Chlorine Compound Used: Sodium Hypochlorite

I certify that all information contained on this form is correct and true to the best of my knowledge.

Signature: 

Title: Public Works Manager

Print Name: Oscar Crosby II

Certification Class: III **Phone #:** 912-644 7999



Thunderbolt Meter

Public Works	1,700 gals.
Fire Department	9,900 gals.
Senior Citizens	6,850 gals.
Town Hall	12,300 gals.
Thompson Park	0 gals.
Honey Park	570 gals.
Nellie Johnson Park	7,766 gals.
Cesoroni Ball Field	10 gals.
Museum	200 gals.
Downing St. Lift Station Gross Pumped	11,322,514 gals.
Savannah Water Usage	695,228 gals.
Line Flushing	0 gals.

Chlorides: Well #3 10 ppm Well #4 80 ppm



Comprehensive Work Order Report

Description	January	February	March	April	May	June	July	August	September	October	November	December	YTD
Water													
Cut-on	37	32	28	30	29	24	26						206
Cut-off	28	29	25	34	28	21	19						184
Red-tagged residences	0	0	0	0	0	0	0						0
Complaints- quality	0	1	0	0	0	0	0						1
Complaints- LWP	0	0	0	0	4	0	0						4
Meters read	1099	1098	1094	1102	1096	1098	1099						7686
Meters re-read	16	6	5	5	4	4	4						44
Meters/Boxes replaced	1	1	1	1	1	0	2						7
New meters installed	0	0	0	0	0	0	1						1
Data Logs	1	6	0	3	2	4	0						16
Lines repaired/leaks	1	2	2	3	4	3	2						17
Hydrant flushed	2	0	0	1	0	1	0						4
Wastewater													
Complaints	0	0	0	0	0	0	0						0
Repairs- managed	0	0	3	1	0	1	1						6
Repairs- enacted	0	0	0	0	0	1	1						2
Spills	0	0	0	0	0	0	0						0
Back-ups	0	0	0	0	0	0	0						0
LS call-outs	0	0	0	0	0	4	1						5
Sanitation													
Garbage Tons collected													0
RECY Tons collected													0
Dry Trash Emptied													0
Complaints													0
Cans replaced/repared													0
General Maintenance													
Facilities/Parks repairs	13	19	16	15	18	17	16						114
Road repairs	3	1	0	1	0	3	2						10
Signs repaired/installed	1	1	1	0	3	1	1						8
Stormwater													
Tide Gates/Outfalls	0	0	0	0	0	0	0						0
Canals/Ditches	2	0	0	1	1	0	0						4
Structures	0	0	0	0	0	0	0						0
Repairs	0	0	0	3	0	0	0						3
Maintenance	3	0	0	1	4	8	0						16
Inspections	0	0	65	0	0	0	0						65