



MONTHLY STATUS REPORT

FOR

PUBLIC WORKS

FOR THE

TOWN OF THUNDERBOLT

JUNE 2026





Water Treatment Reports



Water Distribution Reports

**ENVIRONMENTAL PROTECTION DIVISION
DRINKING WATER PROGRAM
GROUND WATER OPERATION REPORT**

System Name: Thunderbolt Water System
Plant Name: Well # 3
County: Chatham
Summary of (MONTH) JUNE

WSID #: GA- 510006
Plant ID# :
Permit # : 510006
(YEAR): 2026

Day of Month	Raw Water Treated* (Gallons)	Treated Water Pumped to Distribution System* (Gallons)	Amount of Fluoride Used (lb or gal)	Finished Water Analysis			Remarks
				Chlorine Free Available (mg/L)	Fluoride (mg/L)	pH Value (S.U.)	
1	0	0		0.00	0.0	0.0	No water withdrawn from the ground.
2	0	0					
3	0	0					
4	0	0					
5	0	0					
6	0	0					
7	0	0					
8	0	0					
9	0	0					
10	0	0					
11	0	0					
12	0	0					
13	0	0					
14	0	0					
15	0	0					
16	0	0					
17	0	0					
18	0	0					
19	0	0					
20	0	0					
21	0	0					
22	0	0					
23	0	0					
24	0	0					
25	0	0					
26	0	0					
27	0	0					
28	0	0					
29	0	0					
30	0	0					
31							
Total	0	0	0	0.00	0	0.00	
Days	30	30	0	1	1	1	
Avg.	0	0	0.00	0.00	0.00	0.00	
Max.	0	0	0	0	0	0	
Min.	0	0	0	0	0	0	

*Treated and/or Pumped values should be reported as a total for a 24 hour period beginning 0000-2400.

(e.g., Take reading at same time each day so that it is for 24 hours)

Type Fluoride Compound Used: n/a

Type Chlorine Compound Used: Sodium Hypochlorite

I certify that all information contained on this form is correct and true to the best of my knowledge.

Signature: _____ **Title:** Public Works Manager
Print Name: Oscar Crosby II **Certification Class:** III **Phone #:** 912-644 7999

**ENVIRONMENTAL PROTECTION DIVISION
DRINKING WATER PROGRAM
GROUND WATER OPERATION REPORT**

System Name: Thunderbolt Water System
Plant Name: Well #4
County: Chatham
Summary of (MONTH) JUNE

WSID #: GA- 510006
Plant ID# :
Permit # : 510006
(YEAR): 2026

Day of Month	Raw Water Treated* (Gallons)	Treated Water Pumped to Distribution System* (Gallons)	Amount of Fluoride Used (lb or gal)	Finished Water Analysis			Remarks
				Chlorine Free Available (mg/L)	Fluoride (mg/L)	pH Value (S.U.)	
1	552,057	552,057		0.45		8.0	
2	552,192	552,192		0.42		8.1	
3	232,287	232,287		0.52		8.1	Main Break During Initial High Usage
4	66,093	66,093		0.57		8.0	
5	321,171	321,171		0.64		8.0	
6	0	0		1.27		8.0	
7	0	0		1.08		8.0	
8	0	0		1.21		8.1	
9	76,894	76,894		0.71		8.1	
10	249,795	249,795		0.94		8.0	
11	177,401	177,401		0.68		8.1	
12	190,155	190,155		0.51		8.1	
13	153,050	153,050		0.93		8.0	
14	119,997	119,997		1.56		8.0	
15	142,902	142,902		0.66		8.1	
16	117,512	117,512		0.93		8.1	
17	276,591	276,591		0.99		8.0	
18	84,517	84,517		0.64		8.1	
19	81,231	81,231		0.95		8.0	
20	70,201	70,201		0.44		8.0	
21	116,112	116,112		0.73		8.0	
22	279,510	279,510		0.54		8.1	
23	326,951	326,951		0.38		8.0	
24	297,424	297,424		0.8		8.1	
25	304,922	304,922		0.73		8.0	
26	333,316	333,316		0.72		8.1	
27	308,157	308,157		0.5		8.1	
28	249,917	249,917		0.6		8.1	
29	274,707	274,707		0.77		8.0	
30	273,134	273,134		0.73		8.1	
31							
Total	6,228,196	6,228,196	0	22.60	0	241.50	
Days	30	30	0	30	0	30	
Avg.	207,607	207,607	0.00	0.75	0.00	8.05	
Max.	552,192	552,192	0	1.56	0	8.1	
Min.	0	0	0	0.38	0	8	

*Treated and/or Pumped values should be reported as a total for a 24 hour period beginning 0000-2400.

(e.g., Take reading at same time each day so that it is for 24 hours)

Type Fluoride Compound Used: n/a

Type Chlorine Compound Used: Sodium Hypochlorite

I certify that all information contained on this form is correct and true to the best of my knowledge.

Signature: _____ **Title:** Public Works Manager
Print Name: Oscar Crosby II **Certification Class:** III **Phone #:** 912-644 7999



Thunderbolt Meter

Public Works	1,700 gals.
Fire Department	9,700 gals.
Senior Citizens	3,420 gals.
Town Hall	11,800 gals.
Thompson Park	0 gals.
Honey Park	380 gals.
Nellie Johnson Park	7,396 gals.
Cesoroni Ball Field	10 gals.
Museum	100 gals.
Downing St. Lift Station	
Gross Pumped	10,541,548 gals.
Savannah Water Usage	5,214,190 gals.
Line Flushing	0 gals.

Chlorides: Well #3 10 ppm Well #4 80 ppm



Comprehensive Work Order Report