



AGENDA REQUEST

TO: Mayor and City Council
FROM: Kelly Knight, Public Works Director
DATE July 31, 2025
SUBJECT: IN THE MATTER OF CHANGE ORDER APPROVAL DANIELLE COVE
DRAINAGE IMPROVEMENTS – ARPA - BID NO. 2024-037PW - **KWK**

Request:

We are requesting the approval for Change Order 1 – Danielle Cove Drainage Improvements ARPA Bid No. 2024-037PW.

It was discovered during construction that there was a large section of roadway adjacent to the pipe crossing at Maynard Drive that was in very poor shape. The pavement was removed and exposed very wet expansive clay in the subbase. There was also an existing manhole covered up under the pavement. The subgrade needed to be excavated, backfilled with suitable granular material and additional paving was required to repair the roadway.

Original Contract Price - \$455,794.00

Change Order 1 \$7,200.00

New Contract Price - \$462,994.00