



## AGENDA REQUEST

**TO:** Mayor and City Council

**FROM:** Johnny Timmons, Manager TW&L

**DATE:** December 28, 2023

**SUBJECT:** IN THE MATTER OF APPROVAL OF CHANGE ORDER # 1 FOR THE  
CENTRAL PUMPING STATION MODIFICATIONS (BID NO. 2023-040WL)  
**JT**

---

**Request:**

Approval of the attached change order:

**Central Pumping Station Modifications** – Change Order # 1 – This change order shows a net decrease of \$500,000.00 to modify the wet well from a square structure to a round structure. This modification reduces the need for shoring during construction and increases safety and efficiency for the contractor and saves money for the owner. This change order brings the new contract amount to \$11,847,000.00.00 without adding any days to the substantial completion date.