



AGENDA REQUEST

TO: Mayor and City Council

FROM: Ben M. Logan, City Attorney

DATE February 2, 2023

SUBJECT: IN THE MATTER OF ORDINANCE AMENDMING CODE OF ORDINANCES CHAPTER 10 - FIRE AND FIRE PREVENTION, SECTION 10-1. CODE –ADOPTED – REMOVING FROM 2018 INTERNATIONAL FIRE CODE EXCEPTIONS FOR NFPA 13R FIRE SPRINKLER SYSTEM USE ON MULTI-STORY RESIDENTIAL (R-CLASS) BUILDINGS AND REQUIRING NFPA 13 USE

Request: As recommended by the License Commission at its January 19, 2023 meeting, this proposed ordinance amends the 2018 International Fire Code to require NFP 13 Fire Sprinkler Systems in all multi-story residential R-Class buildings.

Ordinance to be attached.