



AGENDA REQUEST

TO: Mayor and City Council

FROM: Johnny Timmons, Manager TW&L

DATE: June 25, 2025

SUBJECT: IN THE MATTER OF APPROVAL OF CHANGE ORDER # 1 FOR THE TWL
LS REPLACEMENT FOR CLIFF GOOKIN #1 & #2 & MID-SOUTH (BID NO
2024-045WL) ARPA **JT**

Request:

Approval of the attached change order:

TWL LS Replacement for Cliff Gookin #1 & #2 & Mis-South (ARPA) – Change Order # 1 –

This change order adds \$45,500.00 to the original contract amount for the installation of two (2) insertion valves due to the discovery that the existing gate valves to isolate the lift station are inoperable. A time extension of 90 days is also requested due to delayed lift station materials delivery. Therefore, the revised contract amount is \$1,605,500.00 and the new completion date will be September 29, 2025.