

Narrowsburg Water & Sewer District

Monthly Report for January 2022

- Completed monthly drinking water and waste water sampling and reporting.
- Took daily chlorine samples around the water district.
- Made adjustments to the chlorinator at the sewer plant, as needed, to maintain Federal and State standards on the effluent wastewater.
- Did water meter readings every Wednesday in the month of May.
- Found several leaks inside homes after a cold weekend, turned water off to two locations. One used 82,000 gallons and the other 31,000 in three days. Notified several other homeowners about possible water leaks.
- Repaired curb valve and turned water off to a house on RT-97 due to water leak inside that we found reading water meters on a weekly basis.
- Attended a class provided by NYRWA and several webinars for sewer and water education.
- Koberlein pumped out sludge from dosing tanks.
- Located sewer cleanouts and one water curb valve in wooded easements, used GPS to mark their location.
- Shoveled and plowed sewer plant, wells, and water tower.
- Responded to a grinder station alarm on Main St due to grinder plugged up. Koberlein helped unclog and get pump running.
- Found a leaking galvanized service line on 5th St, had TAM repair leak due to no working valves to turn water off.
- Continued painting inside Well #2.
- Did several final meter reads.
-