

Date: **December 15, 2021**



B&V New York LLP
489 Fifth Avenue 8 & 12 Floor
New York, NY 10017
(913) 458-6909

Subject: **Structural Analysis Report**

Carrier Designation: **Verizon Wireless Co-Locate**
Site Number: 404764
Site Name: WOODOAK - A

Crown Castle Designation: **BU Number:** 808716
Site Name: Tusten
JDE Job Number: 694710
Work Order Number: 2055240
Order Number: 594303 Rev. 0

Engineering Firm Designation: **Black & Veatch Corp. Project Number:** 406642

Site Data: **6067 State Route 97, Narrowsburg, Sullivan County, NY**
Latitude 41° 35' 34.1", Longitude -75° 1' 17.5"
179.098 Foot - Self Support Tower

B&V New York LLP is pleased to submit this “**Structural Analysis Report**” to determine the structural integrity of the above-mentioned tower.

The purpose of the analysis is to determine acceptability of the tower stress level. Based on our analysis we have determined the tower stress level for the structure and foundation, under the following load case, to be:

LC5: Proposed Equipment Configuration

Sufficient Capacity

This analysis utilizes an ultimate 3-second gust wind speed of 112 mph as required by the 2020 New York Uniform Code. Applicable Standard references and design criteria are listed in Section 2 - Analysis Criteria.

Structural analysis prepared by: Warit Chaisuwan / Jumpon Uea-areevorakul

Respectfully submitted by:

Bryan C. Lindsey, P.E.
Professional Engineer



TABLE OF CONTENTS

1) INTRODUCTION

2) ANALYSIS CRITERIA

Table 1 - Proposed Equipment Configuration

Table 2 - Other Considered Equipment

3) ANALYSIS PROCEDURE

Table 3 - Documents Provided

3.1) Analysis Method

3.2) Assumptions

4) ANALYSIS RESULTS

Table 4 - Section Capacity (Summary)

Table 5 - Tower Component Stresses vs. Capacity - LC5

4.1) Recommendations

5) APPENDIX A

tnxTower Output

6) APPENDIX B

Base Level Drawing

7) APPENDIX C

Additional Calculations

1) INTRODUCTION

This tower is a 179.098 ft Self Support tower designed by GlenMartin.

2) ANALYSIS CRITERIA

| | |
|-----------------------------|---|
| TIA-222 Revision: | TIA-222-H |
| Risk Category: | II |
| Wind Speed: | 112 mph |
| Exposure Category: | C |
| Topographic Factor: | 1 |
| Ice Thickness: | 1 in |
| Wind Speed with Ice: | 40 mph |
| Seismic Ss: | 0.146 |
| Seismic S1: | 0.048 |
| Service Wind Speed: | 60 mph |
| Seismic Loading: | Does not control per engineering judgment |

Table 1 - Proposed Equipment Configuration

| Mounting Level (ft) | Center Line Elevation (ft) | Number of Antennas | Antenna Manufacturer | Antenna Model | Number of Feed Lines | Feed Line Size (in) |
|---------------------|----------------------------|--------------------|----------------------------|--------------------------|----------------------|---------------------|
| 150.0 | 150.0 | 1 | cci tower mounts (v2.1) | Sector Mount [SM 801-3] | 2 | 1-5/8 |
| | | 6 | quintel technology | QS8656-5 w/ Mount Pipe | | |
| | | 1 | raycap | RVZDC-6627-PF-48 | | |
| | | 3 | samsung telecommunications | MT6407-77A w/ Mount Pipe | | |
| | | 3 | samsung telecommunications | RF4439D-25A | | |
| | | 3 | samsung telecommunications | RF4440D-13A | | |

Table 2 - Other Considered Equipment

| Mounting Level (ft) | Center Line Elevation (ft) | Number of Antennas | Antenna Manufacturer | Antenna Model | Number of Feed Lines | Feed Line Size (in) | |
|---------------------|----------------------------|--------------------|----------------------|---------------------------|----------------------|---------------------|-------|
| 176.0 | 180.0 | 3 | alcatel lucent | B25 RRH4x30-4R | 2 | 5/16 | |
| | | 3 | alcatel lucent | RRH4X25-WCS | | | |
| | | 3 | andrew | DBXLH-8585A-R2M | | | |
| | | 3 | andrew | SBNHH-1D65C | | | |
| | | 6 | commscope | NNHH-65A-R4 | | | |
| | | 3 | nokia | AIRSCALE RRH 4T4R B5 160W | | | |
| | | 2 | raycap | DC6-48-60-18-8F | | | |
| | | 6 | andrew | ETD819G-12UB | | | |
| | 177.0 | 1 | telewave | ANT150F2 | 4 | 13/16 | |
| | | 2 | andrew | ETD819G-12UB | | | |
| | 176.0 | 176.0 | 3 | alcatel lucent | RRH2X40-07-L-AT | 12 | 1-5/8 |
| | | | 6 | andrew | ETD819G-12UB | | |
| | | | | | 1 | Conduit | |

| Mounting Level (ft) | Center Line Elevation (ft) | Number of Antennas | Antenna Manufacturer | Antenna Model | Number of Feed Lines | Feed Line Size (in) |
|---------------------|----------------------------|--------------------|-------------------------|-------------------------|----------------------|---------------------|
| 160.0 | 160.0 | 1 | cci tower mounts (v2.1) | Sector Mount [SM 201-3] | 1 | 3/8 |
| | | 1 | Jsource technologies | 12128FM4SEC | | |
| | | 1 | andrew | HPX8-59 | | |
| 160.0 | 160.0 | 1 | ceragon | FIBEAIR IP-10 | 1 | 3/8 |
| | | 1 | cci tower mounts (v2.1) | Pipe Mount [PM 602-1] | | |

3) ANALYSIS PROCEDURE

Table 3 - Documents Provided

| Document | Reference | Source |
|--|-----------|----------|
| 4-TOWER MANUFACTURER DRAWINGS | 2924679 | CCIsites |
| 4-TOWER FOUNDATION DRAWINGS/DESIGN/SPECS | 2924681 | CCIsites |
| 4-GEOTECHNICAL REPORTS | 2924676 | CCIsites |

3.1) Analysis Method

tnxTower (version 8.1.1.0), a commercially available analysis software package, was used to create a three-dimensional model of the tower and calculate member stresses for various loading cases. Selected output from the analysis is included in Appendix A. When applicable, Crown Castle has calculated and provided the effective area for panel antennas using approved methods following the intent of the TIA-222 standard.

3.2) Assumptions

- 1) Tower and structures were maintained in accordance with the TIA-222 Standard.
- 2) The configuration of antennas, transmission cables, mounts and other appurtenances are as specified in Tables 1 and 2 and the referenced drawings.

This analysis may be affected if any assumptions are not valid or have been made in error. B&V New York LLP should be notified to determine the effect on the structural integrity of the tower.

4) ANALYSIS RESULTS

Table 4 - Section Capacity (Summary) (Self Support Tower)

| Section No. | Elevation (ft) | Component Type | Size | Critical Element | P (K) | SF*P_allow (K) | % Capacity | Pass / Fail |
|-------------|-------------------|----------------|---------|------------------|---------|----------------|------------|-------------|
| T1 | 179.098 - 159.41 | Leg | P3x.216 | 2 | -81.63 | 87.22 | 93.6 | Pass |
| T2 | 159.41 - 158.827 | Leg | P5x.258 | 33 | -84.37 | 202.96 | 42.5 | Pass |
| T3 | 158.827 - 139.139 | Leg | P5x.258 | 36 | -100.43 | 178.59 | 56.2 | Pass |
| T4 | 139.139 - 119.452 | Leg | P6x.28 | 57 | -131.98 | 240.98 | 54.8 | Pass |
| T5 | 119.452 - 99.7642 | Leg | P8x.322 | 78 | -158.71 | 376.50 | 42.2 | Pass |

| Section No. | Elevation (ft) | Component Type | Size | Critical Element | P (K) | SF*P_allow (K) | % Capacity | Pass / Fail | |
|-------------|-------------------|----------------|-------------------|------------------|---------|----------------|----------------|-------------|------|
| T6 | 99.7642 - 80.0767 | Leg | P8x.322 | 99 | -183.39 | 376.50 | 48.7 | Pass | |
| T7 | 80.0767 - 60.3892 | Leg | P8x.406 | 120 | -207.78 | 469.43 | 44.3 | Pass | |
| T8 | 60.3892 - 40.7017 | Leg | P10x.365 | 141 | -228.91 | 521.60 | 43.9 | Pass | |
| T9 | 40.7017 - 21.0142 | Leg | P10x.365 | 156 | -251.81 | 521.60 | 48.3 | Pass | |
| T10 | 21.0142 - 1.32667 | Leg | P10x.365 | 171 | -275.56 | 521.60 | 52.8 | Pass | |
| T11 | 1.32667 - 0 | Leg | P10x.593 | 186 | -282.19 | 892.79 | 38.4 | Pass | |
| T1 | 179.098 - 159.41 | Diagonal | L1 3/4x1 3/4x3/16 | 12 | -4.24 | 15.51 | 27.4 | Pass | |
| T3 | 158.827 - 139.139 | Diagonal | L2x2x3/16 | 54 | -6.70 | 15.86 | 42.2 | Pass | |
| T4 | 139.139 - 119.452 | Diagonal | L2x2x1/4 | 63 | -4.83 | 14.27 | 33.8 | Pass | |
| T5 | 119.452 - 99.7642 | Diagonal | L2 1/2x2 1/2x3/16 | 84 | -4.70 | 17.36 | 27.0 | Pass | |
| T6 | 99.7642 - 80.0767 | Diagonal | L2 1/2x2 1/2x3/16 | 105 | -4.89 | 13.28 | 36.8 | Pass | |
| T7 | 80.0767 - 60.3892 | Diagonal | L2 1/2x2 1/2x1/4 | 126 | -5.02 | 13.48 | 37.2 | Pass | |
| T8 | 60.3892 - 40.7017 | Diagonal | L3x3x3/16 | 147 | -6.03 | 14.09 | 42.8 | Pass | |
| T9 | 40.7017 - 21.0142 | Diagonal | L3x3x1/4 | 162 | -6.59 | 15.94 | 41.3 | Pass | |
| T10 | 21.0142 - 1.32667 | Diagonal | L3x3x1/4 | 177 | -8.73 | 13.89 | 62.8 | Pass | |
| T1 | 179.098 - 159.41 | Top Girt | L3x3x1/4 | 5 | -0.55 | 39.51 | 1.4 | Pass | |
| | | | | | | | Summary | | |
| | | | | | | | Leg (T1) | 93.6 | Pass |
| | | | | | | | Diagonal (T10) | 62.8 | Pass |
| | | | | | | | Top Girt (T1) | 1.4 | Pass |
| | | | | | | | Bolt Checks | 86.2 | Pass |
| | | | | | | | Rating = | 93.6 | Pass |

Table 5 - Tower Component Stresses vs. Capacity (Self Support Tower) - LC5

| Notes | Component | Elevation (ft) | % Capacity | Pass / Fail |
|-------|------------------------------------|----------------|------------|-------------|
| 1 | Anchor Rods | 0 | 20.1 | Pass |
| 1 | Base Foundation (Structure) | 0 | 32.0 | Pass |
| | Base Foundation (Soil Interaction) | | 52.0 | Pass |

| | |
|---|--------------|
| Structure Rating (max from all components) = | 93.6% |
|---|--------------|

Notes:


- 1) See additional documentation in "Appendix C – Additional Calculations" for calculations supporting the % capacity. Rating per TIA-222-H Section 15.5.

4.1) Recommendations

The tower and its foundation have sufficient capacity to carry the proposed load configuration. No modifications are required at this time.

APPENDIX A
TNXTOWER OUTPUT

| | | | | | | | | | | | |
|-----------------|-------------------|-------------|-------------|-------------------|------------------|-------------|-------------|------------------|-------------------|-------------|-------------|
| Section | T1 | T2 | T3 | T4 | T5 | T6 | T7 | T8 | T9 | T10 | T11 |
| Legs | P3x.216 | P5x.258 | P6x.28 | P8x.322 | P8x.406 | P10x.365 | L3x3x3/16 | L2 1/2x2 1/2x1/4 | L2 1/2x2 1/2x3/16 | L2x2x1/4 | L2x2x3/16 |
| Leg Grade | A500-50 | A36 | A36 | A36 | A36 | N.A. | A36 | N.A. | A36 | A36 | A36 |
| Diagonals | L1 3/4x1 3/4x3/16 | L2x2x3/16 | L2x2x1/4 | L2 1/2x2 1/2x3/16 | L2 1/2x2 1/2x1/4 | L3x3x1/4 | L3x3x1/4 | L3x3x1/4 | L3x3x1/4 | L3x3x1/4 | L3x3x1/4 |
| Diagonal Grade | A36 | A36 | A36 | A36 | A36 | A36 | A36 | A36 | A36 | A36 | A36 |
| Top Girts | L3x3x1/4 | L3x3x1/4 | L3x3x1/4 | L3x3x1/4 | L3x3x1/4 | L3x3x1/4 | L3x3x1/4 | L3x3x1/4 | L3x3x1/4 | L3x3x1/4 | L3x3x1/4 |
| Face Width (ft) | 4 | 4 | 5.75 | 7.5 | 9.25 | 11 | 12.75 | 14.5 | 16.25 | 18 | 23.0 |
| # Panels @ (ft) | 4 @ 4.92188 | 4 @ 4.92188 | 4 @ 4.92188 | 4 @ 4.92188 | 4 @ 4.92188 | 4 @ 4.92188 | 4 @ 4.92188 | 4 @ 4.92188 | 4 @ 4.92188 | 4 @ 4.92188 | 4 @ 4.92188 |
| Weight (K) | 0.8 | 1.3 | 1.7 | 2.4 | 2.5 | 3.3 | 3.3 | 3.6 | 3.7 | 3.7 | 3.7 |



SYMBOL LIST

| MARK | SIZE | MARK | SIZE |
|------|----------|------|-------------|
| A | P10x.593 | C | 1 @ 0.58333 |
| B | N.A. | D | 1 @ 1.32667 |

MATERIAL STRENGTH

| GRADE | Fy | Fu | GRADE | Fy | Fu |
|---------|--------|--------|-------|--------|--------|
| A500-50 | 50 ksi | 62 ksi | A36 | 36 ksi | 58 ksi |



TOWER DESIGN NOTES

1. Tower is located in Sullivan County, New York.
2. Tower designed for Exposure C to the TIA-222-H Standard.
3. Tower designed for a 112 mph basic wind in accordance with the TIA-222-H Standard.
4. Tower is also designed for a 40 mph basic wind with 1.00 in ice. Ice is considered to increase in thickness with height.
5. Deflections are based upon a 60 mph wind.
6. Tower Risk Category II.
7. Topographic Category 1 with Crest Height of 0.00 ft
8. TOWER RATING: 93.6%

ALL REACTIONS ARE FACTORED

MAX. CORNER REACTIONS AT BASE:
 DOWN: 282 K
 SHEAR: 21 K

UPLIFT: -184 K
 SHEAR: 16 K



| | | |
|--|--|--|
| <p>BLACK & VEATCH Building a world of difference.</p> | <p>B&V New York LLP 489 Fifth Avenue 8 & 12 Floor New York, NY 10017 Phone: (913) 458-6909 FAX:</p> | Job: Tusten (BU# 808716) |
| | | Project: 406642 (808716.2055240) |
| | | Client: Crown Castle Drawn by: Jumpon Uea-areevorakul App'd: |
| | | Code: TIA-222-H Date: 12/15/21 Scale: NTS |
| | | Path: Dwg No. E-1 |

Tower Input Data


The main tower is a 3x free standing tower with an overall height of 179.10 ft above the ground line.
 The base of the tower is set at an elevation of 0.00 ft above the ground line.
 The face width of the tower is 4.00 ft at the top and 18.00 ft at the base.
 This tower is designed using the TIA-222-H standard.

The following design criteria apply:

- Tower is located in Sullivan County, New York.
- Tower base elevation above sea level: 1150.00 ft.
- Basic wind speed of 112 mph.
- Risk Category II.
- Exposure Category C.
- Simplified Topographic Factor Procedure for wind speed-up calculations is used.
- Topographic Category: 1.
- Crest Height: 0.00 ft.
- Nominal ice thickness of 1.0000 in.
- Ice thickness is considered to increase with height.
- Ice density of 56 pcf.
- A wind speed of 40 mph is used in combination with ice.
- Temperature drop of 50 °F.
- Deflections calculated using a wind speed of 60 mph.
- Pressures are calculated at each section.
- Stress ratio used in tower member design is 1.
- Tower analysis based on target reliabilities in accordance with Annex S.
- Load Modification Factors used: $K_{es}(F_w) = 0.95$, $K_{es}(t_i) = 0.85$.
- Maximum demand-capacity ratio is: 1.05.
- Local bending stresses due to climbing loads, feed line supports, and appurtenance mounts are not considered.

Options

| | | |
|--|---|---|
| Consider Moments - Legs Consider Moments - Horizontals Consider Moments - Diagonals Use Moment Magnification ✓ Use Code Stress Ratios ✓ Use Code Safety Factors - Guys Escalate Ice Always Use Max Kz Use Special Wind Profile Include Bolts In Member Capacity Leg Bolts Are At Top Of Section ✓ Secondary Horizontal Braces Leg Use Diamond Inner Bracing (4 Sided) SR Members Have Cut Ends SR Members Are Concentric | Distribute Leg Loads As Uniform Assume Legs Pinned ✓ Assume Rigid Index Plate ✓ Use Clear Spans For Wind Area ✓ Use Clear Spans For KL/r Retension Guys To Initial Tension ✓ Bypass Mast Stability Checks ✓ Use Azimuth Dish Coefficients ✓ Project Wind Area of Appurt. Autocalc Torque Arm Areas Add IBC .6D+W Combination ✓ Sort Capacity Reports By Component Triangulate Diamond Inner Bracing Treat Feed Line Bundles As Cylinder Ignore KL/ry For 60 Deg. Angle Legs | Use ASCE 10 X-Brace Ly Rules ✓ Calculate Redundant Bracing Forces Ignore Redundant Members in FEA ✓ SR Leg Bolts Resist Compression All Leg Panels Have Same Allowable Offset Girt At Foundation ✓ Consider Feed Line Torque ✓ Include Angle Block Shear Check Use TIA-222-H Bracing Resist. Exemption Use TIA-222-H Tension Splice Exemption <div style="text-align: center; background-color: #e0e0e0; padding: 2px;">Poles</div> Include Shear-Torsion Interaction Always Use Sub-Critical Flow Use Top Mounted Sockets Pole Without Linear Attachments Pole With Shroud Or No Appurtenances Outside and Inside Corner Radii Are Known |
|--|---|---|



Triangular Tower

Tower Section Geometry

| Tower Section | Tower Elevation | Assembly Database | Description | Section Width | Number of Sections | Section Length |
|---------------|-----------------|-------------------|-------------|---------------|--------------------|----------------|
| | ft | | | ft | | ft |
| T1 | 179.10-159.41 | | | 4.00 | 1 | 19.69 |
| T2 | 159.41-158.83 | | | 4.00 | 1 | 0.58 |
| T3 | 158.83-139.14 | | | 4.00 | 1 | 19.69 |
| T4 | 139.14-119.45 | | | 5.75 | 1 | 19.69 |
| T5 | 119.45-99.76 | | | 7.50 | 1 | 19.69 |
| T6 | 99.76-80.08 | | | 9.25 | 1 | 19.69 |
| T7 | 80.08-60.39 | | | 11.00 | 1 | 19.69 |
| T8 | 60.39-40.70 | | | 12.75 | 1 | 19.69 |
| T9 | 40.70-21.01 | | | 14.50 | 1 | 19.69 |
| T10 | 21.01-1.33 | | | 16.25 | 1 | 19.69 |
| T11 | 1.33-0.00 | | | 18.00 | 1 | 1.33 |

Tower Section Geometry (cont'd)

| Tower Section | Tower Elevation | Diagonal Spacing | Bracing Type | Has K Brace End Panels | Has Horizontals | Top Girt Offset | Bottom Girt Offset |
|---------------|-----------------|------------------|--------------|------------------------|-----------------|-----------------|--------------------|
| | ft | ft | | | | in | in |
| T1 | 179.10-159.41 | 4.92 | X Brace | No | No | 0.0000 | 0.0000 |
| T2 | 159.41-158.83 | 0.58 | X Brace | No | Yes | 0.0000 | 0.0000 |
| T3 | 158.83-139.14 | 6.56 | X Brace | No | No | 0.0000 | 0.0000 |
| T4 | 139.14-119.45 | 6.56 | X Brace | No | No | 0.0000 | 0.0000 |
| T5 | 119.45-99.76 | 6.56 | X Brace | No | No | 0.0000 | 0.0000 |
| T6 | 99.76-80.08 | 6.56 | X Brace | No | No | 0.0000 | 0.0000 |
| T7 | 80.08-60.39 | 6.56 | X Brace | No | No | 0.0000 | 0.0000 |
| T8 | 60.39-40.70 | 9.84 | X Brace | No | No | 0.0000 | 0.0000 |
| T9 | 40.70-21.01 | 9.84 | X Brace | No | No | 0.0000 | 0.0000 |
| T10 | 21.01-1.33 | 9.84 | X Brace | No | No | 0.0000 | 0.0000 |
| T11 | 1.33-0.00 | 1.33 | X Brace | No | Yes | 0.0000 | 0.0000 |

Tower Section Geometry (cont'd)

| Tower Elevation ft | Leg Type | Leg Size | Leg Grade | Diagonal Type | Diagonal Size | Diagonal Grade |
|-----------------------|----------|----------|---------------------|---------------|-------------------|-----------------|
| T1 179.10-159.41 | Pipe | P3x.216 | A500-50 (50 ksi) | Equal Angle | L1 3/4x1 3/4x3/16 | A36 (36 ksi) |
| T2 159.41-158.83 | Pipe | P5x.258 | A500-50 (50 ksi) | Equal Angle | | A36 (36 ksi) |
| T3 158.83-139.14 | Pipe | P5x.258 | A500-50 (50 ksi) | Equal Angle | L2x2x3/16 | A36 (36 ksi) |
| T4 139.14-119.45 | Pipe | P6x.28 | A500-50 (50 ksi) | Equal Angle | L2x2x1/4 | A36 (36 ksi) |
| T5 119.45-99.76 | Pipe | P8x.322 | A500-50 (50 ksi) | Equal Angle | L2 1/2x2 1/2x3/16 | A36 (36 ksi) |
| T6 99.76-80.08 | Pipe | P8x.322 | A500-50 (50 ksi) | Equal Angle | L2 1/2x2 1/2x3/16 | A36 (36 ksi) |
| T7 80.08-60.39 | Pipe | P8x.406 | A500-50 (50 ksi) | Equal Angle | L2 1/2x2 1/2x1/4 | A36 (36 ksi) |
| T8 60.39-40.70 | Pipe | P10x.365 | A500-50 (50 ksi) | Equal Angle | L3x3x3/16 | A36 (36 ksi) |
| T9 40.70-21.01 | Pipe | P10x.365 | A500-50 (50 ksi) | Equal Angle | L3x3x1/4 | A36 (36 ksi) |
| T10 21.01-1.33 | Pipe | P10x.365 | A500-50 (50 ksi) | Equal Angle | L3x3x1/4 | A36 (36 ksi) |
| T11 1.33-0.00 | Pipe | P10x.593 | A500-50 (50 ksi) | Equal Angle | | A36 (36 ksi) |

Tower Section Geometry (cont'd)

| Tower Elevation ft | Top Girt Type | Top Girt Size | Top Girt Grade | Bottom Girt Type | Bottom Girt Size | Bottom Girt Grade |
|-----------------------|---------------|---------------|-----------------|------------------|------------------|-------------------|
| T1 179.10-159.41 | Equal Angle | L3x3x1/4 | A36 (36 ksi) | Single Angle | | A36 (36 ksi) |

Tower Section Geometry (cont'd)

| Tower Elevation ft | Gusset Area (per face) ft ² | Gusset Thickness in | Gusset Grade | Adjust. Factor A _r | Adjust. Factor A _r | Weight Mult. | Double Angle Stitch Bolt Spacing Diagonals in | Double Angle Stitch Bolt Spacing Horizontal in | Double Angle Stitch Bolt Spacing Redundants in |
|-----------------------|--|------------------------|-----------------|----------------------------------|----------------------------------|--------------|---|--|--|
| T1 179.10-159.41 | 0.00 | 0.3750 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T2 159.41-158.83 | 0.00 | 0.0000 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T3 158.83-139.14 | 0.00 | 0.3750 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T4 139.14-119.45 | 0.00 | 0.3750 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T5 119.45-99.76 | 0.00 | 0.3750 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T6 99.76-80.08 | 0.00 | 0.3750 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T7 80.08-60.39 | 0.00 | 0.3750 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T8 60.39-40.70 | 0.00 | 0.3750 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |

| Tower Elevation | Gusset Area (per face) | Gusset Thickness | Gusset Grade | Adjust. Factor A_r | Adjust. Factor A_r | Weight Mult. | Double Angle Stitch Bolt Spacing Diagonals | Double Angle Stitch Bolt Spacing Horizontals | Double Angle Stitch Bolt Spacing Redundants |
|-----------------|------------------------|------------------|--------------|----------------------|----------------------|--------------|--|--|---|
| ft | ft ² | in | | | | | in | in | in |
| T9 40.70-21.01 | 0.00 | 0.3750 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T10 21.01-1.33 | 0.00 | 0.3750 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |
| T11 1.33-0.00 | 0.00 | 0.0000 | A36 (36 ksi) | 1.05 | 1 | 1.05 | 36.0000 | 36.0000 | 36.0000 |

Tower Section Geometry (cont'd)

| Tower Elevation | Calc K Single Angles | Calc K Solid Rounds | Legs | K Factors ¹ | | | | | | | |
|------------------|----------------------|---------------------|------|------------------------|---------------|--------------|--------|--------|-------------|-------------|---|
| | | | | X Brace Diags | K Brace Diags | Single Diags | Girts | Horiz. | Sec. Horiz. | Inner Brace | |
| | | | | X Y | X Y | X Y | X Y | X Y | X Y | X Y | |
| T1 179.10-159.41 | Yes | No | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T2 159.41-158.83 | Yes | No | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T3 158.83-139.14 | Yes | No | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T4 139.14-119.45 | Yes | No | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T5 119.45-99.76 | Yes | No | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T6 99.76-80.08 | Yes | No | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T7 80.08-60.39 | Yes | No | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T8 60.39-40.70 | Yes | No | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T9 40.70-21.01 | Yes | No | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T10 21.01-1.33 | Yes | No | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| T11 1.33-0.00 | Yes | No | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |

¹Note: K factors are applied to member segment lengths. K-braces without inner supporting members will have the K factor in the out-of-plane direction applied to the overall length.

Tower Section Geometry (cont'd)

| Tower Elevation ft | Leg | | Diagonal | | Top Girt | | Bottom Girt | | Mid Girt | | Long Horizontal | | Short Horizontal | |
|--------------------|-----------|---|-----------|------|-----------|------|-------------|------|-----------|------|-----------------|------|------------------|------|
| | Net Width | U | Net Width | U | Net Width | U | Net Width | U | Net Width | U | Net Width | U | Net Width | U |
| | Deduct | | Deduct | | Deduct | | Deduct | | Deduct | | Deduct | | Deduct | |
| | in | | in | | in | | in | | in | | in | | in | |
| T1 179.10-159.41 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T2 159.41-158.83 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T3 158.83-139.14 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T4 139.14-119.45 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T5 119.45-99.76 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |

| Tower Elevation ft | Leg | | Diagonal | | Top Girt | | Bottom Girt | | Mid Girt | | Long Horizontal | | Short Horizontal | |
|--------------------|---------------------|---|---------------------|------|---------------------|------|---------------------|------|---------------------|------|---------------------|------|---------------------|------|
| | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U |
| T6 99.76-80.08 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T7 80.08-60.39 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T8 60.39-40.70 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T9 40.70-21.01 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T10 21.01-1.33 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T11 1.33-0.00 | 0.0000 | 1 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |

| Tower Elevation ft | Redundant Horizontal | | Redundant Diagonal | | Redundant Sub-Diagonal | | Redundant Sub-Horizontal | | Redundant Vertical | | Redundant Hip | | Redundant Hip Diagonal | |
|--------------------|----------------------|------|---------------------|------|------------------------|------|--------------------------|------|---------------------|------|---------------------|------|------------------------|------|
| | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U | Net Width Deduct in | U |
| T1 179.10-159.41 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T2 159.41-158.83 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T3 158.83-139.14 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T4 139.14-119.45 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T5 119.45-99.76 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T6 99.76-80.08 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T7 80.08-60.39 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T8 60.39-40.70 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T9 40.70-21.01 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T10 21.01-1.33 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |
| T11 1.33-0.00 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 | 0.0000 | 0.75 |

Tower Section Geometry (cont'd)

| Tower Elevation ft | Leg Connection Type | Leg | | Diagonal | | Top Girt | | Bottom Girt | | Mid Girt | | Long Horizontal | | Short Horizontal | |
|--------------------|---------------------|--------------|-----|--------------|-----|--------------|-----|--------------|-----|--------------|-----|-----------------|-----|------------------|-----|
| | | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. |
| T1 179.10-159.41 | Flange | 1.0000 | 4 | 0.6250 | 1 | 0.6250 | 1 | 0.0000 | 0 | 0.6250 | 0 | 0.0000 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325X | | A325N | | A325N | |
| T2 159.41-158.83 | Flange | 1.0000 | 4 | 0.0000 | 0 | 0.0000 | 0 | 0.0000 | 0 | 0.6250 | 0 | 0.0000 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325X | | A325N | | A325N | |
| T3 158.83-139.14 | Flange | 1.0000 | 6 | 0.6250 | 1 | 0.0000 | 0 | 0.0000 | 0 | 0.6250 | 0 | 0.0000 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325X | | A325N | | A325N | |
| T4 139.14-119.45 | Flange | 1.0000 | 6 | 0.6250 | 1 | 0.0000 | 0 | 0.0000 | 0 | 0.6250 | 0 | 0.0000 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325X | | A325N | | A325N | |
| T5 119.45-99.76 | Flange | 1.0000 | 6 | 0.7500 | 1 | 0.0000 | 0 | 0.0000 | 0 | 0.6250 | 0 | 0.0000 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325X | | A325N | | A325N | |

| Tower Elevation ft | Leg Connection Type | Leg | | Diagonal | | Top Girt | | Bottom Girt | | Mid Girt | | Long Horizontal | | Short Horizontal | |
|--------------------|---------------------|--------------|-----|--------------|-----|--------------|-----|--------------|-----|--------------|-----|-----------------|-----|------------------|-----|
| | | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. | Bolt Size in | No. |
| T6 99.76-80.08 | Flange | 1.0000 | 6 | 0.7500 | 1 | 0.0000 | 0 | 0.0000 | 0 | 0.6250 | 0 | 0.0000 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325X | | A325N | | A325N | |
| T7 80.08-60.39 | Flange | 1.0000 | 10 | 0.7500 | 1 | 0.0000 | 0 | 0.0000 | 0 | 0.6250 | 0 | 0.0000 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325X | | A325N | | A325N | |
| T8 60.39-40.70 | Flange | 1.0000 | 10 | 0.7500 | 2 | 0.0000 | 0 | 0.0000 | 0 | 0.6250 | 0 | 0.0000 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325X | | A325N | | A325N | |
| T9 40.70-21.01 | Flange | 1.0000 | 10 | 0.7500 | 2 | 0.0000 | 0 | 0.0000 | 0 | 0.6250 | 0 | 0.0000 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325X | | A325N | | A325N | |
| T10 21.01-1.33 | Flange | 1.0000 | 10 | 0.7500 | 2 | 0.0000 | 0 | 0.0000 | 0 | 0.6250 | 0 | 0.0000 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325X | | A325N | | A325N | |
| T11 1.33-0.00 | Flange | 1.0000 | 0 | 0.7500 | 0 | 0.0000 | 0 | 0.0000 | 0 | 0.6250 | 0 | 0.0000 | 0 | 0.6250 | 0 |
| | | A325N | | A325N | | A325N | | A325N | | A325X | | A325N | | A325N | |

Feed Line/Linear Appurtenances - Entered As Round Or Flat

| Description | Face or Leg | Allow Shield | Exclude From Torque Calculation | Component Type | Placement ft | Face Offset in | Lateral Offset (Frac FW) | # | # Per Row | Clear Spacing in | Width or Diameter in | Perimeter in | Weight plf |
|----------------------------|-------------|--------------|---------------------------------|----------------|----------------|----------------|--------------------------|----|-----------|------------------|----------------------|--------------|------------|
| Safety Line 3/8 *** | A | No | No | Ar (CaAa) | 179.10 - 0.00 | 0.0000 | -0.5 | 1 | 1 | 0.3750 | 0.3750 | | 0.22 |
| Feedline Ladder (Af) | C | No | No | Af (CaAa) | 179.10 - 10.00 | 0.0000 | 0.35 | 1 | 1 | 3.0000 | 3.0000 | | 8.40 |
| AVA7-50(1-5/8) | C | No | No | Ar (CaAa) | 176.00 - 10.00 | 0.0000 | 0.35 | 12 | 11 | 2.0100 | 2.0100 | | 0.70 |
| 2" Rigid Conduit | C | No | No | Ar (CaAa) | 176.00 - 10.00 | 0.0000 | 0.47 | 1 | 1 | 2.0000 | 2.0000 | | 2.80 |
| ATCB-B01-006(5/16") | C | No | No | Ar (CaAa) | 176.00 - 10.00 | 0.0000 | 0.47 | 2 | 1 | 0.5000 | 0.0000 | | 0.07 |
| RFFT-36SM-001-xxM(3/8") | C | No | No | Ar (CaAa) | 176.00 - 10.00 | 0.0000 | 0.47 | 2 | 1 | 0.5000 | 0.0000 | | 0.09 |
| PWRT-608-S(13/16") | C | No | No | Ar (CaAa) | 176.00 - 10.00 | 0.0000 | 0.47 | 4 | 2 | 0.5000 | 0.0000 | | 0.62 |
| LDF4-50A(1/2") ** | C | No | No | Ar (CaAa) | 176.00 - 10.00 | 0.0000 | 0.23 | 1 | 1 | 0.5000 | 0.6300 | | 0.15 |
| 04-001-54 (3/8" Cable) ** | C | No | No | Ar (CaAa) | 160.00 - 10.00 | 2.5000 | 0.35 | 1 | 1 | 0.5000 | 0.0001 | | 0.06 |
| Feedline Ladder (Af) CR 50 | B | No | No | Af (CaAa) | 152.00 - 6.00 | 0.0000 | -0.4 | 1 | 1 | 3.0000 | 3.0000 | | 8.40 |
| 1873(1-5/8") | B | No | No | Ar (CaAa) | 150.00 - 8.00 | 0.5000 | -0.4 | 2 | 2 | 1.9800 | 1.9800 | | 0.83 |

Feed Line/Linear Appurtenances Section Areas

| Tower Section | Tower Elevation ft | Face | A _R ft ² | A _F ft ² | C _A A _A In Face ft ² | C _A A _A Out Face ft ² | Weight K |
|---------------|--------------------|------|--------------------------------|--------------------------------|---|--|----------|
| T1 | 179.10-159.41 | A | 0.000 | 0.000 | 0.738 | 0.000 | 0.00 |
| | | B | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |
| | | C | 0.000 | 0.000 | 54.222 | 0.000 | 0.40 |
| T2 | 159.41-158.83 | A | 0.000 | 0.000 | 0.022 | 0.000 | 0.00 |
| | | B | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |
| | | C | 0.000 | 0.000 | 1.852 | 0.000 | 0.01 |
| T3 | 158.83-139.14 | A | 0.000 | 0.000 | 0.738 | 0.000 | 0.00 |
| | | B | 0.000 | 0.000 | 10.731 | 0.000 | 0.13 |

| Tower Section | Tower Elevation ft | Face | A_R ft ² | A_F ft ² | C_{AA} In Face ft ² | C_{AA} Out Face ft ² | Weight K |
|---------------|--------------------|------|--------------------------|--------------------------|--|---|-------------|
| T4 | 139.14-119.45 | C | 0.000 | 0.000 | 62.508 | 0.000 | 0.44 |
| | | A | 0.000 | 0.000 | 0.738 | 0.000 | 0.00 |
| | | B | 0.000 | 0.000 | 17.640 | 0.000 | 0.20 |
| T5 | 119.45-99.76 | C | 0.000 | 0.000 | 62.508 | 0.000 | 0.44 |
| | | A | 0.000 | 0.000 | 0.738 | 0.000 | 0.00 |
| | | B | 0.000 | 0.000 | 17.640 | 0.000 | 0.20 |
| T6 | 99.76-80.08 | C | 0.000 | 0.000 | 62.508 | 0.000 | 0.44 |
| | | A | 0.000 | 0.000 | 0.738 | 0.000 | 0.00 |
| | | B | 0.000 | 0.000 | 17.640 | 0.000 | 0.20 |
| T7 | 80.08-60.39 | C | 0.000 | 0.000 | 62.508 | 0.000 | 0.44 |
| | | A | 0.000 | 0.000 | 0.738 | 0.000 | 0.00 |
| | | B | 0.000 | 0.000 | 17.640 | 0.000 | 0.20 |
| T8 | 60.39-40.70 | C | 0.000 | 0.000 | 62.508 | 0.000 | 0.44 |
| | | A | 0.000 | 0.000 | 0.738 | 0.000 | 0.00 |
| | | B | 0.000 | 0.000 | 17.640 | 0.000 | 0.20 |
| T9 | 40.70-21.01 | C | 0.000 | 0.000 | 62.508 | 0.000 | 0.44 |
| | | A | 0.000 | 0.000 | 0.738 | 0.000 | 0.00 |
| | | B | 0.000 | 0.000 | 17.640 | 0.000 | 0.20 |
| T10 | 21.01-1.33 | C | 0.000 | 0.000 | 62.508 | 0.000 | 0.44 |
| | | A | 0.000 | 0.000 | 0.738 | 0.000 | 0.00 |
| | | B | 0.000 | 0.000 | 12.661 | 0.000 | 0.15 |
| T11 | 1.33-0.00 | C | 0.000 | 0.000 | 34.970 | 0.000 | 0.25 |
| | | A | 0.000 | 0.000 | 0.050 | 0.000 | 0.00 |
| | | B | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |
| | | C | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |

Feed Line/Linear Appurtenances Section Areas - With Ice

| Tower Section | Tower Elevation ft | Face or Leg | Ice Thickness in | A_R ft ² | A_F ft ² | C_{AA} In Face ft ² | C_{AA} Out Face ft ² | Weight K |
|---------------|--------------------|-------------|------------------|--------------------------|--------------------------|--|---|-------------|
| T1 | 179.10-159.41 | A | 1.001 | 0.000 | 0.000 | 4.680 | 0.000 | 0.04 |
| | | B | | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |
| | | C | | 0.000 | 0.000 | 125.406 | 0.000 | 1.46 |
| T2 | 159.41-158.83 | A | 0.995 | 0.000 | 0.000 | 0.138 | 0.000 | 0.00 |
| | | B | | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |
| | | C | | 0.000 | 0.000 | 4.431 | 0.000 | 0.05 |
| T3 | 158.83-139.14 | A | 0.988 | 0.000 | 0.000 | 4.630 | 0.000 | 0.04 |
| | | B | | 0.000 | 0.000 | 17.567 | 0.000 | 0.28 |
| | | C | | 0.000 | 0.000 | 148.985 | 0.000 | 1.69 |
| T4 | 139.14-119.45 | A | 0.974 | 0.000 | 0.000 | 4.575 | 0.000 | 0.04 |
| | | B | | 0.000 | 0.000 | 29.150 | 0.000 | 0.45 |
| | | C | | 0.000 | 0.000 | 147.819 | 0.000 | 1.66 |
| T5 | 119.45-99.76 | A | 0.958 | 0.000 | 0.000 | 4.512 | 0.000 | 0.04 |
| | | B | | 0.000 | 0.000 | 28.961 | 0.000 | 0.45 |
| | | C | | 0.000 | 0.000 | 146.482 | 0.000 | 1.63 |
| T6 | 99.76-80.08 | A | 0.940 | 0.000 | 0.000 | 4.438 | 0.000 | 0.03 |
| | | B | | 0.000 | 0.000 | 28.739 | 0.000 | 0.44 |
| | | C | | 0.000 | 0.000 | 144.907 | 0.000 | 1.60 |
| T7 | 80.08-60.39 | A | 0.917 | 0.000 | 0.000 | 4.348 | 0.000 | 0.03 |
| | | B | | 0.000 | 0.000 | 28.468 | 0.000 | 0.43 |
| | | C | | 0.000 | 0.000 | 142.986 | 0.000 | 1.56 |
| T8 | 60.39-40.70 | A | 0.887 | 0.000 | 0.000 | 4.231 | 0.000 | 0.03 |
| | | B | | 0.000 | 0.000 | 28.118 | 0.000 | 0.42 |
| | | C | | 0.000 | 0.000 | 140.501 | 0.000 | 1.51 |
| T9 | 40.70-21.01 | A | 0.844 | 0.000 | 0.000 | 4.063 | 0.000 | 0.03 |
| | | B | | 0.000 | 0.000 | 27.613 | 0.000 | 0.41 |
| | | C | | 0.000 | 0.000 | 136.923 | 0.000 | 1.44 |
| T10 | 21.01-1.33 | A | 0.763 | 0.000 | 0.000 | 3.742 | 0.000 | 0.03 |
| | | B | | 0.000 | 0.000 | 18.922 | 0.000 | 0.28 |
| | | C | | 0.000 | 0.000 | 72.779 | 0.000 | 0.74 |
| T11 | 1.33-0.00 | A | 0.575 | 0.000 | 0.000 | 0.202 | 0.000 | 0.00 |
| | | B | | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |
| | | C | | 0.000 | 0.000 | 0.000 | 0.000 | 0.00 |

Feed Line Center of Pressure

| Section | Elevation | CP _x | CP _z | CP _x | CP _z |
|---------|---------------|-----------------|-----------------|-----------------|-----------------|
| | ft | in | in | Ice in | Ice in |
| T1 | 179.10-159.41 | -7.8902 | 4.8892 | -10.4211 | 6.4326 |
| T2 | 159.41-158.83 | -10.3690 | 6.6308 | -12.6883 | 8.4593 |
| T3 | 158.83-139.14 | -8.7624 | 2.3992 | -11.8620 | 4.3180 |
| T4 | 139.14-119.45 | -10.4498 | 0.8532 | -14.3510 | 3.0137 |
| T5 | 119.45-99.76 | -11.3913 | 0.8129 | -16.2694 | 3.2280 |
| T6 | 99.76-80.08 | -13.0611 | 0.8593 | -18.6992 | 3.5966 |
| T7 | 80.08-60.39 | -14.5388 | 0.8990 | -20.8489 | 3.9079 |
| T8 | 60.39-40.70 | -15.7354 | 0.9152 | -22.8127 | 4.1601 |
| T9 | 40.70-21.01 | -17.0947 | 0.9567 | -24.5777 | 4.3828 |
| T10 | 21.01-1.33 | -11.5836 | -0.6603 | -17.4089 | 1.6670 |
| T11 | 1.33-0.00 | -1.1461 | 0.6597 | -2.9197 | 1.6806 |

Shielding Factor Ka

| Tower Section | Feed Line Record No. | Description | Feed Line Segment Elev. | K _a No Ice | K _a Ice |
|---------------|----------------------|-------------------------|-------------------------|--------------------------|-----------------------|
| T1 | 1 | Safety Line 3/8 | 159.41 - 179.10 | 0.6000 | 0.6000 |
| T1 | 3 | Feedline Ladder (Af) | 159.41 - 179.10 | 0.6000 | 0.6000 |
| T1 | 4 | AVA7-50(1-5/8) | 159.41 - 176.00 | 0.6000 | 0.6000 |
| T1 | 5 | 2" Rigid Conduit | 159.41 - 176.00 | 0.6000 | 0.6000 |
| T1 | 6 | ATCB-B01-006(5/16") | 159.41 - 176.00 | 0.6000 | 0.6000 |
| T1 | 7 | RFFT-36SM-001-xxM(3/8") | 159.41 - 176.00 | 0.6000 | 0.6000 |
| T1 | 8 | PWRT-608-S(13/16") | 159.41 - 176.00 | 0.6000 | 0.6000 |
| T1 | 9 | LDF4-50A(1/2") | 159.41 - 176.00 | 0.6000 | 0.6000 |
| T1 | 11 | 04-001-54 (3/8" Cable) | 159.41 - 160.00 | 0.6000 | 0.6000 |
| T2 | 1 | Safety Line 3/8 | 158.83 - 159.41 | 0.6000 | 0.6000 |
| T2 | 3 | Feedline Ladder (Af) | 158.83 - 159.41 | 0.6000 | 0.6000 |
| T2 | 4 | AVA7-50(1-5/8) | 158.83 - 159.41 | 0.6000 | 0.6000 |
| T2 | 5 | 2" Rigid Conduit | 158.83 - 159.41 | 0.6000 | 0.6000 |
| T2 | 6 | ATCB-B01-006(5/16") | 158.83 - 159.41 | 0.6000 | 0.6000 |
| T2 | 7 | RFFT-36SM-001-xxM(3/8") | 158.83 - 159.41 | 0.6000 | 0.6000 |
| T2 | 8 | PWRT-608-S(13/16") | 158.83 - 159.41 | 0.6000 | 0.6000 |
| T2 | 9 | LDF4-50A(1/2") | 158.83 - 159.41 | 0.6000 | 0.6000 |
| T2 | 11 | 04-001-54 (3/8" Cable) | 158.83 - 159.41 | 0.6000 | 0.6000 |
| T3 | 1 | Safety Line 3/8 | 139.14 - 158.83 | 0.6000 | 0.6000 |
| T3 | 3 | Feedline Ladder (Af) | 139.14 - 158.83 | 0.6000 | 0.6000 |
| T3 | 4 | AVA7-50(1-5/8) | 139.14 - 158.83 | 0.6000 | 0.6000 |

| Tower Section | Feed Line Record No. | Description | Feed Line Segment Elev. | K _a No Ice | K _a Ice |
|---------------|----------------------|-------------------------|-------------------------|-----------------------|--------------------|
| T3 | 5 | 2" Rigid Conduit | 139.14 - 158.83 | 0.6000 | 0.6000 |
| T3 | 6 | ATCB-B01-006(5/16") | 139.14 - 158.83 | 0.6000 | 0.6000 |
| T3 | 7 | RFFT-36SM-001-xxM(3/8") | 139.14 - 158.83 | 0.6000 | 0.6000 |
| T3 | 8 | PWRT-608-S(13/16") | 139.14 - 158.83 | 0.6000 | 0.6000 |
| T3 | 9 | LDF4-50A(1/2") | 139.14 - 158.83 | 0.6000 | 0.6000 |
| T3 | 11 | 04-001-54 (3/8" Cable) | 139.14 - 158.83 | 0.6000 | 0.6000 |
| T3 | 13 | Feedline Ladder (Af) | 139.14 - 152.00 | 0.6000 | 0.6000 |
| T3 | 14 | CR 50 1873(1-5/8") | 139.14 - 150.00 | 0.6000 | 0.6000 |
| T4 | 1 | Safety Line 3/8 | 119.45 - 139.14 | 0.6000 | 0.6000 |
| T4 | 3 | Feedline Ladder (Af) | 119.45 - 139.14 | 0.6000 | 0.6000 |
| T4 | 4 | AVA7-50(1-5/8) | 119.45 - 139.14 | 0.6000 | 0.6000 |
| T4 | 5 | 2" Rigid Conduit | 119.45 - 139.14 | 0.6000 | 0.6000 |
| T4 | 6 | ATCB-B01-006(5/16") | 119.45 - 139.14 | 0.6000 | 0.6000 |
| T4 | 7 | RFFT-36SM-001-xxM(3/8") | 119.45 - 139.14 | 0.6000 | 0.6000 |
| T4 | 8 | PWRT-608-S(13/16") | 119.45 - 139.14 | 0.6000 | 0.6000 |
| T4 | 9 | LDF4-50A(1/2") | 119.45 - 139.14 | 0.6000 | 0.6000 |
| T4 | 11 | 04-001-54 (3/8" Cable) | 119.45 - 139.14 | 0.6000 | 0.6000 |
| T4 | 13 | Feedline Ladder (Af) | 119.45 - 139.14 | 0.6000 | 0.6000 |
| T4 | 14 | CR 50 1873(1-5/8") | 119.45 - 139.14 | 0.6000 | 0.6000 |
| T5 | 1 | Safety Line 3/8 | 99.76 - 119.45 | 0.6000 | 0.6000 |
| T5 | 3 | Feedline Ladder (Af) | 99.76 - 119.45 | 0.6000 | 0.6000 |
| T5 | 4 | AVA7-50(1-5/8) | 99.76 - 119.45 | 0.6000 | 0.6000 |
| T5 | 5 | 2" Rigid Conduit | 99.76 - 119.45 | 0.6000 | 0.6000 |
| T5 | 6 | ATCB-B01-006(5/16") | 99.76 - 119.45 | 0.6000 | 0.6000 |
| T5 | 7 | RFFT-36SM-001-xxM(3/8") | 99.76 - 119.45 | 0.6000 | 0.6000 |
| T5 | 8 | PWRT-608-S(13/16") | 99.76 - 119.45 | 0.6000 | 0.6000 |
| T5 | 9 | LDF4-50A(1/2") | 99.76 - 119.45 | 0.6000 | 0.6000 |
| T5 | 11 | 04-001-54 (3/8" Cable) | 99.76 - 119.45 | 0.6000 | 0.6000 |
| T5 | 13 | Feedline Ladder (Af) | 99.76 - 119.45 | 0.6000 | 0.6000 |
| T5 | 14 | CR 50 1873(1-5/8") | 99.76 - 119.45 | 0.6000 | 0.6000 |
| T6 | 1 | Safety Line 3/8 | 80.08 - 99.76 | 0.6000 | 0.6000 |
| T6 | 3 | Feedline Ladder (Af) | 80.08 - 99.76 | 0.6000 | 0.6000 |
| T6 | 4 | AVA7-50(1-5/8) | 80.08 - 99.76 | 0.6000 | 0.6000 |
| T6 | 5 | 2" Rigid Conduit | 80.08 - 99.76 | 0.6000 | 0.6000 |
| T6 | 6 | ATCB-B01-006(5/16") | 80.08 - | 0.6000 | 0.6000 |

| Tower Section | Feed Line Record No. | Description | Feed Line Segment Elev. | K_a No Ice | K_a Ice |
|---------------|----------------------|-------------------------|-------------------------|--------------|-----------|
| T6 | 7 | RFFT-36SM-001-xxM(3/8") | 99.76 80.08 - 99.76 | 0.6000 | 0.6000 |
| T6 | 8 | PWRT-608-S(13/16") | 99.76 80.08 - 99.76 | 0.6000 | 0.6000 |
| T6 | 9 | LDF4-50A(1/2") | 80.08 - 99.76 | 0.6000 | 0.6000 |
| T6 | 11 | 04-001-54 (3/8" Cable) | 80.08 - 99.76 | 0.6000 | 0.6000 |
| T6 | 13 | Feedline Ladder (Af) | 80.08 - 99.76 | 0.6000 | 0.6000 |
| T6 | 14 | CR 50 1873(1-5/8") | 80.08 - 99.76 | 0.6000 | 0.6000 |
| T7 | 1 | Safety Line 3/8 | 60.39 - 80.08 | 0.6000 | 0.6000 |
| T7 | 3 | Feedline Ladder (Af) | 60.39 - 80.08 | 0.6000 | 0.6000 |
| T7 | 4 | AVA7-50(1-5/8) | 60.39 - 80.08 | 0.6000 | 0.6000 |
| T7 | 5 | 2" Rigid Conduit | 60.39 - 80.08 | 0.6000 | 0.6000 |
| T7 | 6 | ATCB-B01-006(5/16") | 60.39 - 80.08 | 0.6000 | 0.6000 |
| T7 | 7 | RFFT-36SM-001-xxM(3/8") | 60.39 - 80.08 | 0.6000 | 0.6000 |
| T7 | 8 | PWRT-608-S(13/16") | 60.39 - 80.08 | 0.6000 | 0.6000 |
| T7 | 9 | LDF4-50A(1/2") | 60.39 - 80.08 | 0.6000 | 0.6000 |
| T7 | 11 | 04-001-54 (3/8" Cable) | 60.39 - 80.08 | 0.6000 | 0.6000 |
| T7 | 13 | Feedline Ladder (Af) | 60.39 - 80.08 | 0.6000 | 0.6000 |
| T7 | 14 | CR 50 1873(1-5/8") | 60.39 - 80.08 | 0.6000 | 0.6000 |
| T8 | 1 | Safety Line 3/8 | 40.70 - 60.39 | 0.6000 | 0.6000 |
| T8 | 3 | Feedline Ladder (Af) | 40.70 - 60.39 | 0.6000 | 0.6000 |
| T8 | 4 | AVA7-50(1-5/8) | 40.70 - 60.39 | 0.6000 | 0.6000 |
| T8 | 5 | 2" Rigid Conduit | 40.70 - 60.39 | 0.6000 | 0.6000 |
| T8 | 6 | ATCB-B01-006(5/16") | 40.70 - 60.39 | 0.6000 | 0.6000 |
| T8 | 7 | RFFT-36SM-001-xxM(3/8") | 40.70 - 60.39 | 0.6000 | 0.6000 |
| T8 | 8 | PWRT-608-S(13/16") | 40.70 - 60.39 | 0.6000 | 0.6000 |
| T8 | 9 | LDF4-50A(1/2") | 40.70 - 60.39 | 0.6000 | 0.6000 |
| T8 | 11 | 04-001-54 (3/8" Cable) | 40.70 - 60.39 | 0.6000 | 0.6000 |
| T8 | 13 | Feedline Ladder (Af) | 40.70 - 60.39 | 0.6000 | 0.6000 |
| T8 | 14 | CR 50 1873(1-5/8") | 40.70 - 60.39 | 0.6000 | 0.6000 |
| T9 | 1 | Safety Line 3/8 | 21.01 - 40.70 | 0.6000 | 0.6000 |
| T9 | 3 | Feedline Ladder (Af) | 21.01 - 40.70 | 0.6000 | 0.6000 |
| T9 | 4 | AVA7-50(1-5/8) | 21.01 - 40.70 | 0.6000 | 0.6000 |
| T9 | 5 | 2" Rigid Conduit | 21.01 - 40.70 | 0.6000 | 0.6000 |
| T9 | 6 | ATCB-B01-006(5/16") | 21.01 - 40.70 | 0.6000 | 0.6000 |
| T9 | 7 | RFFT-36SM-001-xxM(3/8") | 21.01 - 40.70 | 0.6000 | 0.6000 |

| Tower Section | Feed Line Record No. | Description | Feed Line Segment Elev. | K_a No Ice | K_a Ice |
|---------------|----------------------|-------------------------|-------------------------|--------------|-----------|
| T9 | 8 | PWRT-608-S(13/16") | 21.01 - 40.70 | 0.6000 | 0.6000 |
| T9 | 9 | LDF4-50A(1/2") | 21.01 - 40.70 | 0.6000 | 0.6000 |
| T9 | 11 | 04-001-54 (3/8" Cable) | 21.01 - 40.70 | 0.6000 | 0.6000 |
| T9 | 13 | Feedline Ladder (Af) | 21.01 - 40.70 | 0.6000 | 0.6000 |
| T9 | 14 | CR 50 1873(1-5/8") | 21.01 - 40.70 | 0.6000 | 0.6000 |
| T10 | 1 | Safety Line 3/8 | 1.33 - 21.01 | 0.6000 | 0.6000 |
| T10 | 3 | Feedline Ladder (Af) | 10.00 - 21.01 | 0.6000 | 0.6000 |
| T10 | 4 | AVA7-50(1-5/8) | 10.00 - 21.01 | 0.6000 | 0.6000 |
| T10 | 5 | 2" Rigid Conduit | 10.00 - 21.01 | 0.6000 | 0.6000 |
| T10 | 6 | ATCB-B01-006(5/16") | 10.00 - 21.01 | 0.6000 | 0.6000 |
| T10 | 7 | RFFT-36SM-001-xxM(3/8") | 10.00 - 21.01 | 0.6000 | 0.6000 |
| T10 | 8 | PWRT-608-S(13/16") | 10.00 - 21.01 | 0.6000 | 0.6000 |
| T10 | 9 | LDF4-50A(1/2") | 10.00 - 21.01 | 0.6000 | 0.6000 |
| T10 | 11 | 04-001-54 (3/8" Cable) | 10.00 - 21.01 | 0.6000 | 0.6000 |
| T10 | 13 | Feedline Ladder (Af) | 6.00 - 21.01 | 0.6000 | 0.6000 |
| T10 | 14 | CR 50 1873(1-5/8") | 8.00 - 21.01 | 0.6000 | 0.6000 |
| T11 | 1 | Safety Line 3/8 | 0.00 - 1.33 | 0.6000 | 0.6000 |

Discrete Tower Loads

| Description | Face or Leg | Offset Type | Offsets: Horz Lateral Vert ft ft ft | Azimuth Adjustmen t ° | Placement ft | $C_A A_A$ Front ft ² | $C_A A_A$ Side ft ² | Weight K | |
|-------------------------|-------------|-------------|---|-----------------------------|-----------------|------------------------------------|-----------------------------------|-------------|------|
| Lightning Rod 5/8"x8' | A | From Leg | 0.00 | 0.00 | 179.00 | No Ice | 0.50 | 0.50 | 0.01 |
| | | | 0.00 | | | 1/2" | 1.31 | 1.31 | 0.01 |
| | | | 4.00 | | | Ice | 2.14 | 2.14 | 0.02 |
| | | | | | | 1" Ice | | | |
| *** | | | | | | | | | |
| 6'x2" Mount Pipe | B | From Face | 0.50 | 0.00 | 176.00 | No Ice | 1.43 | 1.43 | 0.02 |
| | | | 1.50 | | | 1/2" | 1.92 | 1.92 | 0.03 |
| | | | 0.00 | | | Ice | 2.29 | 2.29 | 0.05 |
| | | | | | | 1" Ice | | | |
| ANT150F2 | B | From Face | 0.50 | 0.00 | 176.00 | No Ice | 1.23 | 1.23 | 0.01 |
| | | | 1.50 | | | 1/2" | 1.53 | 1.53 | 0.02 |
| | | | 1.00 | | | Ice | 1.84 | 1.84 | 0.04 |
| | | | | | | 1" Ice | | | |
| (2) ETD819G-12UB | B | From Face | 0.50 | 0.00 | 176.00 | No Ice | 1.84 | 0.45 | 0.03 |
| | | | 1.50 | | | 1/2" | 2.01 | 0.55 | 0.04 |
| | | | 1.00 | | | Ice | 2.19 | 0.66 | 0.06 |
| | | | | | | 1" Ice | | | |
| *** | | | | | | | | | |
| Sector Mount [SM 201-3] | C | None | | 0.00 | 176.00 | No Ice | 24.76 | 24.76 | 1.08 |
| | | | | | | 1/2" | 33.89 | 33.89 | 1.52 |
| | | | | | | Ice | 43.00 | 43.00 | 2.10 |
| | | | | | | 1" Ice | | | |

| Description | Face or Leg | Offset Type | Offsets: | | | Azimuth Adjustment | Placement | C _{AA} _{Front} | C _{AA} _{Side} | Weight | |
|---------------------------|-------------|-------------|----------|---------|------|--------------------|-----------|----------------------------------|---------------------------------|--------|--------|
| | | | Horz | Lateral | Vert | | | | | | ft |
| | | | ft | ft | ft | ° | ft | ft ² | ft ² | K | |
| Mount Modifications (3) | C | None | | | | 0.00 | 176.00 | No Ice | 5.00 | 5.00 | 50.00 |
| | | | | | | | | 1/2" | 6.00 | 6.00 | 75.00 |
| | | | | | | | | Ice | 7.00 | 7.00 | 100.00 |
| | | | | | | | | 1" Ice | | | |
| (12) 4' Vertical Unistrut | C | None | | | | 0.00 | 176.00 | No Ice | 12.80 | 12.80 | 50.00 |
| | | | | | | | | 1/2" | 19.20 | 19.20 | 75.00 |
| | | | | | | | | Ice | 25.60 | 25.60 | 100.00 |
| | | | | | | | | 1" Ice | | | |
| 6'x4" Mount Pipe | A | From Leg | 0.50 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 1.89 | 1.89 | 0.06 |
| | | | 0.00 | | | | | 1/2" | 2.62 | 2.62 | 0.08 |
| | | | 0.00 | | | | | Ice | 3.00 | 3.00 | 0.11 |
| | | | | | | | | 1" Ice | | | |
| 6'x4" Mount Pipe | B | From Leg | 0.50 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 1.89 | 1.89 | 0.06 |
| | | | 0.00 | | | | | 1/2" | 2.62 | 2.62 | 0.08 |
| | | | 0.00 | | | | | Ice | 3.00 | 3.00 | 0.11 |
| | | | | | | | | 1" Ice | | | |
| 6'x4" Mount Pipe | C | From Leg | 0.50 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 1.89 | 1.89 | 0.06 |
| | | | 0.00 | | | | | 1/2" | 2.62 | 2.62 | 0.08 |
| | | | 0.00 | | | | | Ice | 3.00 | 3.00 | 0.11 |
| | | | | | | | | 1" Ice | | | |
| DBXLH-8585A-R2M | A | From Leg | 2.00 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 4.95 | 2.70 | 0.04 |
| | | | 0.00 | | | | | 1/2" | 5.47 | 3.18 | 0.07 |
| | | | 4.00 | | | | | Ice | 6.02 | 3.67 | 0.11 |
| | | | | | | | | 1" Ice | | | |
| DBXLH-8585A-R2M | B | From Leg | 2.00 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 4.95 | 2.70 | 0.04 |
| | | | 0.00 | | | | | 1/2" | 5.47 | 3.18 | 0.07 |
| | | | 4.00 | | | | | Ice | 6.02 | 3.67 | 0.11 |
| | | | | | | | | 1" Ice | | | |
| DBXLH-8585A-R2M | C | From Leg | 2.00 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 4.95 | 2.70 | 0.04 |
| | | | 0.00 | | | | | 1/2" | 5.47 | 3.18 | 0.07 |
| | | | 4.00 | | | | | Ice | 6.02 | 3.67 | 0.11 |
| | | | | | | | | 1" Ice | | | |
| (4) ETD819G-12UB | A | From Leg | 2.00 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 1.84 | 0.45 | 0.03 |
| | | | 0.00 | | | | | 1/2" | 2.01 | 0.55 | 0.04 |
| | | | 0.00 | | | | | Ice | 2.19 | 0.66 | 0.06 |
| | | | | | | | | 1" Ice | | | |
| (4) ETD819G-12UB | A | From Leg | 2.00 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 1.84 | 0.45 | 0.03 |
| | | | 0.00 | | | | | 1/2" | 2.01 | 0.55 | 0.04 |
| | | | 4.00 | | | | | Ice | 2.19 | 0.66 | 0.06 |
| | | | | | | | | 1" Ice | | | |
| (2) ETD819G-12UB | B | From Leg | 2.00 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 1.84 | 0.45 | 0.03 |
| | | | 0.00 | | | | | 1/2" | 2.01 | 0.55 | 0.04 |
| | | | 0.00 | | | | | Ice | 2.19 | 0.66 | 0.06 |
| | | | | | | | | 1" Ice | | | |
| (2) ETD819G-12UB | B | From Leg | 2.00 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 1.84 | 0.45 | 0.03 |
| | | | 0.00 | | | | | 1/2" | 2.01 | 0.55 | 0.04 |
| | | | 4.00 | | | | | Ice | 2.19 | 0.66 | 0.06 |
| | | | | | | | | 1" Ice | | | |
| (2) NNHH-65A-R4 | A | From Leg | 2.00 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 5.71 | 2.32 | 0.07 |
| | | | 0.00 | | | | | 1/2" | 6.11 | 2.66 | 0.12 |
| | | | 4.00 | | | | | Ice | 6.52 | 3.01 | 0.19 |
| | | | | | | | | 1" Ice | | | |
| (2) NNHH-65A-R4 | B | From Leg | 2.00 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 5.71 | 2.32 | 0.07 |
| | | | 0.00 | | | | | 1/2" | 6.11 | 2.66 | 0.12 |
| | | | 4.00 | | | | | Ice | 6.52 | 3.01 | 0.19 |
| | | | | | | | | 1" Ice | | | |
| (2) NNHH-65A-R4 | C | From Leg | 2.00 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 5.71 | 2.32 | 0.07 |
| | | | 0.00 | | | | | 1/2" | 6.11 | 2.66 | 0.12 |
| | | | 4.00 | | | | | Ice | 6.52 | 3.01 | 0.19 |
| | | | | | | | | 1" Ice | | | |
| SBNHH-1D65C | A | From Leg | 2.00 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 5.67 | 3.40 | 0.05 |
| | | | 0.00 | | | | | 1/2" | 6.20 | 3.91 | 0.12 |
| | | | 4.00 | | | | | Ice | 6.74 | 4.43 | 0.19 |
| | | | | | | | | 1" Ice | | | |
| SBNHH-1D65C | B | From Leg | 2.00 | 0.00 | 0.00 | 0.00 | 176.00 | No Ice | 5.67 | 3.40 | 0.05 |
| | | | | | | | | | | | |

| Description | Face or Leg | Offset Type | Offsets: | | Azimuth Adjustment | Placement | C _{AA} Front | C _{AA} Side | Weight |
|----------------------------------|-------------|-------------|----------|---------|--------------------|-----------|-----------------------|----------------------|--------|
| | | | Horz | Lateral | | | | | |
| | | | ft | ft | ° | ft | ft ² | ft ² | K |
| | | | 0.00 | | | 1/2" | 6.20 | 3.91 | 0.12 |
| | | | 4.00 | | | Ice | 6.74 | 4.43 | 0.19 |
| SBNHH-1D65C | C | From Leg | 2.00 | 0.00 | 176.00 | 1" Ice | 5.67 | 3.40 | 0.05 |
| | | | 0.00 | | | No Ice | 6.20 | 3.91 | 0.12 |
| | | | 4.00 | | | Ice | 6.74 | 4.43 | 0.19 |
| (3) B25 RRH4x30-4R | A | From Leg | 2.00 | 0.00 | 176.00 | 1" Ice | 2.14 | 1.31 | 0.05 |
| | | | 0.00 | | | No Ice | 2.33 | 1.46 | 0.07 |
| | | | 4.00 | | | Ice | 2.53 | 1.63 | 0.09 |
| DC6-48-60-18-8F | A | From Leg | 2.00 | 0.00 | 176.00 | 1" Ice | 0.92 | 0.92 | 0.02 |
| | | | 0.00 | | | No Ice | 1.46 | 1.46 | 0.04 |
| | | | 4.00 | | | Ice | 1.64 | 1.64 | 0.06 |
| DC6-48-60-18-8F | B | From Leg | 2.00 | 0.00 | 176.00 | 1" Ice | 0.92 | 0.92 | 0.02 |
| | | | 0.00 | | | No Ice | 1.46 | 1.46 | 0.04 |
| | | | 4.00 | | | Ice | 1.64 | 1.64 | 0.06 |
| (2) RRH4X25-WCS | B | From Leg | 2.00 | 0.00 | 176.00 | 1" Ice | 3.16 | 2.38 | 0.07 |
| | | | 0.00 | | | No Ice | 3.40 | 2.60 | 0.10 |
| | | | 4.00 | | | Ice | 3.65 | 2.82 | 0.13 |
| RRH4X25-WCS | C | From Leg | 2.00 | 0.00 | 176.00 | 1" Ice | 3.16 | 2.38 | 0.07 |
| | | | 0.00 | | | No Ice | 3.40 | 2.60 | 0.10 |
| | | | 4.00 | | | Ice | 3.65 | 2.82 | 0.13 |
| RRH2X40-07-L-AT | B | From Leg | 2.00 | 0.00 | 176.00 | 1" Ice | 2.38 | 1.26 | 0.05 |
| | | | 0.00 | | | No Ice | 2.58 | 1.43 | 0.07 |
| | | | 0.00 | | | Ice | 2.79 | 1.60 | 0.09 |
| (2) RRH2X40-07-L-AT | C | From Leg | 2.00 | 0.00 | 176.00 | 1" Ice | 2.38 | 1.26 | 0.05 |
| | | | 0.00 | | | No Ice | 2.58 | 1.43 | 0.07 |
| | | | 0.00 | | | Ice | 2.79 | 1.60 | 0.09 |
| AIRSCALE RRH 4T4R B5 160W | A | From Leg | 2.00 | 0.00 | 176.00 | 1" Ice | 1.29 | 0.72 | 0.04 |
| | | | 0.00 | | | No Ice | 1.43 | 0.83 | 0.05 |
| | | | 4.00 | | | Ice | 1.58 | 0.96 | 0.06 |
| (2) AIRSCALE RRH 4T4R B5 160W | B | From Leg | 2.00 | 0.00 | 176.00 | 1" Ice | 1.29 | 0.72 | 0.04 |
| | | | 0.00 | | | No Ice | 1.43 | 0.83 | 0.05 |
| | | | 4.00 | | | Ice | 1.58 | 0.96 | 0.06 |
| jsource technologies 12128FM4SEC | B | From Leg | 2.00 | 0.00 | 176.00 | 1" Ice | 1.20 | 0.80 | 0.01 |
| | | | 0.00 | | | No Ice | 1.34 | 0.91 | 0.02 |
| | | | 0.00 | | | Ice | 1.48 | 1.04 | 0.03 |
| *** | | | | | | 1" Ice | | | |
| Pipe Mount [PM 602-1] | A | From Leg | 1.00 | 0.00 | 160.00 | 1" Ice | 2.78 | 2.78 | 0.09 |
| | | | 0.00 | | | No Ice | 3.21 | 3.21 | 0.11 |
| | | | 0.00 | | | Ice | 3.64 | 3.64 | 0.14 |
| (2) 10' Tieback | A | From Face | 2.00 | 0.00 | 160.00 | 1" Ice | 2.38 | 0.25 | 0.04 |
| | | | 0.00 | | | No Ice | 3.38 | 0.50 | 0.05 |
| | | | 0.00 | | | Ice | 4.38 | 0.75 | 0.07 |
| 10' Tieback | B | From Face | 2.00 | 0.00 | 160.00 | 1" Ice | 2.38 | 0.25 | 0.04 |
| | | | 0.00 | | | No Ice | 3.38 | 0.50 | 0.05 |
| | | | 0.00 | | | Ice | 4.38 | 0.75 | 0.07 |
| FIBEAIR IP-10 | A | From Leg | 2.00 | 0.00 | 160.00 | 1" Ice | 1.01 | 0.56 | 0.02 |
| | | | 0.00 | | | No Ice | 1.14 | 0.66 | 0.02 |
| | | | 0.00 | | | Ice | 1.28 | 0.77 | 0.03 |
| *** | | | | | | 1" Ice | | | |

| Description | Face or Leg | Offset Type | Offsets: | | | Azimuth Adjustment | Placement | C _{AA} _{Front} | C _{AA} _{Side} | Weight | |
|------------------------------------|-------------|-------------|----------|---------|------|--------------------|-----------|----------------------------------|---------------------------------|--------|------|
| | | | Horz | Lateral | Vert | | | | | | ft |
| | | | ft | ft | ft | ° | ft | ft ² | ft ² | K | |
| Sector Mount [SM 801-3] | C | None | | | | 0.00 | 150.00 | No Ice | 20.61 | 20.61 | 0.88 |
| | | | | | | | | 1/2" | 29.42 | 29.42 | 1.28 |
| | | | | | | | | Ice | 38.23 | 38.23 | 1.82 |
| | | | | | | | | 1" Ice | | | |
| Mount Reinforcement Specifications | C | None | | | | 0.00 | 150.00 | No Ice | 28.63 | 28.63 | 0.00 |
| | | | | | | | | 1/2" | 34.69 | 34.69 | 0.00 |
| | | | | | | | | Ice | 40.75 | 40.75 | 0.00 |
| | | | | | | | | 1" Ice | | | |
| (2) QS8656-5 w/ Mount Pipe | A | From Leg | 4.00 | 0.00 | 0.00 | 0.00 | 150.00 | No Ice | 5.42 | 5.62 | 0.12 |
| | | | 0.00 | | | | | 1/2" | 5.92 | 6.12 | 0.21 |
| | | | 0.00 | | | | | Ice | 6.43 | 6.63 | 0.31 |
| | | | | | | | | 1" Ice | | | |
| (2) QS8656-5 w/ Mount Pipe | B | From Leg | 4.00 | 0.00 | 0.00 | 0.00 | 150.00 | No Ice | 5.42 | 5.62 | 0.12 |
| | | | 0.00 | | | | | 1/2" | 5.92 | 6.12 | 0.21 |
| | | | 0.00 | | | | | Ice | 6.43 | 6.63 | 0.31 |
| | | | | | | | | 1" Ice | | | |
| (2) QS8656-5 w/ Mount Pipe | C | From Leg | 4.00 | 0.00 | 0.00 | 0.00 | 150.00 | No Ice | 5.42 | 5.62 | 0.12 |
| | | | 0.00 | | | | | 1/2" | 5.92 | 6.12 | 0.21 |
| | | | 0.00 | | | | | Ice | 6.43 | 6.63 | 0.31 |
| | | | | | | | | 1" Ice | | | |
| RF4439D-25A | A | From Leg | 4.00 | 0.00 | 0.00 | 0.00 | 150.00 | No Ice | 1.87 | 1.25 | 0.07 |
| | | | 0.00 | | | | | 1/2" | 2.03 | 1.39 | 0.09 |
| | | | 0.00 | | | | | Ice | 2.21 | 1.54 | 0.11 |
| | | | | | | | | 1" Ice | | | |
| RF4439D-25A | B | From Leg | 4.00 | 0.00 | 0.00 | 0.00 | 150.00 | No Ice | 1.87 | 1.25 | 0.07 |
| | | | 0.00 | | | | | 1/2" | 2.03 | 1.39 | 0.09 |
| | | | 0.00 | | | | | Ice | 2.21 | 1.54 | 0.11 |
| | | | | | | | | 1" Ice | | | |
| RF4439D-25A | C | From Leg | 4.00 | 0.00 | 0.00 | 0.00 | 150.00 | No Ice | 1.87 | 1.25 | 0.07 |
| | | | 0.00 | | | | | 1/2" | 2.03 | 1.39 | 0.09 |
| | | | 0.00 | | | | | Ice | 2.21 | 1.54 | 0.11 |
| | | | | | | | | 1" Ice | | | |
| RF4440D-13A | A | From Leg | 4.00 | 0.00 | 0.00 | 0.00 | 150.00 | No Ice | 1.87 | 1.13 | 0.07 |
| | | | 0.00 | | | | | 1/2" | 2.03 | 1.27 | 0.09 |
| | | | 0.00 | | | | | Ice | 2.21 | 1.41 | 0.11 |
| | | | | | | | | 1" Ice | | | |
| RF4440D-13A | B | From Leg | 4.00 | 0.00 | 0.00 | 0.00 | 150.00 | No Ice | 1.87 | 1.13 | 0.07 |
| | | | 0.00 | | | | | 1/2" | 2.03 | 1.27 | 0.09 |
| | | | 0.00 | | | | | Ice | 2.21 | 1.41 | 0.11 |
| | | | | | | | | 1" Ice | | | |
| RF4440D-13A | C | From Leg | 4.00 | 0.00 | 0.00 | 0.00 | 150.00 | No Ice | 1.87 | 1.13 | 0.07 |
| | | | 0.00 | | | | | 1/2" | 2.03 | 1.27 | 0.09 |
| | | | 0.00 | | | | | Ice | 2.21 | 1.41 | 0.11 |
| | | | | | | | | 1" Ice | | | |
| MT6407-77A w/ Mount Pipe | A | From Leg | 4.00 | 0.00 | 0.00 | 0.00 | 150.00 | No Ice | 4.91 | 2.68 | 0.10 |
| | | | 0.00 | | | | | 1/2" | 5.26 | 3.14 | 0.14 |
| | | | 0.00 | | | | | Ice | 5.61 | 3.62 | 0.18 |
| | | | | | | | | 1" Ice | | | |
| MT6407-77A w/ Mount Pipe | B | From Leg | 4.00 | 0.00 | 0.00 | 0.00 | 150.00 | No Ice | 4.91 | 2.68 | 0.10 |
| | | | 0.00 | | | | | 1/2" | 5.26 | 3.14 | 0.14 |
| | | | 0.00 | | | | | Ice | 5.61 | 3.62 | 0.18 |
| | | | | | | | | 1" Ice | | | |
| MT6407-77A w/ Mount Pipe | C | From Leg | 4.00 | 0.00 | 0.00 | 0.00 | 150.00 | No Ice | 4.91 | 2.68 | 0.10 |
| | | | 0.00 | | | | | 1/2" | 5.26 | 3.14 | 0.14 |
| | | | 0.00 | | | | | Ice | 5.61 | 3.62 | 0.18 |
| | | | | | | | | 1" Ice | | | |
| RVZDC-6627-PF-48 | B | From Leg | 4.00 | 0.00 | 0.00 | 0.00 | 150.00 | No Ice | 3.79 | 2.51 | 0.03 |
| | | | 0.00 | | | | | 1/2" | 4.04 | 2.73 | 0.06 |
| | | | 0.00 | | | | | Ice | 4.30 | 2.95 | 0.10 |
| | | | | | | | | 1" Ice | | | |

Dishes

| Description | Face or Leg | Dish Type | Offset Type | Offsets: Horz Lateral Vert ft | Azimuth Adjustment ° | 3 dB Beam Width ° | Elevation ft | Outside Diameter ft | Aperture Area ft ² | Weight K | |
|-------------|-------------------|-----------------------------|----------------|---|----------------------------|----------------------------|-----------------|---------------------------|-------------------------------------|-------------|------|
| HPX8-59 | A | Paraboloid w/Shroud (HP) | From Leg | 2.00 | 41.00 | | 160.00 | 8.38 | No Ice | 55.09 | 0.30 |
| | | | | 0.00 | | | | | 1/2" Ice | 56.19 | 0.59 |
| | | | | 0.00 | | | | | 1" Ice | 57.29 | 0.88 |

Load Combinations

| Comb. No. | Description |
|--------------|--|
| 1 | Dead Only |
| 2 | 1.2 Dead+1.0 Wind 0 deg - No Ice |
| 3 | 0.9 Dead+1.0 Wind 0 deg - No Ice |
| 4 | 1.2 Dead+1.0 Wind 30 deg - No Ice |
| 5 | 0.9 Dead+1.0 Wind 30 deg - No Ice |
| 6 | 1.2 Dead+1.0 Wind 60 deg - No Ice |
| 7 | 0.9 Dead+1.0 Wind 60 deg - No Ice |
| 8 | 1.2 Dead+1.0 Wind 90 deg - No Ice |
| 9 | 0.9 Dead+1.0 Wind 90 deg - No Ice |
| 10 | 1.2 Dead+1.0 Wind 120 deg - No Ice |
| 11 | 0.9 Dead+1.0 Wind 120 deg - No Ice |
| 12 | 1.2 Dead+1.0 Wind 150 deg - No Ice |
| 13 | 0.9 Dead+1.0 Wind 150 deg - No Ice |
| 14 | 1.2 Dead+1.0 Wind 180 deg - No Ice |
| 15 | 0.9 Dead+1.0 Wind 180 deg - No Ice |
| 16 | 1.2 Dead+1.0 Wind 210 deg - No Ice |
| 17 | 0.9 Dead+1.0 Wind 210 deg - No Ice |
| 18 | 1.2 Dead+1.0 Wind 240 deg - No Ice |
| 19 | 0.9 Dead+1.0 Wind 240 deg - No Ice |
| 20 | 1.2 Dead+1.0 Wind 270 deg - No Ice |
| 21 | 0.9 Dead+1.0 Wind 270 deg - No Ice |
| 22 | 1.2 Dead+1.0 Wind 300 deg - No Ice |
| 23 | 0.9 Dead+1.0 Wind 300 deg - No Ice |
| 24 | 1.2 Dead+1.0 Wind 330 deg - No Ice |
| 25 | 0.9 Dead+1.0 Wind 330 deg - No Ice |
| 26 | 1.2 Dead+1.0 Ice+1.0 Temp |
| 27 | 1.2 Dead+1.0 Wind 0 deg+1.0 Ice+1.0 Temp |
| 28 | 1.2 Dead+1.0 Wind 30 deg+1.0 Ice+1.0 Temp |
| 29 | 1.2 Dead+1.0 Wind 60 deg+1.0 Ice+1.0 Temp |
| 30 | 1.2 Dead+1.0 Wind 90 deg+1.0 Ice+1.0 Temp |
| 31 | 1.2 Dead+1.0 Wind 120 deg+1.0 Ice+1.0 Temp |
| 32 | 1.2 Dead+1.0 Wind 150 deg+1.0 Ice+1.0 Temp |
| 33 | 1.2 Dead+1.0 Wind 180 deg+1.0 Ice+1.0 Temp |
| 34 | 1.2 Dead+1.0 Wind 210 deg+1.0 Ice+1.0 Temp |
| 35 | 1.2 Dead+1.0 Wind 240 deg+1.0 Ice+1.0 Temp |
| 36 | 1.2 Dead+1.0 Wind 270 deg+1.0 Ice+1.0 Temp |
| 37 | 1.2 Dead+1.0 Wind 300 deg+1.0 Ice+1.0 Temp |
| 38 | 1.2 Dead+1.0 Wind 330 deg+1.0 Ice+1.0 Temp |
| 39 | Dead+Wind 0 deg - Service |
| 40 | Dead+Wind 30 deg - Service |
| 41 | Dead+Wind 60 deg - Service |
| 42 | Dead+Wind 90 deg - Service |
| 43 | Dead+Wind 120 deg - Service |
| 44 | Dead+Wind 150 deg - Service |
| 45 | Dead+Wind 180 deg - Service |
| 46 | Dead+Wind 210 deg - Service |
| 47 | Dead+Wind 240 deg - Service |
| 48 | Dead+Wind 270 deg - Service |
| 49 | Dead+Wind 300 deg - Service |
| 50 | Dead+Wind 330 deg - Service |

Maximum Member Forces

| Section No. | Elevation ft | Component Type | Condition | Gov. Load Comb. | Axial K | Major Axis Moment kip-ft | Minor Axis Moment kip-ft | | |
|-------------|-------------------|----------------|-------------------|-----------------|------------------|--------------------------|--------------------------|-------|-------|
| T1 | 179.098 - 159.41 | Leg | Max Tension | 1 | 0.00 | 0.00 | 0.00 | | |
| | | | Max. Compression | 31 | -81.63 | 0.28 | 0.15 | | |
| | | | Max. Mx | 20 | -44.17 | -1.21 | -0.00 | | |
| | | | Max. My | 14 | -43.88 | 0.04 | 1.36 | | |
| | | | Max. Vy | 9 | 1.38 | -0.25 | 0.19 | | |
| | | Diagonal | Max. Vx | 16 | 1.20 | -0.05 | -0.20 | | |
| | | | Max Tension | 24 | 3.35 | 0.00 | 0.00 | | |
| | | | Max. Compression | 16 | -4.24 | 0.00 | 0.00 | | |
| | | | Max. Mx | 27 | -1.01 | 0.08 | 0.00 | | |
| | | | Max. My | 12 | 2.39 | -0.02 | 0.01 | | |
| | | | Max. Vy | 27 | -0.03 | 0.08 | 0.00 | | |
| | | | Max. Vx | 12 | 0.00 | -0.02 | 0.01 | | |
| | | Top Girt | Max Tension | 1 | 0.00 | 0.00 | 0.00 | | |
| | | | Max. Compression | 35 | -0.55 | 0.00 | 0.00 | | |
| | | | Max. Mx | 26 | -0.52 | -0.03 | 0.00 | | |
| T2 | 159.41 - 158.827 | Leg | Max Tension | 1 | 0.00 | 0.00 | 0.00 | | |
| | | | Max. Compression | 27 | -84.37 | -0.02 | 0.32 | | |
| | | | Max. Mx | 18 | -69.14 | 2.22 | -2.06 | | |
| | | | Max. My | 2 | -71.74 | -0.38 | 2.85 | | |
| | | | Max. Vy | 18 | -3.89 | 2.22 | -2.06 | | |
| | | Diagonal | Max. Vx | 2 | -4.91 | -0.38 | 2.85 | | |
| | | | Max Tension | 15 | 24.58 | -0.74 | -0.03 | | |
| | | | Max. Compression | 2 | -100.43 | 0.35 | 0.09 | | |
| | | | Max. Mx | 18 | -72.64 | 2.95 | -0.67 | | |
| | | | Max. My | 8 | -41.35 | 0.97 | 1.51 | | |
| | | | Max. Vy | 22 | -0.73 | -0.94 | 0.11 | | |
| | | | Max. Vx | 24 | 0.67 | -0.49 | 0.79 | | |
| | | T3 | 158.827 - 139.139 | Leg | Max Tension | 15 | 24.58 | -0.74 | -0.03 |
| | | | | | Max. Compression | 2 | -100.43 | 0.35 | 0.09 |
| | | | | | Max. Mx | 18 | -72.64 | 2.95 | -0.67 |
| Max. My | 8 | | | | -41.35 | 0.97 | 1.51 | | |
| Max. Vy | 22 | | | | -0.73 | -0.94 | 0.11 | | |
| Diagonal | Max. Vx | | | 24 | 0.67 | -0.49 | 0.79 | | |
| | Max Tension | | | 16 | 5.90 | 0.00 | 0.00 | | |
| | Max. Compression | | | 16 | -6.70 | 0.00 | 0.00 | | |
| | Max. Mx | | | 27 | 1.34 | 0.06 | 0.00 | | |
| | Max. My | | | 8 | -4.25 | 0.00 | 0.01 | | |
| | Max. Vy | | | 27 | -0.03 | 0.06 | 0.00 | | |
| | Max. Vx | | | 8 | -0.00 | 0.00 | 0.00 | | |
| T4 | 139.139 - 119.452 | | | Leg | Max Tension | 15 | 54.25 | -0.82 | -0.08 |
| | | | | | Max. Compression | 2 | -131.98 | 1.02 | 0.05 |
| | | | | | Max. Mx | 2 | -122.34 | 1.09 | 0.04 |
| | | Max. My | 24 | | -41.31 | -0.24 | 0.94 | | |
| | | Max. Vy | 2 | | -0.16 | 1.09 | 0.04 | | |
| | | Diagonal | Max. Vx | 13 | 0.14 | -0.13 | -0.94 | | |
| | | | Max Tension | 16 | 5.23 | 0.00 | 0.00 | | |
| | | | Max. Compression | 17 | -5.01 | 0.00 | 0.00 | | |
| | | | Max. Mx | 27 | 0.75 | 0.05 | 0.00 | | |
| | | | Max. My | 14 | 2.60 | 0.03 | -0.01 | | |
| | | | Max. Vy | 27 | -0.02 | 0.05 | 0.00 | | |
| | | | Max. Vx | 14 | 0.00 | 0.00 | 0.00 | | |
| | | T5 | 119.452 - 99.7642 | Leg | Max Tension | 15 | 78.55 | -1.31 | -0.08 |
| | | | | | Max. Compression | 2 | -158.71 | 1.34 | 0.05 |
| | | | | | Max. Mx | 18 | -149.58 | 1.58 | -0.03 |
| Max. My | 16 | | | | -44.25 | -0.10 | 1.43 | | |
| Max. Vy | 14 | | | | 0.15 | -1.35 | -0.07 | | |
| Diagonal | Max. Vx | | | 13 | 0.15 | 0.15 | -1.12 | | |
| | Max Tension | | | 16 | 4.72 | 0.00 | 0.00 | | |
| | Max. Compression | | | 16 | -4.76 | 0.00 | 0.00 | | |
| | Max. Mx | | | 27 | 0.65 | 0.05 | 0.00 | | |
| | Max. My | | | 14 | 2.35 | 0.02 | -0.01 | | |
| | Max. Vy | | | 35 | -0.03 | 0.05 | -0.00 | | |
| | Max. Vx | | | 14 | 0.00 | 0.00 | 0.00 | | |
| T6 | 99.7642 - 80.0767 | | | Leg | Max Tension | 15 | 100.70 | -1.26 | -0.06 |

| Section No. | Elevation ft | Component Type | Condition | Gov. Load Comb. | Axial K | Major Axis Moment kip-ft | Minor Axis Moment kip-ft |
|-------------|-------------------|----------------|------------------|-----------------|---------|--------------------------|--------------------------|
| T7 | 80.0767 - 60.3892 | Diagonal | Max. Compression | 2 | -183.39 | 1.71 | 0.15 |
| | | | Max. Mx | 2 | -183.39 | 1.71 | 0.15 |
| | | | Max. My | 13 | -41.51 | 0.11 | -1.56 |
| | | | Max. Vy | 2 | -0.15 | 1.71 | 0.15 |
| | | | Max. Vx | 12 | 0.13 | 0.12 | -1.56 |
| | | | Max Tension | 16 | 4.83 | 0.00 | 0.00 |
| | | | Max. Compression | 16 | -4.89 | 0.00 | 0.00 |
| | | Leg | Max. Mx | 35 | 0.49 | 0.05 | -0.00 |
| | | | Max. My | 14 | -4.36 | 0.00 | -0.01 |
| | | | Max. Vy | 35 | -0.03 | 0.05 | -0.00 |
| | | | Max. Vx | 33 | 0.00 | 0.00 | 0.00 |
| | | | Max Tension | 15 | 121.44 | -1.21 | -0.05 |
| | | | Max. Compression | 2 | -207.78 | 1.64 | 0.05 |
| | | | Max. Mx | 2 | -191.37 | 1.71 | 0.15 |
| T8 | 60.3892 - 40.7017 | Diagonal | Max. My | 16 | -47.08 | -0.03 | 1.64 |
| | | | Max. Vy | 2 | 0.15 | 1.71 | 0.15 |
| | | | Max. Vx | 24 | -0.19 | -0.06 | 1.57 |
| | | | Max Tension | 16 | 5.24 | 0.00 | 0.00 |
| | | | Max. Compression | 16 | -5.22 | 0.00 | 0.00 |
| | | | Max. Mx | 35 | 0.91 | 0.06 | -0.01 |
| | | | Max. My | 33 | -0.88 | 0.04 | -0.01 |
| | | Leg | Max. Vy | 35 | -0.04 | 0.06 | -0.01 |
| | | | Max. Vx | 33 | 0.00 | 0.00 | 0.00 |
| | | | Max Tension | 15 | 139.34 | -2.15 | -0.12 |
| | | | Max. Compression | 2 | -228.91 | 2.88 | 0.22 |
| | | | Max. Mx | 2 | -228.91 | 2.88 | 0.22 |
| | | | Max. My | 16 | -47.97 | -0.30 | 2.59 |
| | | | Max. Vy | 2 | -0.22 | 2.88 | 0.22 |
| T9 | 40.7017 - 21.0142 | Diagonal | Max. Vx | 24 | -0.25 | -0.34 | 2.49 |
| | | | Max Tension | 16 | 6.10 | 0.00 | 0.00 |
| | | | Max. Compression | 16 | -6.03 | 0.00 | 0.00 |
| | | | Max. Mx | 35 | 0.93 | 0.09 | -0.01 |
| | | | Max. My | 32 | 0.87 | 0.08 | -0.01 |
| | | | Max. Vy | 35 | -0.05 | 0.09 | -0.01 |
| | | | Max. Vx | 32 | 0.00 | 0.00 | 0.00 |
| | | Leg | Max Tension | 15 | 158.57 | -2.39 | -0.11 |
| | | | Max. Compression | 2 | -251.81 | 0.93 | 0.03 |
| | | | Max. Mx | 2 | -239.87 | 2.88 | 0.22 |
| | | | Max. My | 16 | -49.07 | -0.28 | 2.38 |
| | | | Max. Vy | 34 | 0.32 | -1.90 | -0.16 |
| | | | Max. Vx | 24 | 0.20 | -0.32 | 2.30 |
| | | | Max Tension | 17 | 6.41 | 0.00 | 0.00 |
| T10 | 21.0142 - 1.32667 | Diagonal | Max. Compression | 16 | -6.59 | 0.00 | 0.00 |
| | | | Max. Mx | 35 | 1.27 | 0.12 | -0.01 |
| | | | Max. My | 32 | 1.35 | 0.12 | -0.01 |
| | | | Max. Vy | 33 | 0.06 | 0.10 | -0.01 |
| | | | Max. Vx | 32 | 0.00 | 0.00 | 0.00 |
| | | | Max Tension | 15 | 177.86 | -7.79 | -0.32 |
| | | | Max. Compression | 2 | -275.56 | -27.81 | -1.17 |
| | | Leg | Max. Mx | 2 | -275.56 | -27.81 | -1.17 |
| | | | Max. My | 12 | -61.74 | -3.59 | 5.31 |
| | | | Max. Vy | 2 | 3.80 | 8.83 | 0.26 |
| | | | Max. Vx | 12 | -0.95 | 0.67 | -3.08 |
| | | | Max Tension | 16 | 9.03 | 0.00 | 0.00 |
| | | | Max. Compression | 17 | -8.73 | 0.00 | 0.00 |
| | | | Max. Mx | 35 | -0.20 | 0.13 | -0.01 |
| T11 | 1.32667 - 0 | Leg | Max. My | 32 | 0.39 | 0.09 | -0.02 |
| | | | Max. Vy | 33 | 0.06 | 0.12 | -0.01 |
| | | | Max. Vx | 32 | 0.00 | 0.00 | 0.00 |
| | | | Max Tension | 15 | 183.80 | -1.26 | 21.68 |
| | | | Max. Compression | 2 | -282.24 | 0.00 | 0.00 |
| | | | Max. Mx | 18 | -279.37 | -23.42 | 13.91 |
| | | | Max. My | 2 | -282.13 | 1.17 | -27.81 |
| | | | Max. Vy | 18 | -17.66 | 0.00 | 0.00 |
| | | | Max. Vx | 2 | -20.97 | 0.00 | 0.00 |
| | | | | | | | |

| Section No. | Elevation ft | Component Type | Condition | Gov. Load Comb. | Axial K | Major Axis Moment kip-ft | Minor Axis Moment kip-ft |
|-------------|--------------|----------------|-----------|-----------------|---------|--------------------------|--------------------------|
|-------------|--------------|----------------|-----------|-----------------|---------|--------------------------|--------------------------|

Maximum Reactions

| Location | Condition | Gov. Load Comb. | Vertical K | Horizontal, X K | Horizontal, Z K |
|----------|---------------------|-----------------|------------|-----------------|-----------------|
| Leg C | Max. Vert | 18 | 279.48 | 17.66 | -10.49 |
| | Max. H _x | 18 | 279.48 | 17.66 | -10.49 |
| | Max. H _z | 5 | -153.35 | -11.11 | 8.86 |
| | Min. Vert | 7 | -171.53 | -13.26 | 7.92 |
| | Min. H _x | 7 | -171.53 | -13.26 | 7.92 |
| Leg B | Min. H _z | 16 | 252.98 | 14.73 | -11.04 |
| | Max. Vert | 10 | 269.59 | -17.54 | -9.63 |
| | Max. H _x | 23 | -168.44 | 13.37 | 7.21 |
| | Max. H _z | 25 | -147.19 | 11.39 | 7.39 |
| | Min. Vert | 23 | -168.44 | 13.37 | 7.21 |
| Leg A | Min. H _x | 10 | 269.59 | -17.54 | -9.63 |
| | Min. H _z | 10 | 269.59 | -17.54 | -9.63 |
| | Max. Vert | 2 | 282.24 | -0.88 | 20.97 |
| | Max. H _x | 19 | -75.88 | 2.94 | -7.65 |
| | Max. H _z | 2 | 282.24 | -0.88 | 20.97 |
| | Min. Vert | 15 | -183.72 | 0.95 | -16.35 |
| | Min. H _x | 8 | 60.17 | -2.84 | 2.65 |
| | Min. H _z | 15 | -183.72 | 0.95 | -16.35 |

Tower Mast Reaction Summary

| Load Combination | Vertical K | Shear _x K | Shear _z K | Overturning Moment, M _x kip-ft | Overturning Moment, M _z kip-ft | Torque kip-ft |
|------------------------------------|------------|----------------------|----------------------|---|---|---------------|
| Dead Only | 134.20 | -0.00 | -0.00 | 1.00 | 12.18 | 0.00 |
| 1.2 Dead+1.0 Wind 0 deg - No Ice | 161.04 | 0.60 | -32.95 | -3562.92 | -80.65 | -26.14 |
| 0.9 Dead+1.0 Wind 0 deg - No Ice | 120.78 | 0.60 | -32.95 | -3563.23 | -84.31 | -26.14 |
| 1.2 Dead+1.0 Wind 30 deg - No Ice | 161.04 | 16.02 | -27.64 | -3019.90 | -1737.63 | -17.57 |
| 0.9 Dead+1.0 Wind 30 deg - No Ice | 120.78 | 16.02 | -27.64 | -3020.20 | -1741.28 | -17.57 |
| 1.2 Dead+1.0 Wind 60 deg - No Ice | 161.04 | 25.95 | -15.31 | -1695.66 | -2829.45 | -6.92 |
| 0.9 Dead+1.0 Wind 60 deg - No Ice | 120.78 | 25.95 | -15.31 | -1695.96 | -2833.11 | -6.92 |
| 1.2 Dead+1.0 Wind 90 deg - No Ice | 161.04 | 27.42 | -0.65 | -101.11 | -3007.08 | -5.25 |
| 0.9 Dead+1.0 Wind 90 deg - No Ice | 120.78 | 27.42 | -0.65 | -101.41 | -3010.73 | -5.25 |
| 1.2 Dead+1.0 Wind 120 deg - No Ice | 161.04 | 27.25 | 15.37 | 1649.23 | -2934.13 | 12.56 |
| 0.9 Dead+1.0 Wind 120 deg - No Ice | 120.78 | 27.25 | 15.37 | 1648.93 | -2937.79 | 12.56 |
| 1.2 Dead+1.0 Wind 150 deg - No Ice | 161.04 | 15.02 | 27.43 | 3010.02 | -1590.37 | 28.96 |
| 0.9 Dead+1.0 Wind 150 deg - No Ice | 120.78 | 15.02 | 27.43 | 3009.72 | -1594.02 | 28.96 |
| 1.2 Dead+1.0 Wind 180 deg - No Ice | 161.04 | -0.78 | 31.71 | 3491.79 | 139.17 | 28.65 |
| 0.9 Dead+1.0 Wind 180 deg - No Ice | 120.78 | -0.78 | 31.71 | 3491.49 | 135.51 | 28.65 |
| 1.2 Dead+1.0 Wind 210 deg - No Ice | 161.04 | -16.31 | 27.97 | 3075.21 | 1811.91 | 19.54 |

| Load Combination | Vertical K | Shear _x K | Shear _z K | Overturning Moment, M _x kip-ft | Overturning Moment, M _z kip-ft | Torque kip-ft |
|--|---------------|-------------------------|-------------------------|--|--|------------------|
| 0.9 Dead+1.0 Wind 210 deg - No Ice | 120.78 | -16.31 | 27.97 | 3074.91 | 1808.25 | 19.54 |
| 1.2 Dead+1.0 Wind 240 deg - No Ice | 161.04 | -27.62 | 16.41 | 1810.66 | 3019.00 | 7.16 |
| 0.9 Dead+1.0 Wind 240 deg - No Ice | 120.78 | -27.62 | 16.41 | 1810.36 | 3015.34 | 7.16 |
| 1.2 Dead+1.0 Wind 270 deg - No Ice | 161.04 | -27.65 | 0.93 | 148.30 | 3074.57 | 4.57 |
| 0.9 Dead+1.0 Wind 270 deg - No Ice | 120.78 | -27.65 | 0.93 | 148.00 | 3070.92 | 4.57 |
| 1.2 Dead+1.0 Wind 300 deg - No Ice | 161.04 | -25.81 | -14.63 | -1590.19 | 2842.01 | -13.56 |
| 0.9 Dead+1.0 Wind 300 deg - No Ice | 120.78 | -25.81 | -14.63 | -1590.50 | 2838.35 | -13.56 |
| 1.2 Dead+1.0 Wind 330 deg - No Ice | 161.04 | -15.20 | -27.35 | -2994.25 | 1648.89 | -26.99 |
| 0.9 Dead+1.0 Wind 330 deg - No Ice | 120.78 | -15.20 | -27.35 | -2994.55 | 1645.23 | -26.99 |
| 1.2 Dead+1.0 Ice+1.0 Temp | 294.30 | -0.00 | 0.00 | 17.87 | 46.85 | 0.00 |
| 1.2 Dead+1.0 Wind 0 deg+1.0 Ice+1.0 Temp | 294.30 | 0.08 | -6.72 | -704.21 | 34.65 | -7.74 |
| 1.2 Dead+1.0 Wind 30 deg+1.0 Ice+1.0 Temp | 294.30 | 3.29 | -5.67 | -594.35 | -307.96 | -4.59 |
| 1.2 Dead+1.0 Wind 60 deg+1.0 Ice+1.0 Temp | 294.30 | 5.00 | -2.92 | -302.74 | -497.24 | -1.29 |
| 1.2 Dead+1.0 Wind 90 deg+1.0 Ice+1.0 Temp | 294.30 | 5.45 | -0.08 | 4.74 | -548.75 | 0.28 |
| 1.2 Dead+1.0 Wind 120 deg+1.0 Ice+1.0 Temp | 294.30 | 5.12 | 2.91 | 330.00 | -506.78 | 3.78 |
| 1.2 Dead+1.0 Wind 150 deg+1.0 Ice+1.0 Temp | 294.30 | 3.14 | 5.62 | 626.21 | -287.64 | 8.70 |
| 1.2 Dead+1.0 Wind 180 deg+1.0 Ice+1.0 Temp | 294.30 | -0.10 | 6.58 | 732.51 | 62.93 | 8.07 |
| 1.2 Dead+1.0 Wind 210 deg+1.0 Ice+1.0 Temp | 294.30 | -3.32 | 5.72 | 637.10 | 407.63 | 4.85 |
| 1.2 Dead+1.0 Wind 240 deg+1.0 Ice+1.0 Temp | 294.30 | -5.20 | 3.06 | 352.25 | 610.19 | 1.32 |
| 1.2 Dead+1.0 Wind 270 deg+1.0 Ice+1.0 Temp | 294.30 | -5.48 | 0.12 | 36.94 | 647.52 | -0.37 |
| 1.2 Dead+1.0 Wind 300 deg+1.0 Ice+1.0 Temp | 294.30 | -4.95 | -2.82 | -287.91 | 586.39 | -3.92 |
| 1.2 Dead+1.0 Wind 330 deg+1.0 Ice+1.0 Temp | 294.30 | -3.16 | -5.61 | -588.70 | 385.22 | -8.44 |
| Dead+Wind 0 deg - Service | 134.20 | 0.18 | -10.38 | -1107.43 | -16.60 | -7.89 |
| Dead+Wind 30 deg - Service | 134.20 | 5.05 | -8.72 | -939.14 | -533.02 | -5.31 |
| Dead+Wind 60 deg - Service | 134.20 | 8.21 | -4.84 | -527.48 | -874.47 | -2.09 |
| Dead+Wind 90 deg - Service | 134.20 | 8.71 | -0.19 | -29.91 | -932.38 | -1.59 |
| Dead+Wind 120 deg - Service | 134.20 | 8.60 | 4.86 | 514.73 | -906.10 | 3.79 |
| Dead+Wind 150 deg - Service | 134.20 | 4.75 | 8.66 | 937.43 | -488.54 | 8.74 |
| Dead+Wind 180 deg - Service | 134.20 | -0.24 | 10.01 | 1087.22 | 49.81 | 8.65 |
| Dead+Wind 210 deg - Service | 134.20 | -5.14 | 8.82 | 957.12 | 571.00 | 5.90 |
| Dead+Wind 240 deg - Service | 134.20 | -8.71 | 5.17 | 563.49 | 947.27 | 2.16 |
| Dead+Wind 270 deg - Service | 134.20 | -8.78 | 0.28 | 45.44 | 968.31 | 1.38 |
| Dead+Wind 300 deg - Service | 134.20 | -8.17 | -4.63 | -495.61 | 893.80 | -4.09 |
| Dead+Wind 330 deg - Service | 134.20 | -4.81 | -8.63 | -931.39 | 521.75 | -8.15 |

Solution Summary

| Load Comb. | Sum of Applied Forces | | | Sum of Reactions | | | % Error |
|------------|-----------------------|---------|---------|------------------|---------|---------|---------|
| | PX K | PY K | PZ K | PX K | PY K | PZ K | |
| 1 | 0.00 | -134.20 | 0.00 | 0.00 | 134.20 | 0.00 | 0.000% |
| 2 | 0.60 | -161.04 | -32.95 | -0.60 | 161.04 | 32.95 | 0.000% |
| 3 | 0.60 | -120.78 | -32.95 | -0.60 | 120.78 | 32.95 | 0.000% |
| 4 | 16.02 | -161.04 | -27.64 | -16.02 | 161.04 | 27.64 | 0.000% |
| 5 | 16.02 | -120.78 | -27.64 | -16.02 | 120.78 | 27.64 | 0.000% |
| 6 | 25.95 | -161.04 | -15.31 | -25.95 | 161.04 | 15.31 | 0.000% |
| 7 | 25.95 | -120.78 | -15.31 | -25.95 | 120.78 | 15.31 | 0.000% |
| 8 | 27.42 | -161.04 | -0.65 | -27.42 | 161.04 | 0.65 | 0.000% |
| 9 | 27.42 | -120.78 | -0.65 | -27.42 | 120.78 | 0.65 | 0.000% |
| 10 | 27.25 | -161.04 | 15.37 | -27.25 | 161.04 | -15.37 | 0.000% |
| 11 | 27.25 | -120.78 | 15.37 | -27.25 | 120.78 | -15.37 | 0.000% |
| 12 | 15.02 | -161.04 | 27.43 | -15.02 | 161.04 | -27.43 | 0.000% |
| 13 | 15.02 | -120.78 | 27.43 | -15.02 | 120.78 | -27.43 | 0.000% |
| 14 | -0.78 | -161.04 | 31.71 | 0.78 | 161.04 | -31.71 | 0.000% |
| 15 | -0.78 | -120.78 | 31.71 | 0.78 | 120.78 | -31.71 | 0.000% |
| 16 | -16.31 | -161.04 | 27.97 | 16.31 | 161.04 | -27.97 | 0.000% |
| 17 | -16.31 | -120.78 | 27.97 | 16.31 | 120.78 | -27.97 | 0.000% |
| 18 | -27.62 | -161.04 | 16.41 | 27.62 | 161.04 | -16.41 | 0.000% |
| 19 | -27.62 | -120.78 | 16.41 | 27.62 | 120.78 | -16.41 | 0.000% |
| 20 | -27.65 | -161.04 | 0.93 | 27.65 | 161.04 | -0.93 | 0.000% |
| 21 | -27.65 | -120.78 | 0.93 | 27.65 | 120.78 | -0.93 | 0.000% |
| 22 | -25.81 | -161.04 | -14.63 | 25.81 | 161.04 | 14.63 | 0.000% |
| 23 | -25.81 | -120.78 | -14.63 | 25.81 | 120.78 | 14.63 | 0.000% |
| 24 | -15.20 | -161.04 | -27.35 | 15.20 | 161.04 | 27.35 | 0.000% |
| 25 | -15.20 | -120.78 | -27.35 | 15.20 | 120.78 | 27.35 | 0.000% |
| 26 | 0.00 | -294.30 | 0.00 | 0.00 | 294.30 | -0.00 | 0.000% |
| 27 | 0.08 | -294.30 | -6.72 | -0.08 | 294.30 | 6.72 | 0.000% |
| 28 | 3.29 | -294.30 | -5.67 | -3.29 | 294.30 | 5.67 | 0.000% |
| 29 | 5.00 | -294.30 | -2.92 | -5.00 | 294.30 | 2.92 | 0.000% |
| 30 | 5.45 | -294.30 | -0.08 | -5.45 | 294.30 | 0.08 | 0.000% |
| 31 | 5.12 | -294.30 | 2.91 | -5.12 | 294.30 | -2.91 | 0.000% |
| 32 | 3.14 | -294.30 | 5.62 | -3.14 | 294.30 | -5.62 | 0.000% |
| 33 | -0.10 | -294.30 | 6.58 | 0.10 | 294.30 | -6.58 | 0.000% |
| 34 | -3.32 | -294.30 | 5.72 | 3.32 | 294.30 | -5.72 | 0.000% |
| 35 | -5.20 | -294.30 | 3.06 | 5.20 | 294.30 | -3.06 | 0.000% |
| 36 | -5.48 | -294.30 | 0.12 | 5.48 | 294.30 | -0.12 | 0.000% |
| 37 | -4.95 | -294.30 | -2.82 | 4.95 | 294.30 | 2.82 | 0.000% |
| 38 | -3.16 | -294.30 | -5.61 | 3.16 | 294.30 | 5.61 | 0.000% |
| 39 | 0.18 | -134.20 | -10.38 | -0.18 | 134.20 | 10.38 | 0.000% |
| 40 | 5.05 | -134.20 | -8.72 | -5.05 | 134.20 | 8.72 | 0.000% |
| 41 | 8.21 | -134.20 | -4.84 | -8.21 | 134.20 | 4.84 | 0.000% |
| 42 | 8.71 | -134.20 | -0.19 | -8.71 | 134.20 | 0.19 | 0.000% |
| 43 | 8.60 | -134.20 | 4.86 | -8.60 | 134.20 | -4.86 | 0.000% |
| 44 | 4.75 | -134.20 | 8.66 | -4.75 | 134.20 | -8.66 | 0.000% |
| 45 | -0.24 | -134.20 | 10.01 | 0.24 | 134.20 | -10.01 | 0.000% |
| 46 | -5.14 | -134.20 | 8.82 | 5.14 | 134.20 | -8.82 | 0.000% |
| 47 | -8.71 | -134.20 | 5.17 | 8.71 | 134.20 | -5.17 | 0.000% |
| 48 | -8.78 | -134.20 | 0.28 | 8.78 | 134.20 | -0.28 | 0.000% |
| 49 | -8.17 | -134.20 | -4.63 | 8.17 | 134.20 | 4.63 | 0.000% |
| 50 | -4.81 | -134.20 | -8.63 | 4.81 | 134.20 | 8.63 | 0.000% |

Maximum Tower Deflections - Service Wind

| Section No. | Elevation ft | Horz. Deflection in | Gov. Load Comb. | Tilt ° | Twist ° |
|-------------|----------------------|---------------------------|-----------------------|-----------|------------|
| T1 | 179.098 - 159.41 | 4.6699 | 46 | 0.27 | 0.08 |
| T2 | 159.41 - 158.827 | 3.5990 | 46 | 0.24 | 0.08 |
| T3 | 158.827 - 139.139 | 3.5670 | 46 | 0.24 | 0.08 |
| T4 | 139.139 - 119.452 | 2.6418 | 46 | 0.19 | 0.05 |
| T5 | 119.452 - 99.7642 | 1.9036 | 46 | 0.15 | 0.04 |
| T6 | 99.7642 - | 1.3149 | 46 | 0.12 | 0.03 |

| Section No. | Elevation ft | Horz. Deflection in | Gov. Load Comb. | Tilt ° | Twist ° |
|-------------|------------------------------|------------------------|-----------------|-----------|------------|
| T7 | 80.0767 80.0767 - 60.3892 | 0.8494 | 46 | 0.09 | 0.02 |
| T8 | 60.3892 - 40.7017 | 0.5017 | 46 | 0.07 | 0.02 |
| T9 | 40.7017 - 21.0142 | 0.2472 | 39 | 0.04 | 0.01 |
| T10 | 21.0142 - 1.32667 | 0.0877 | 39 | 0.02 | 0.00 |
| T11 | 1.32667 - 0 | 0.0108 | 39 | 0.00 | 0.00 |

Critical Deflections and Radius of Curvature - Service Wind

| Elevation ft | Appurtenance | Gov. Load Comb. | Deflection in | Tilt ° | Twist ° | Radius of Curvature ft |
|-----------------|-------------------------|-----------------|------------------|-----------|------------|---------------------------|
| 179.00 | Lightning Rod 5/8"x8' | 46 | 4.6646 | 0.27 | 0.08 | 474775 |
| 176.00 | 6"x2" Mount Pipe | 46 | 4.5021 | 0.26 | 0.09 | 474775 |
| 160.00 | HPX8-59 | 46 | 3.6313 | 0.24 | 0.09 | 33561 |
| 150.00 | Sector Mount [SM 801-3] | 46 | 3.1193 | 0.22 | 0.06 | 17000 |

Maximum Tower Deflections - Design Wind

| Section No. | Elevation ft | Horz. Deflection in | Gov. Load Comb. | Tilt ° | Twist ° |
|-------------|-------------------|------------------------|-----------------|-----------|------------|
| T1 | 179.098 - 159.41 | 15.1664 | 16 | 0.86 | 0.28 |
| T2 | 159.41 - 158.827 | 11.6537 | 16 | 0.77 | 0.28 |
| T3 | 158.827 - 139.139 | 11.5491 | 16 | 0.77 | 0.27 |
| T4 | 139.139 - 119.452 | 8.5303 | 16 | 0.63 | 0.17 |
| T5 | 119.452 - 99.7642 | 6.1331 | 16 | 0.49 | 0.13 |
| T6 | 99.7642 - 80.0767 | 4.2281 | 16 | 0.40 | 0.10 |
| T7 | 80.0767 - 60.3892 | 2.7261 | 16 | 0.29 | 0.07 |
| T8 | 60.3892 - 40.7017 | 1.6073 | 3 | 0.21 | 0.05 |
| T9 | 40.7017 - 21.0142 | 0.7926 | 3 | 0.14 | 0.03 |
| T10 | 21.0142 - 1.32667 | 0.2796 | 3 | 0.07 | 0.02 |
| T11 | 1.32667 - 0 | 0.0342 | 2 | 0.00 | 0.00 |

Critical Deflections and Radius of Curvature - Design Wind

| Elevation ft | Appurtenance | Gov. Load Comb. | Deflection in | Tilt ° | Twist ° | Radius of Curvature ft |
|-----------------|-------------------------|-----------------|------------------|-----------|------------|---------------------------|
| 179.00 | Lightning Rod 5/8"x8' | 16 | 15.1491 | 0.86 | 0.28 | 154904 |
| 176.00 | 6"x2" Mount Pipe | 16 | 14.6156 | 0.85 | 0.29 | 154904 |
| 160.00 | HPX8-59 | 16 | 11.7596 | 0.78 | 0.28 | 10407 |
| 150.00 | Sector Mount [SM 801-3] | 16 | 10.0861 | 0.71 | 0.20 | 5092 |

Bolt Design Data

| Section No. | Elevation ft | Component Type | Bolt Grade | Bolt Size in | Number Of Bolts | Maximum Load per Bolt K | Allowable Load per Bolt K | Ratio Load Allowable | Allowable Ratio | Criteria |
|-------------|-----------------|----------------|------------|-----------------|-----------------|----------------------------|------------------------------|----------------------|-----------------|--------------------|
| T1 | 179.098 | Leg | A325N | 1.0000 | 4 | 6.75 | 54.52 | 0.124 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.6250 | 1 | 3.35 | 5.51 | 0.609 | 1.05 | Member Block Shear |
| T2 | 159.41 | Top Girt | A325N | 0.6250 | 1 | 0.55 | 13.81 | 0.040 | 1.05 | Bolt Shear |
| | | Leg | A325N | 1.0000 | 4 | 7.03 | 54.52 | 0.129 | 1.05 | Bolt Tension |
| T3 | 158.827 | Leg | A325N | 1.0000 | 6 | 5.58 | 54.52 | 0.102 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.6250 | 1 | 5.90 | 6.53 | 0.905 | 1.05 | Member Block Shear |
| T4 | 139.139 | Leg | A325N | 1.0000 | 6 | 9.04 | 54.52 | 0.166 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.6250 | 1 | 5.23 | 8.70 | 0.601 | 1.05 | Member Block Shear |
| T5 | 119.452 | Leg | A325N | 1.0000 | 6 | 13.09 | 54.52 | 0.240 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.7500 | 1 | 4.72 | 8.16 | 0.579 | 1.05 | Member Bearing |
| T6 | 99.7642 | Leg | A325N | 1.0000 | 6 | 16.78 | 54.52 | 0.308 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.7500 | 1 | 4.83 | 8.16 | 0.592 | 1.05 | Member Bearing |
| T7 | 80.0767 | Leg | A325N | 1.0000 | 10 | 12.14 | 54.52 | 0.223 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.7500 | 1 | 5.24 | 10.88 | 0.482 | 1.05 | Member Bearing |
| T8 | 60.3892 | Leg | A325N | 1.0000 | 10 | 13.93 | 54.52 | 0.256 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.7500 | 2 | 3.05 | 8.05 | 0.379 | 1.05 | Member Block Shear |
| T9 | 40.7017 | Leg | A325N | 1.0000 | 10 | 15.86 | 54.52 | 0.291 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.7500 | 2 | 3.21 | 10.74 | 0.299 | 1.05 | Member Block Shear |
| T10 | 21.0142 | Leg | A325N | 1.0000 | 10 | 17.79 | 54.52 | 0.326 | 1.05 | Bolt Tension |
| | | Diagonal | A325N | 0.7500 | 2 | 4.51 | 10.74 | 0.420 | 1.05 | Member Block Shear |

Compression Checks

Leg Design Data (Compression)

| Section No. | Elevation ft | Size | L ft | L _u ft | Kl/r | A in ² | P _u K | φP _n K | Ratio P _u / φP _n |
|-------------|-------------------|----------|---------|----------------------|----------------|----------------------|---------------------|----------------------|---|
| T1 | 179.098 - 159.41 | P3x.216 | 19.69 | 4.92 | 50.8 K=1.00 | 2.2285 | -81.63 | 83.06 | 0.983 ¹ |
| T2 | 159.41 - 158.827 | P5x.258 | 0.58 | 0.58 | 3.7 K=1.00 | 4.2999 | -84.37 | 193.30 | 0.436 |
| T3 | 158.827 - 139.139 | P5x.258 | 19.71 | 6.57 | 42.0 K=1.00 | 4.2999 | -100.43 | 170.09 | 0.590 ¹ |
| T4 | 139.139 - 119.452 | P6x.28 | 19.71 | 6.57 | 35.1 K=1.00 | 5.5813 | -131.98 | 229.51 | 0.575 ¹ |
| T5 | 119.452 - 99.7642 | P8x.322 | 19.71 | 6.57 | 26.8 K=1.00 | 8.3993 | -158.71 | 358.57 | 0.443 ¹ |
| T6 | 99.7642 - 80.0767 | P8x.322 | 19.71 | 6.57 | 26.8 K=1.00 | 8.3993 | -183.39 | 358.57 | 0.511 ¹ |
| T7 | 80.0767 - 60.3892 | P8x.406 | 19.71 | 6.57 | 27.1 K=1.00 | 10.483 | -207.78 | 447.08 | 0.465 ¹ |
| T8 | 60.3892 - 40.7017 | P10x.365 | 19.71 | 9.86 | 32.2 | 11.908 | -228.91 | 496.76 | 0.461 ¹ |
| | | | | | K=1.00 | 3 | | | |
| T9 | 40.7017 - | P10x.365 | 19.71 | 9.86 | 32.2 | 11.908 | -251.81 | 496.76 | 0.507 ¹ |

| Section No. | Elevation ft | Size | L ft | L _u ft | Kl/r | A in ² | P _u K | φP _n K | Ratio P _u / φP _n |
|-------------|-------------------|----------|---------|----------------------|-------------------------|----------------------|---------------------|----------------------|---|
| T10 | 21.0142 - 1.32667 | P10x.365 | 19.71 | 9.86 | K=1.00 32.2 | 3 11.908 | -275.56 | 496.76 | 0.555 ¹ |
| T11 | 1.32667 - 0 | P10x.593 | 1.33 | 1.33 | K=1.00 4.4 K=1.00 | 3 18.922 1 | -282.19 | 850.28 | 0.332 |

¹ P_u / φP_n controls

Leg Bending Design Data (Compression)

| Section No. | Elevation ft | Size | M _{ux} kip-ft | φM _{nx} kip-ft | Ratio M _{ux} / φM _{nx} | M _{uy} kip-ft | φM _{ny} kip-ft | Ratio M _{uy} / φM _{ny} |
|-------------|-------------------|----------|---------------------------|----------------------------|---|---------------------------|----------------------------|---|
| T1 | 179.098 - 159.41 | P3x.216 | 0.00 | 8.75 | 0.000 | 0.00 | 8.75 | 0.000 |
| T2 | 159.41 - 158.827 | P5x.258 | 1.80 | 27.25 | 0.066 | 0.00 | 27.25 | 0.000 |
| T3 | 158.827 - 139.139 | P5x.258 | 0.00 | 27.25 | 0.000 | 0.00 | 27.25 | 0.000 |
| T4 | 139.139 - 119.452 | P6x.28 | 0.00 | 42.30 | 0.000 | 0.00 | 42.30 | 0.000 |
| T5 | 119.452 - 99.7642 | P8x.322 | 0.00 | 83.29 | 0.000 | 0.00 | 83.29 | 0.000 |
| T6 | 99.7642 - 80.0767 | P8x.322 | 0.00 | 83.29 | 0.000 | 0.00 | 83.29 | 0.000 |
| T7 | 80.0767 - 60.3892 | P8x.406 | 0.00 | 102.93 | 0.000 | 0.00 | 102.93 | 0.000 |
| T8 | 60.3892 - 40.7017 | P10x.365 | 0.00 | 147.68 | 0.000 | 0.00 | 147.68 | 0.000 |
| T9 | 40.7017 - 21.0142 | P10x.365 | 0.00 | 147.68 | 0.000 | 0.00 | 147.68 | 0.000 |
| T10 | 21.0142 - 1.32667 | P10x.365 | 0.00 | 147.68 | 0.000 | 0.00 | 147.68 | 0.000 |
| T11 | 1.32667 - 0 | P10x.593 | 27.83 | 229.67 | 0.121 | 0.00 | 229.67 | 0.000 |

Leg Interaction Design Data (Compression)

| Section No. | Elevation ft | Size | Ratio P _u / φP _n | Ratio M _{ux} / φM _{nx} | Ratio M _{uy} / φM _{ny} | Comb. Stress Ratio | Allow. Stress Ratio | Criteria |
|-------------|-------------------|----------|---|---|---|--------------------|---------------------|----------|
| T1 | 179.098 - 159.41 | P3x.216 | 0.983 | 0.000 | 0.000 | 0.983 ¹ | 1.050 | 4.8.1 |
| T2 | 159.41 - 158.827 | P5x.258 | 0.436 | 0.066 | 0.000 | 0.447 | 1.050 | 4.8.1 |
| T3 | 158.827 - 139.139 | P5x.258 | 0.590 | 0.000 | 0.000 | 0.590 ¹ | 1.050 | 4.8.1 |
| T4 | 139.139 - 119.452 | P6x.28 | 0.575 | 0.000 | 0.000 | 0.575 ¹ | 1.050 | 4.8.1 |
| T5 | 119.452 - 99.7642 | P8x.322 | 0.443 | 0.000 | 0.000 | 0.443 ¹ | 1.050 | 4.8.1 |
| T6 | 99.7642 - 80.0767 | P8x.322 | 0.511 | 0.000 | 0.000 | 0.511 ¹ | 1.050 | 4.8.1 |
| T7 | 80.0767 - 60.3892 | P8x.406 | 0.465 | 0.000 | 0.000 | 0.465 ¹ | 1.050 | 4.8.1 |
| T8 | 60.3892 - 40.7017 | P10x.365 | 0.461 | 0.000 | 0.000 | 0.461 ¹ | 1.050 | 4.8.1 |
| T9 | 40.7017 - 21.0142 | P10x.365 | 0.507 | 0.000 | 0.000 | 0.507 ¹ | 1.050 | 4.8.1 |
| T10 | 21.0142 - 1.32667 | P10x.365 | 0.555 | 0.000 | 0.000 | 0.555 ¹ | 1.050 | 4.8.1 |

| Section No. | Elevation ft | Size | Ratio $\frac{P_u}{\phi P_n}$ | Ratio $\frac{M_{ux}}{\phi M_{nx}}$ | Ratio $\frac{M_{uy}}{\phi M_{ny}}$ | Comb. Stress Ratio | Allow. Stress Ratio | Criteria |
|-------------|-----------------|----------|---------------------------------|---------------------------------------|---------------------------------------|--------------------------|---------------------------|----------|
| T11 | 1.32667 - 0 | P10x.593 | 0.332 | 0.121 | 0.000 | 0.403 | 1.050 | 4.8.1 |

¹ $P_u / \phi P_n$ controls

Diagonal Design Data (Compression)

| Section No. | Elevation ft | Size | L ft | L_u ft | KI/r | A in^2 | P_u K | ϕP_n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-------------------|-------------------|---------|-------------|-----------------|-------------|------------|-----------------|---------------------------------|
| T1 | 179.098 - 159.41 | L1 3/4x1 3/4x3/16 | 6.34 | 2.82 | 103.9 K=1.05 | 0.6211 | -4.24 | 14.77 | 0.287 ¹ |
| T3 | 158.827 - 139.139 | L2x2x3/16 | 7.84 | 3.71 | 114.7 K=1.02 | 0.7150 | -6.70 | 15.10 | 0.443 ¹ |
| T4 | 139.139 - 119.452 | L2x2x1/4 | 9.75 | 4.58 | 140.5 K=1.00 | 0.9380 | -4.83 | 13.59 | 0.355 ¹ |
| T5 | 119.452 - 99.7642 | L2 1/2x2 1/2x3/16 | 11.11 | 5.15 | 124.9 K=1.00 | 0.9020 | -4.70 | 16.54 | 0.284 ¹ |
| T6 | 99.7642 - 80.0767 | L2 1/2x2 1/2x3/16 | 12.56 | 5.89 | 142.9 K=1.00 | 0.9020 | -4.89 | 12.64 | 0.387 ¹ |
| T7 | 80.0767 - 60.3892 | L2 1/2x2 1/2x1/4 | 14.08 | 6.66 | 162.9 K=1.00 | 1.1900 | -5.02 | 12.84 | 0.391 ¹ |
| T8 | 60.3892 - 40.7017 | L3x3x3/16 | 17.17 | 8.07 | 152.5 K=0.94 | 1.0900 | -6.03 | 13.42 | 0.450 ¹ |
| T9 | 40.7017 - 21.0142 | L3x3x1/4 | 18.63 | 8.81 | 164.8 K=0.92 | 1.4400 | -6.59 | 15.18 | 0.434 ¹ |
| T10 | 21.0142 - 1.32667 | L3x3x1/4 | 20.13 | 9.58 | 176.5 K=0.91 | 1.4400 | -8.73 | 13.23 | 0.660 ¹ |

¹ $P_u / \phi P_n$ controls

Top Girt Design Data (Compression)

| Section No. | Elevation ft | Size | L ft | L_u ft | KI/r | A in^2 | P_u K | ϕP_n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|------------------|----------|---------|-------------|----------------|-------------|------------|-----------------|---------------------------------|
| T1 | 179.098 - 159.41 | L3x3x1/4 | 4.00 | 3.29 | 93.4 K=1.40 | 1.4400 | -0.55 | 37.63 | 0.015 ¹ |

¹ $P_u / \phi P_n$ controls

Tension Checks

Leg Design Data (Tension)

| Section No. | Elevation ft | Size | L ft | L_u ft | KI/r | A in^2 | P_u K | ϕP_n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-------------------|---------|---------|-------------|--------|-------------|------------|-----------------|---------------------------------|
| T3 | 158.827 - 139.139 | P5x.258 | 19.71 | 6.57 | 42.0 | 4.2999 | 24.58 | 193.49 | 0.127 ¹ |
| T4 | 139.139 - 119.452 | P6x.28 | 19.71 | 6.57 | 35.1 | 5.5813 | 54.25 | 251.16 | 0.216 ¹ |
| T5 | 119.452 - 99.7642 | P8x.322 | 19.71 | 6.57 | 26.8 | 8.3993 | 78.55 | 377.97 | 0.208 ¹ |

| Section No. | Elevation ft | Size | L ft | L _u ft | Kl/r | A in ² | P _u K | φP _n K | Ratio P _u / φP _n |
|-------------|-------------------|----------|---------|----------------------|------|----------------------|---------------------|----------------------|---|
| T6 | 99.7642 - 80.0767 | P8x.322 | 19.71 | 6.57 | 26.8 | 8.3993 | 100.70 | 377.97 | 0.266 ¹ |
| T7 | 80.0767 - 60.3892 | P8x.406 | 19.71 | 6.57 | 27.1 | 10.483 ₂ | 121.44 | 471.75 | 0.257 ¹ |
| T8 | 60.3892 - 40.7017 | P10x.365 | 19.71 | 9.86 | 32.2 | 11.908 ₃ | 139.34 | 535.87 | 0.260 ¹ |
| T9 | 40.7017 - 21.0142 | P10x.365 | 19.71 | 9.86 | 32.2 | 11.908 ₃ | 158.57 | 535.87 | 0.296 ¹ |
| T10 | 21.0142 - 1.32667 | P10x.365 | 19.71 | 9.86 | 32.2 | 11.908 ₃ | 177.86 | 535.87 | 0.332 ¹ |
| T11 | 1.32667 - 0 | P10x.593 | 1.33 | 1.33 | 4.4 | 18.922 ₁ | 183.80 | 851.50 | 0.216 |

¹ P_u / φP_n controls

Leg Bending Design Data (Tension)

| Section No. | Elevation ft | Size | M _{ux} kip-ft | φM _{nx} kip-ft | Ratio M _{ux} / φM _{nx} | M _{uy} kip-ft | φM _{ny} kip-ft | Ratio M _{uy} / φM _{ny} |
|-------------|-------------------|----------|---------------------------|----------------------------|---|---------------------------|----------------------------|---|
| T3 | 158.827 - 139.139 | P5x.258 | 0.00 | 27.25 | 0.000 | 0.00 | 27.25 | 0.000 |
| T4 | 139.139 - 119.452 | P6x.28 | 0.00 | 42.30 | 0.000 | 0.00 | 42.30 | 0.000 |
| T5 | 119.452 - 99.7642 | P8x.322 | 0.00 | 83.29 | 0.000 | 0.00 | 83.29 | 0.000 |
| T6 | 99.7642 - 80.0767 | P8x.322 | 0.00 | 83.29 | 0.000 | 0.00 | 83.29 | 0.000 |
| T7 | 80.0767 - 60.3892 | P8x.406 | 0.00 | 102.93 | 0.000 | 0.00 | 102.93 | 0.000 |
| T8 | 60.3892 - 40.7017 | P10x.365 | 0.00 | 147.68 | 0.000 | 0.00 | 147.68 | 0.000 |
| T9 | 40.7017 - 21.0142 | P10x.365 | 0.00 | 147.68 | 0.000 | 0.00 | 147.68 | 0.000 |
| T10 | 21.0142 - 1.32667 | P10x.365 | 0.00 | 147.68 | 0.000 | 0.00 | 147.68 | 0.000 |
| T11 | 1.32667 - 0 | P10x.593 | 21.72 | 229.67 | 0.095 | 0.00 | 229.67 | 0.000 |

Leg Interaction Design Data (Tension)

| Section No. | Elevation ft | Size | Ratio P _u / φP _n | Ratio M _{ux} / φM _{nx} | Ratio M _{uy} / φM _{ny} | Comb. Stress Ratio | Allow. Stress Ratio | Criteria |
|-------------|-------------------|----------|---|---|---|--------------------------|---------------------------|----------|
| T3 | 158.827 - 139.139 | P5x.258 | 0.127 | 0.000 | 0.000 | 0.127 ¹ | 1.050 | 4.8.1 |
| T4 | 139.139 - 119.452 | P6x.28 | 0.216 | 0.000 | 0.000 | 0.216 ¹ | 1.050 | 4.8.1 |
| T5 | 119.452 - 99.7642 | P8x.322 | 0.208 | 0.000 | 0.000 | 0.208 ¹ | 1.050 | 4.8.1 |
| T6 | 99.7642 - 80.0767 | P8x.322 | 0.266 | 0.000 | 0.000 | 0.266 ¹ | 1.050 | 4.8.1 |
| T7 | 80.0767 - 60.3892 | P8x.406 | 0.257 | 0.000 | 0.000 | 0.257 ¹ | 1.050 | 4.8.1 |
| T8 | 60.3892 - 40.7017 | P10x.365 | 0.260 | 0.000 | 0.000 | 0.260 ¹ | 1.050 | 4.8.1 |
| T9 | 40.7017 - 21.0142 | P10x.365 | 0.296 | 0.000 | 0.000 | 0.296 ¹ | 1.050 | 4.8.1 |
| T10 | 21.0142 - 1.32667 | P10x.365 | 0.332 | 0.000 | 0.000 | 0.332 ¹ | 1.050 | 4.8.1 |
| T11 | 1.32667 - 0 | P10x.593 | 0.216 | 0.095 | 0.000 | 0.276 | 1.050 | 4.8.1 |

| Section No. | Elevation ft | Size | Ratio $\frac{P_u}{\phi P_n}$ | Ratio $\frac{M_{ux}}{\phi M_{nx}}$ | Ratio $\frac{M_{uy}}{\phi M_{ny}}$ | Comb. Stress Ratio | Allow. Stress Ratio | Criteria |
|-------------|-----------------|------|---------------------------------|---------------------------------------|---------------------------------------|--------------------|---------------------|----------|
|-------------|-----------------|------|---------------------------------|---------------------------------------|---------------------------------------|--------------------|---------------------|----------|

¹ $P_u / \phi P_n$ controls

Diagonal Design Data (Tension)

| Section No. | Elevation ft | Size | L ft | L_u ft | Kl/r | A in^2 | P_u K | ϕP_n K | Ratio $\frac{P_u}{\phi P_n}$ |
|-------------|-------------------|-------------------|---------|-------------|--------|-------------|------------|-----------------|---------------------------------|
| T1 | 179.098 - 159.41 | L1 3/4x1 3/4x3/16 | 6.34 | 2.82 | 65.7 | 0.3604 | 3.35 | 15.68 | 0.214 ¹ |
| T3 | 158.827 - 139.139 | L2x2x3/16 | 8.18 | 3.85 | 77.2 | 0.4308 | 5.90 | 18.74 | 0.315 ¹ |
| T4 | 139.139 - 119.452 | L2x2x1/4 | 8.92 | 4.18 | 84.8 | 0.5629 | 5.23 | 24.49 | 0.214 ¹ |
| T5 | 119.452 - 99.7642 | L2 1/2x2 1/2x3/16 | 11.11 | 5.15 | 81.6 | 0.5535 | 4.72 | 24.08 | 0.196 ¹ |
| T6 | 99.7642 - 80.0767 | L2 1/2x2 1/2x3/16 | 12.07 | 5.65 | 89.2 | 0.5535 | 4.83 | 24.08 | 0.201 ¹ |
| T7 | 80.0767 - 60.3892 | L2 1/2x2 1/2x1/4 | 14.08 | 6.66 | 106.1 | 0.7284 | 5.24 | 31.69 | 0.165 ¹ |
| T8 | 60.3892 - 40.7017 | L3x3x3/16 | 17.17 | 8.07 | 106.1 | 0.6945 | 6.10 | 30.21 | 0.202 ¹ |
| T9 | 40.7017 - 21.0142 | L3x3x1/4 | 18.63 | 8.81 | 116.7 | 0.9159 | 6.41 | 39.84 | 0.161 ¹ |
| T10 | 21.0142 - 1.32667 | L3x3x1/4 | 20.13 | 9.58 | 126.5 | 0.9159 | 9.03 | 39.84 | 0.227 ¹ |

¹ $P_u / \phi P_n$ controls

Section Capacity Table

| Section No. | Elevation ft | Component Type | Size | Critical Element | P K | ϕP_{allow} K | % Capacity | Pass Fail |
|-------------|-------------------|----------------|-------------------|------------------|---------|-----------------------|------------|-----------|
| T1 | 179.098 - 159.41 | Leg | P3x.216 | 2 | -81.63 | 87.22 | 93.6 | Pass |
| T2 | 159.41 - 158.827 | Leg | P5x.258 | 33 | -84.37 | 202.96 | 42.5 | Pass |
| T3 | 158.827 - 139.139 | Leg | P5x.258 | 36 | -100.43 | 178.59 | 56.2 | Pass |
| T4 | 139.139 - 119.452 | Leg | P6x.28 | 57 | -131.98 | 240.98 | 54.8 | Pass |
| T5 | 119.452 - 99.7642 | Leg | P8x.322 | 78 | -158.71 | 376.50 | 42.2 | Pass |
| T6 | 99.7642 - 80.0767 | Leg | P8x.322 | 99 | -183.39 | 376.50 | 48.7 | Pass |
| T7 | 80.0767 - 60.3892 | Leg | P8x.406 | 120 | -207.78 | 469.43 | 44.3 | Pass |
| T8 | 60.3892 - 40.7017 | Leg | P10x.365 | 141 | -228.91 | 521.60 | 43.9 | Pass |
| T9 | 40.7017 - 21.0142 | Leg | P10x.365 | 156 | -251.81 | 521.60 | 48.3 | Pass |
| T10 | 21.0142 - 1.32667 | Leg | P10x.365 | 171 | -275.56 | 521.60 | 52.8 | Pass |
| T11 | 1.32667 - 0 | Leg | P10x.593 | 186 | -282.19 | 892.79 | 38.4 | Pass |
| T1 | 179.098 - 159.41 | Diagonal | L1 3/4x1 3/4x3/16 | 12 | -4.24 | 15.51 | 27.4 | Pass |
| T3 | 158.827 - 139.139 | Diagonal | L2x2x3/16 | 54 | -6.70 | 15.86 | 42.2 | Pass |
| T4 | 139.139 - 119.452 | Diagonal | L2x2x1/4 | 63 | -4.83 | 14.27 | 33.8 | Pass |

| Section No. | Elevation ft | Component Type | Size | Critical Element | P K | ϕP_{allow} K | % Capacity | Pass Fail | |
|-------------|-------------------|----------------|-------------------|------------------|-------|--------------------|-----------------|-------------|-------------|
| T5 | 119.452 - 99.7642 | Diagonal | L2 1/2x2 1/2x3/16 | 84 | -4.70 | 17.36 | 27.0 | Pass | |
| T6 | 99.7642 - 80.0767 | Diagonal | L2 1/2x2 1/2x3/16 | 105 | -4.89 | 13.28 | 36.8 | Pass | |
| T7 | 80.0767 - 60.3892 | Diagonal | L2 1/2x2 1/2x1/4 | 126 | -5.02 | 13.48 | 37.2 | Pass | |
| T8 | 60.3892 - 40.7017 | Diagonal | L3x3x3/16 | 147 | -6.03 | 14.09 | 42.8 | Pass | |
| T9 | 40.7017 - 21.0142 | Diagonal | L3x3x1/4 | 162 | -6.59 | 15.94 | 41.3 | Pass | |
| T10 | 21.0142 - 1.32667 | Diagonal | L3x3x1/4 | 177 | -8.73 | 13.89 | 62.8 | Pass | |
| T1 | 179.098 - 159.41 | Top Girt | L3x3x1/4 | 5 | -0.55 | 39.51 | 1.4 | Pass | |
| | | | | | | | Summary | | |
| | | | | | | | Leg (T1) | 93.6 | Pass |
| | | | | | | | Diagonal (T10) | 62.8 | Pass |
| | | | | | | | Top Girt (T1) | 1.4 | Pass |
| | | | | | | | Bolt | 86.2 | Pass |
| | | | | | | | Checks | | |
| | | | | | | | RATING = | 93.6 | Pass |

APPENDIX B
BASE LEVEL DRAWING



(PROPOSED EQUIPMENT CONFIGURATION)
(2) 1-5/8" TO 150 FT LEVEL

LEG A



LEG B


(OTHER CONSIDERED EQUIPMENT)
(1) 3/8" TO 160 FT LEVEL

(OTHER CONSIDERED EQUIPMENT)
(1) 1/2" TO 176 FT LEVEL

(OTHER CONSIDERED EQUIPMENT - IN CONDUIT)
(2) 5/16" TO 176 FT LEVEL
(2) 3/8" TO 176 FT LEVEL
(4) 13/16" TO 176 FT LEVEL
(OTHER CONSIDERED EQUIPMENT)
(12) 1-5/8" TO 176 FT LEVEL

CLIMBING PEGS
W/ SAFETY CLIMB

LEG C



APPENDIX C
ADDITIONAL CALCULATIONS

Self Support Anchor Rod Capacity



| Site Info | |
|-----------|--------------|
| BU # | 808716 |
| Site Name | Tusten |
| Order # | 594303 Rev.0 |


| Analysis Considerations | |
|-------------------------|-----|
| TIA-222 Revision | H |
| Grout Considered: | Yes |
| l_{ar} (in) | 2.5 |

| Applied Loads | | |
|--------------------|--------|--------|
| | Comp. | Uplift |
| Axial Force (kips) | 282.24 | 183.72 |
| Shear Force (kips) | 20.99 | 16.38 |

*TIA-222-H Section 15.5 Applied

| Considered Eccentricity | |
|---------------------------|-------|
| Leg Mod Eccentricity (in) | 0.000 |
| Anchor Rod N.A Shift (in) | 0.000 |
| Total Eccentricity (in) | 0.000 |

*Anchor Rod Eccentricity Applied



| Connection Properties | Analysis Results |
|-----------------------|------------------|
|-----------------------|------------------|

| Anchor Rod Data | |
|---|-----|
| (8) 2" ϕ bolts (A36 N; $F_y=36$ ksi, $F_u=58$ ksi) | |
| l_{ar} (in): | 2.5 |

| Anchor Rod Summary | | (units of kips, kip-in) | |
|--------------------|----------------------|-------------------------|--|
| $Pu_t = 22.97$ | $\phi Pn_t = 108.75$ | Stress Rating | |
| $Vu = 2.05$ | $\phi Vn = 68.33$ | 20.1% | |
| $Mu = n/a$ | $\phi Mn = n/a$ | Pass | |

SST Unit Base Foundation



| | |
|-------------------|--------------|
| BU # : | 808716 |
| Site Name: | Tusten |
| App. Number: | 594303 Rev.0 |
| TIA-222 Revision: | H |

| | |
|----------------------------------|-------------------------------------|
| Top & Bot. Pad Rein. Different?: | <input type="checkbox"/> |
| Tower Centroid Offset?: | <input checked="" type="checkbox"/> |
| Block Foundation?: | <input type="checkbox"/> |
| Rectangular Pad?: | <input type="checkbox"/> |

| Superstructure Analysis Reactions | | |
|--|--------|---------|
| Global Moment, M : | 3569.3 | ft-kips |
| Global Axial, P : | 161.04 | kips |
| Global Shear, V : | 32.38 | kips |
| Leg Compression, P_{comp} : | 282.24 | kips |
| Leg Comp. Shear, V_{u,comp} : | 20.99 | kips |
| Leg Uplift, P_{uplift} : | 183.72 | kips |
| Leg Uplift. Shear, V_{u,uplift} : | 16.38 | kips |
| Tower Height, H : | 179.1 | ft |
| Base Face Width, BW : | 18 | ft |
| BP Dist. Above Fdn, bp_{dist} : | 4.5 | in |

| Foundation Analysis Checks | | | | |
|--|----------|---------|---------|-------|
| | Capacity | Demand | Rating* | Check |
| <i>Lateral (Sliding) (kips)</i> | 330.53 | 32.38 | 9.3% | Pass |
| <i>Bearing Pressure (ksf)</i> | 12.00 | 3.11 | 24.7% | Pass |
| <i>Overturning (kip*ft)</i> | 8183.41 | 4251.72 | 52.0% | Pass |
| <i>Pier Flexure (Comp.) (kip*ft)</i> | 3112.24 | 115.45 | 3.5% | Pass |
| <i>Pier Flexure (Tension) (kip*ft)</i> | 2436.18 | 90.09 | 3.5% | Pass |
| <i>Pier Compression (kip)</i> | 11247.53 | 301.68 | 2.6% | Pass |
| <i>Pad Flexure (kip*ft)</i> | 2256.58 | 215.83 | 9.1% | Pass |
| <i>Pad Shear - 1-way (kips)</i> | 593.48 | 68.72 | 11.0% | Pass |
| <i>Pad Shear - Comp 2-way (ksi)</i> | 0.190 | 0.064 | 32.0% | Pass |
| <i>Flexural 2-way (Comp) (kip*ft)</i> | 1482.16 | 69.27 | 4.5% | Pass |
| <i>Pad Shear - Tension 2-way (ksi)</i> | 0.190 | 0.045 | 22.8% | Pass |
| <i>Flexural 2-way (Tension) (kip*ft)</i> | 1482.16 | 54.05 | 3.5% | Pass |

*Rating per TIA-222-H Section 15.5

| | |
|---------------------|-------|
| Structural Rating*: | 32.0% |
| Soil Rating*: | 52.0% |

| Pier Properties | | |
|--|----------|----|
| Pier Shape: | Circular | |
| Pier Diameter, dpier : | 5.0 | ft |
| Ext. Above Grade, E : | 1.00 | ft |
| Pier Rebar Size, Sc : | 9 | |
| Pier Rebar Quantity, mc : | 26 | |
| Pier Tie/Spiral Size, St : | 4 | |
| Pier Tie/Spiral Quantity, mt : | 6 | |
| Pier Reinforcement Type: | Tie | |
| Pier Clear Cover, cc_{pier} : | 5 | in |

| Pad Properties | | |
|---|-------|----|
| Depth, D : | 6.50 | ft |
| Pad Width, W₁ : | 27.00 | ft |
| Pad Thickness, T : | 2.00 | ft |
| Pad Rebar Size (Bottom dir. 2), Sp₂ : | 9 | |
| Pad Rebar Quantity (Bottom dir. 2), mp₂ : | 27 | |
| Pad Clear Cover, cc_{pad} : | 3 | in |

| Material Properties | | |
|---|-----|-----|
| Rebar Grade, Fy : | 60 | ksi |
| Concrete Compressive Strength, F'c : | 4 | ksi |
| Dry Concrete Density, δc : | 150 | pcf |

| Soil Properties | | |
|--|--------|---------|
| Total Soil Unit Weight, γ : | 115 | pcf |
| Ultimate Gross Bearing, Qult : | 16.000 | ksf |
| Cohesion, Cu : | | ksf |
| Friction Angle, φ : | | degrees |
| SPT Blow Count, N_{blows} : | | |
| Base Friction, μ : | 0.6 | |
| Neglected Depth, N : | 4.2 | ft |
| Foundation Bearing on Rock? | Yes | |
| Groundwater Depth, gw : | 15 | ft |



<-- Toggle between Gross and Net

ASCE 7 Hazards Report

Address:
No Address at This Location

Standard: ASCE/SEI 7-16
Risk Category: II
Soil Class: D - Stiff Soil

Elevation: 1150.28 ft (NAVD 88)
Latitude: 41.592806
Longitude: -75.021528



Wind

Results:

| | |
|--------------|----------|
| Wind Speed | 112 Vmph |
| 10-year MRI | 75 Vmph |
| 25-year MRI | 83 Vmph |
| 50-year MRI | 88 Vmph |
| 100-year MRI | 94 Vmph |

Data Source: ASCE/SEI 7-16, Fig. 26.5-1B and Figs. CC.2-1–CC.2-4, and Section 26.5.2
Date Accessed: Mon Dec 13 2021

Value provided is 3-second gust wind speeds at 33 ft above ground for Exposure C Category, based on linear interpolation between contours. Wind speeds are interpolated in accordance with the 7-16 Standard. Wind speeds correspond to approximately a 7% probability of exceedance in 50 years (annual exceedance probability = 0.00143, MRI = 700 years).





Site is not in a hurricane-prone region as defined in ASCE/SEI 7-16 Section 26.2.

Site Soil Class: D - Stiff Soil

Results:

| | | | |
|------------|-------|--------------------|-------|
| S_s : | 0.146 | S_{D1} : | 0.077 |
| S_1 : | 0.048 | T_L : | 6 |
| F_a : | 1.6 | PGA : | 0.075 |
| F_v : | 2.4 | PGA _M : | 0.12 |
| S_{MS} : | 0.233 | F_{PGA} : | 1.6 |
| S_{M1} : | 0.115 | I_e : | 1 |
| S_{DS} : | 0.156 | C_v : | 0.7 |

Seismic Design Category B



Data Accessed: Mon Dec 13 2021

Date Source:

USGS Seismic Design Maps based on ASCE/SEI 7-16 and ASCE/SEI 7-16 Table 1.5-2. Additional data for site-specific ground motion procedures in accordance with ASCE/SEI 7-16 Ch. 21 are available from USGS.

Ice

Results:

Ice Thickness: 1.00 in.
Concurrent Temperature: 15 F
Gust Speed 40 mph

Data Source: Standard ASCE/SEI 7-16, Figs. 10-2 through 10-8

Date Accessed: Mon Dec 13 2021

Ice thicknesses on structures in exposed locations at elevations higher than the surrounding terrain and in valleys and gorges may exceed the mapped values.

Values provided are equivalent radial ice thicknesses due to freezing rain with concurrent 3-second gust speeds, for a 500-year mean recurrence interval, and temperatures concurrent with ice thicknesses due to freezing rain. Thicknesses for ice accretions caused by other sources shall be obtained from local meteorological studies. Ice thicknesses in exposed locations at elevations higher than the surrounding terrain and in valleys and gorges may exceed the mapped values.

The ASCE 7 Hazard Tool is provided for your convenience, for informational purposes only, and is provided “as is” and without warranties of any kind. The location data included herein has been obtained from information developed, produced, and maintained by third party providers; or has been extrapolated from maps incorporated in the ASCE 7 standard. While ASCE has made every effort to use data obtained from reliable sources or methodologies, ASCE does not make any representations or warranties as to the accuracy, completeness, reliability, currency, or quality of any data provided herein. Any third-party links provided by this Tool should not be construed as an endorsement, affiliation, relationship, or sponsorship of such third-party content by or from ASCE.

ASCE does not intend, nor should anyone interpret, the results provided by this Tool to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this Tool or the ASCE 7 standard.

In using this Tool, you expressly assume all risks associated with your use. Under no circumstances shall ASCE or its officers, directors, employees, members, affiliates, or agents be liable to you or any other person for any direct, indirect, special, incidental, or consequential damages arising from or related to your use of, or reliance on, the Tool or any information obtained therein. To the fullest extent permitted by law, you agree to release and hold harmless ASCE from any and all liability of any nature arising out of or resulting from any use of data provided by the ASCE 7 Hazard Tool.