



COUNCIL AGENDA ITEM COVER SHEET

Meeting Type: Council - Regular

Meeting Date: August 3, 2023

Agenda Item Type: New Business

Staff Contact: Scott Langford

STAFF REPORT

AGENDA ITEM:

Consideration to award the 2023 Sinkhole Repair 220 Stonewyck project to URETEK USA, Incorporated.

BACKGROUND:

A hole was reported near 220 Stonewyck Drive in the Town's right-of-way. The Town's infrastructure, gravity sewer, sewer forcemain, and stormwater culvert were inspected and are not contributing to the hole. There was a small seepage in the sewer manhole but it does not appear to be the problem. With the depth of the gravity sewer there was a possibility that the trench for the sewer line was blasted in rock. On occasion, blasting can cause a crack in the rock that could allow soil to migrate and form a sink hole. Because of this, the use of a high-density, hydro-insensitive polyurethane structural polymer was chosen as the repair. URETEK was recommended by a contractor that had great success with URETEK. This product should resolve both a crack issue and the manhole joint issue. The project estimate is \$29,238. Since the exact quantity is not known, staff is asking for a \$5,000 contingency in the event more polymer is need for a total of \$34,238.

FUNDING:

General Fund – Public Works

STAFF RECOMMENDATION:

Staff recommends award of the 2023 Sinkhole Repair 220 Stonewyck project to URETEK USA, Incorporated for the amount \$34,238.

ATTACHMENTS:

July 27, 2023 letter from URETEK USA, Inc.

PREVIOUS DISCUSSIONS:

None