



## WALLER COUNTY RIGHT-OF-WAY PERMIT

Approval Date: 2026-02-24

Permit # 2026-540

Issued To: San Bernard Electric Cooperative, San Bernard Electric  
Cooperative

Road Name: Macedonia Rd

Utility Type: Two poles in ROW for existing powerline.

The location of your proposed improvements within the County Right-Of-Way as shown by the accompanying notice is approved. Contractor shall notify Waller County Road and Bridge at (979) 826-7670, a minimum of 48 hours prior to construction.

Your attention is directed to Art. 1436A (for power lines) and Art. 1416 (communication lines) Vernon's Annotated Texas Civil Statutes with particular attention to the following provisions:

1. The Commissioners Court may designate the place along the right-of-way where such lines shall be constructed.
2. Placement of buried lines shall be a minimum of 36-inches below the flow line of the existing ditch. For installations parallel to the right-of-way, the utility shall be located within three (3) feet of the edge of the right-of-way, unless otherwise approved by the County Engineer.
3. All placement of lines beneath roadways and asphalt or concrete paved driveways shall be jacked and bored. No open cut will be allowed within five feet of the edge of roadways or such driveways. Open cuts on unpaved driveways shall be performed only with a trenching machine and shall not be excavated. In such cases the trench shall be backfilled and compacted. The driveway surface shall be restored to its original or better condition.
4. All buried water lines shall be marked thoroughly with detectable tracer wire. All other lines shall be marked thoroughly with detectable underground warning tape. Public to be safe-guarded by use of construction signs and barricades. Identification markers shall be placed along right-of-way lines, that is readily identifiable, indicating name of Company, type of line and emergency contact number.
5. Restore roads to their original condition. Trench is to be back-tracked, dragged, graded and filled as necessary to minimize erosion and sedimentation resulting from the proposed installation. Ditches are to be left clear for drainage.
6. The Commissioners Court may require the owner to relocate this line, for valid reasons under the law by giving thirty (30) days written notice.

A handwritten signature in blue ink, appearing to read "Ross McCall".

---

Ross McCall  
County Engineer