

Amendment #15 Amend Article 10 to require “all” subdivisions to include Rural open-ditch and Rural Public Road developments to supply county water to the development if water is within 1,500 feet of the development.

The Planning Commission recommended approval.

Section 10-2-120 Public Water Systems

If a public water supply is available to any proposed subdivision ***(to include Open-Ditch and Rural Public Road developments)*** or development and connection is permitted or required, the developer shall install all required water mains, fire hydrants, and connections from the existing water main to each lot in accordance with the Standards and Specifications of the Public Utility providing service. Connection to an operational public water system shall be required when any proposed subdivision or development lies within 1,500 feet from the nearest point on the property to an existing public water main (at least 6 inches in size), provided that there is an adequate water supply to serve the proposed development.