

**ARCHITECTURAL REVIEW BOARD
CERTIFICATE OF APPROPRIATENESS 22-27**

October 27, 2022

MOTION TO APPROVE

I move to approve the application for **Certificate of Appropriateness 22-27** for the proposed painting of unpainted brick at **20 North Fifth Street** with the following conditions:

1. Only lime-based paint be used on the unpainted brick, as proposed.
2. If lime-based paint is to be used on the sides and rear of the structure, it shall be primed with specialized primer to ensure adherence to the existing paint.
3. No high pressure washing, or any sandblasting shall occur.

Motion to Approve By:

Seconded By:

For:

Against:

Abstained: