

ARCHITECTURAL REVIEW BOARD  
CERTIFICATE OF APPROPRIATENESS 25-3

**February 27, 2025**

MOTION TO APPROVE

I move to approve the application for **Certificate of Appropriateness 25-3** for the request to install a new metal scroll bracket and hanging sign on the exterior of the building at **3 N. Fifth Street**, all as described and depicted within the application, provided the following conditions are met, as described and depicted within the application, provided the following conditions are met:

1. All necessary permits are acquired; and
2. The bracket shall be installed only within the mortar joints of the building's exterior in order to prevent any damage to the historic brick.
3. The sign panel should have a minimum six-inch (6") clearance from the face of the building and extend to its outermost part less than four (4) feet.
4. The bottom edge of the projecting sign should be eight (8) feet above the sidewalk.

Motion to Approve By:

Seconded By:

For:

Against:

Abstained: