

RESOLUTION
PURCHASE BORGER ROTARY LOBE SLUDGE PUMPS
SPONSOR: ALDERPERSON ARNETT
FROM: PUBLIC WORKS COMMISSION

WHEREAS, the Wastewater Department owns and operates an advanced wastewater treatment process which includes primary sludge pumps as part of the treatment plant, and;

WHEREAS, the primary sludge pumps play a critical role in transferring waste from one process to another at the wastewater treatment plant, and part of the immediate needs identified in the WWTP facilities plan included new primary sludge pumps estimated to cost \$188,000, as the entire primary sludge pump system is original, and;

WHEREAS, two of the four sludge pumps have failed, and one of the two screw compressors and air-drying system used to supply air to the diaphragm piston pumps has also failed, and most equipment is now obsolete so parts are no longer available for repairs, and;

WHEREAS, These four sludge pumps are part of the sludge system which includes four other sludge pumps, those all being the same Borger rotary lobe type, and these primary sludge pumps would be identical to the two dewatering transfer pumps which provides a uniform system of pumps and reduces spare parts, and provides easier maintenance for staff as all have been trained on the Borger pump maintenance so can perform routine maintenance more efficiently, and

NOW, THEREFORE, BE IT RESOLVED BY THE COMMON COUNCIL OF THE CITY OF WATERTOWN, WISCONSIN: that the proper City Officials be and are hereby authorized to purchase four new Borger rotary lobe sludge pumps and controls from Mulcahy Shaw Inc. for \$105,206.

The funding for said equipment will come from the equipment replacement account #02-97-30-12

	YES	NO
DAVIS		
LAMPE		
BERG		
BARTZ		
BLANKE		
SMITH		
ARNETT		
WETZEL		
MOLDENHAUER		
MAYOR STOCKS		
TOTAL		

ADOPTED November 4, 2025

CITY CLERK

APPROVED November 4, 2025

MAYOR