

WATERTOWN FIRE DEPARTMENT (WI)

INSPECTION REPORT

LATINO SUPER MARKET, 1504 S CHURCH ST, BLDG UNNAMED, WATERTOWN WI 53094



DETAILS

Inspection Date: 12/18/2024 | Inspection Type: Annual | Inspection Number: 3703 | Shift: N/A | Station: N/A | Unit: N/A |
Lead Inspector: Don Dishno | Other Inspectors: N/A

VIOLATIONS AND COMPLIANCES

Showing only violations and images for this inspection. Please reach out to the lead inspector for more details.
Resolved Violations: 0 | Passed Codes: 41 | Violations: 5 | N/A Codes: 0

STATUS	CODE	DESCRIPTION
FAIL	0.13 - Suppression system	Annual inspections up to date on suppression system? Location: Kitchen Original Comment: Current type two hood on location does not have a suppression system. When the type one hood is properly installed, a fire suppression system shall Also be Design, installed, and tested prior to any cooking taking place.
FAIL	32.4.11.1.5 - Extinguishment Requirements	Portable fire extinguishers shall be installed and maintained in accordance with Section 13.6. [140:4.11.1.5] Location: GENERAL Original Comment: An ABC fire extinguisher must be placed at each of the exterior doors.
FAIL	32.4.11.1.5 - Extinguishment Requirements	Portable fire extinguishers shall be installed and maintained in accordance with Section 13.6. [140:4.11.1.5] Location: Kitchen Original Comment: A Class K kitchen fire extinguisher must be placed in the kitchen.

STATUS	CODE	DESCRIPTION
FAIL	50.2.2.1 - Clearance	<p>Where enclosures are not required, hoods, grease removal devices, exhaust fans, and ducts shall have a clearance of at least 18 in. (457 mm) to combustible material, 3 in. (76 mm) to limited-combustible material, and 0 in. (0 mm) to noncombustible material. [96:4.2.1]</p> <p>Location: Kitchen</p> <p>Original Comment: All appliances must fit properly underneath a type one hood. Currently, the type two hood in place is not large enough for all of the equipment below it. The cooking shall take place until all violations are remedied.</p>
FAIL	50.4.4.7.3 - Modifications to Existing Hood Systems	<p>The addition of obstructions to spray patterns from the cooking appliance nozzle(s) such as baffle plates, shelves, or any modification shall not be permitted. [96:10.2.7.3]</p> <p>Location: Kitchen</p> <p>Original Comment: The current type two hood system is not designed for fryers, grills, charbroiler, or stoves. Have a qualified hood contractor evaluate the hood and duct system, and either properly design and modify existing hood or replace with the proper hood. No cooking shall take place until all violations are remedied.</p>

REINSPECTION DATE

01/17/2025

FEE

Invoice Date: N/A | Inspection Fee: N/A | Date Paid: N/A | Amount Paid: N/A | Invoice Number: N/A | Check Number: N/A | Transaction Number: N/A

CONTACT SIGNATURE

Felisa Corona Forte
Signed on: 12/18/2024 @ 16:02

INSPECTOR SIGNATURE

Don Dishno
Signed on: 12/18/2024 @ 16:03

A handwritten signature in black ink, appearing to read 'Don Dishno', written over a horizontal line.

QUESTIONS ABOUT YOUR INSPECTION?

Don Dishno
ddishno@watertownwi.gov
No phone number available

David Johnsen

From: Don Dishno
Sent: Wednesday, December 18, 2024 9:18 PM
To: Lumos Dei Consulting Services LLC; notification@esosolutions.com
Cc: David Johnsen
Subject: Re: Inspection Report for your occupancy

Felisa,

I want to make sure we all understand that there shall be NO COOKING on site until the proper hood and suppression systems are in. Doing so could cause a fire or potentially activate the building fire sprinkler system, causing water damage and possibly injury.

Please contact me with any questions or concerns. Thank you.

Don A. Dishno

City of Watertown Fire Inspector

E: ddishno@watertownwi.gov

P: 920.261.3610

C: 920.285.8095



From: Lumos Dei Consulting Services LLC <lumosdeiconsultingservices@gmail.com>
Sent: Wednesday, December 18, 2024 4:17:47 PM
To: notification@esosolutions.com <notification@esosolutions.com>
Cc: David Johnsen <DJohnsen@watertownwi.gov>; Don Dishno <DDishno@watertownwi.gov>
Subject: Re: Inspection Report for your occupancy

Thank you for the report



FELISA CORONA-FORTE
BUSINESS CONSULTANT

608-333-4167

WWW.lumosdeiconsultingservices.com

On Wed, Dec 18, 2024 at 4:04 PM <notification@esosolutions.com> wrote:

Attached is the inspection report recently completed on your occupancy. Information about contacting your inspector is within the inspection report.

Please do not reply to this email.



Watertown Fire Department

106 Jones Street, Watertown, WI 53094

Phone: 920-261-3610 | Fax: 920-261-7527

FDID	State	Incident #	Exposure	CAD #	Internal Incident #	Station	Shift
28090	WI	250000728	0	WCD-2500004	25-0000723	Station One	A
Incident Date	Event / Call Time		Emergency / Non Emergency		Incident Action		
2/24/2025	20:36:34		Emergency		86 86 Investigate		
Incident Type							
711	711 Municipal alarm system, malicious false alarm						
Incident Type Plus One					Aid Given or Received: None		

Times				
Alarm Time	En Route	Arrival	Last Unit Cleared	Time Controlled
20:36:43	20:38:08	20:40:57	21:18:19	
EMS Unit	EMS Dispatch	EMS En Route	EMS Arrival	With Patient

General			
Location Type	Address	Property ID	
1 - Street address	1504 S Church ST Watertown, Jefferson County		
District/Box	State	City	Zip Code
01- Watertown Ci	WI - Wisconsin	Watertown, Jefferson County	53094
Number/Milepost	Street or Highway		Apt./Suit/Room
1504	S Church ST		
Number/Milepost	Crossing street		

Narrative

Dispatched for a fire alarm at the listed address. This was our third call within nine hours for a fire alarm at this location. Upon arrival found the 2 occupants outside and all the doors propped open. When we made entry interior we found a light haze of smoke throughout the location. The alarm was reset prior to our arrival. Further investigations found that they were cooking and the ventilation hood system is not properly working. There is no active fire or hazards. The manager stated that they know the hood system is not working and they are working with the owner of the property to get it fixed. We informed them that they can no longer cook until the hood/ventilation system is serviced and fixed. We also informed them that we would be sending out a fire inspector at 10 am tomorrow to inspect the hood system. All units cleared the scene and returned to quarters.

Property

Is Residential Number of Residential Units: 1

Estimated Dollar Value and Losses	Property Use / HazMat / Detector Status
<p>PRE-INCIDENT VALUES</p> <p style="padding-left: 20px;">Property</p> <p style="padding-left: 20px;">Contents</p> <p>LOSSES (If no loss, leave blank)</p> <p style="padding-left: 20px;">Property</p> <p style="padding-left: 20px;">Contents</p>	<p>Property Use</p> <p>519 519 Food and beverage sales, grocery store</p> <p>Mixed Property Use</p> <p>HazMat Release</p> <p>Detector Status</p>

Response

Apparatus ID	CAD App ID	Dispatch (DP)	Enroute (ER)	Arrival (AR)	Cleared	# of Personnel
4110 - Comma	4110	20:38:20	20:38:22	20:41:34	21:18:19	1
4154 - Ambula	4154	20:36:43	20:38:08	20:40:57	21:18:19	2
4161 - Engine	4161	20:36:44	20:38:16	20:41:33	21:18:19	4

Authorization

Member Making Report

Member Making Report	Member Making Assignment	Report Completed Date
Matthew Pieper	Battalion Chief	2/24/2025 9:25:56 PM

Officer In Charge

Officer In Charge	Officer In Charge Assignment
Matthew Pieper	Battalion Chief

Review

Report Reviewed By	Report Reviewed Date



Watertown Fire Department

106 Jones Street, Watertown, WI 53094

Phone: 920-261-3610 | Fax: 920-261-7527

FDID	State	Incident #	Exposure	CAD #	Internal Incident #	Station	Shift
28090	WI	250000723	0	WCD-2500004	25-0000718	Station One	A
Incident Date	Event / Call Time		Emergency / Non Emergency		Incident Action		
2/24/2025	14:07:40		Emergency		86 86 Investigate		
Incident Type							
735	735 Alarm system sounded due to malfunction						
Incident Type Plus One					Aid Given or Received: None		

Times

Alarm Time	En Route	Arrival	Last Unit Cleared	Time Controlled
14:08:44	14:09:29	14:12:35	14:33:44	
EMS Unit	EMS Dispatch	EMS En Route	EMS Arrival	With Patient

General

Location Type	Address	Property ID	
1 - Street address	1504 S Church ST Watertown, Jefferson County		
District/Box	State	City	Zip Code
01- Watertown Ci	WI - Wisconsin	Watertown, Jefferson County	53094
Number/Milepost	Street or Highway		Apt./Suit/Room
1504	S Church ST		
Number/Milepost	Crossing street		

Narrative

Dispatched for a fire alarm. While en route dispatch notified us that they received a call from the property stating there was no fire and they wanted to cancel the response. 4110 continued to the scene. Upon arrival there was no smoke or flames showing. 4110 made contact with 2 occupants inside that stated there were no hazards and that the alarm did not sound in the building. The manager stated he thinks there are issues with the alarm system. I informed him to call a technician to fix the alarm, and if they need to take the alarm offline they need to have a fire watch. I walked the building and found no hazards. 4110 cleared the scene. While enroute back to the station dispatch notified me over the radio that they got another call from the alarm company in regard to a fire alarm at the listed address so I responded back to the scene. I found no hazards and re informed the manager that they should get a service technician out to service the fire alarm. I also informed him that if they need to take the alarm offline they have to contact the fire department and have a firewatch. 4110 cleared the scene and returned to quarters

Property

Is Residential Number of Residential Units: 1

Estimated Dollar Value and Losses

PRE-INCIDENT VALUES

Property

Contents

LOSSES (If no loss, leave blank)

Property

Contents

Property Use / HazMat / Detector Status

Property Use

519 519 Food and beverage sales, grocery store

Mixed Property Use

HazMat Release

Detector Status

Response

Apparatus ID	CAD App ID	Dispatch (DP)	Enroute (ER)	Arrival (AR)	Cleared	# of Personnel
4110 - Comma	4110	14:09:30	14:09:33	14:12:35	14:33:44	1

Authorization

Member Making Report

Member Making Report

Matthew Pieper

Member Making Assignment

Deputy Chief

Report Completed Date

2/24/2025 2:58:10 PM

Officer In Charge

Officer In Charge

Matthew Pieper

Officer In Charge Assignment

Deputy Chief

Review

Report Reviewed By

Report Reviewed Date



Watertown Fire Department

106 Jones Street, Watertown, WI 53094

Phone: 920-261-3610 | Fax: 920-261-7527

FDID	State	Incident #	Exposure	CAD #	Internal Incident #	Station	Shift
28090	WI	250000650	0	WCD-2500004	25-0000645	Station One	A

Incident Date	Event / Call Time	Emergency / Non Emergency	Incident Action
2/17/2025	9:09:07	Emergency	86 86 Investigate

Incident Type

745 745 Alarm system activation, no fire - unintentional

Incident Type Plus One

Aid Given or Received: None

Times

Alarm Time	En Route	Arrival	Last Unit Cleared	Time Controlled
9:09:31	9:10:01	9:13:57	9:18:59	
EMS Unit	EMS Dispatch	EMS En Route	EMS Arrival	With Patient

General

Location Type	Address	Property ID	
1 - Street address	1504 S Church ST Watertown, Jefferson County		
District/Box	State	City	Zip Code
03-Watertown Cit	WI - Wisconsin	Watertown, Jefferson County	53094
Number/Milepost	Street or Highway	Apt./Suit/Room	
1504	S Church ST		
Number/Milepost	Crossing street		

Narrative

WFD dispatched 911 to above location for a fire alarm. While enroute 4110 and 4161 advised by dispatch that alarm company had called back to cancel the alarm. 4161 continued in non-emergent to verify. Upon arrival no alarms were present. Spoke with a person inside who stated the alarm was due to burnt food and he had reset the alarm prior to FD arrival. FD advised the gentleman he should not be resetting the alarm. FD confirmed the burnt food and no other hazards present. FD cleared and went to another call for service. A name was not taken due to multiple runs.

Property

Is Residential Number of Residential Units: 1

Estimated Dollar Value and Losses	Property Use / HazMat / Detector Status
<p>PRE-INCIDENT VALUES</p> <p style="padding-left: 20px;">Property</p> <p style="padding-left: 20px;">Contents</p> <p>LOSSES (If no loss, leave blank)</p> <p style="padding-left: 20px;">Property</p> <p style="padding-left: 20px;">Contents</p>	<p>Property Use</p> <p>161 161 Restaurant or cafeteria</p> <p>Mixed Property Use</p> <p>HazMat Release</p> <p>Detector Status</p>

Response

Apparatus ID	CAD App ID	Dispatch (DP)	Enroute (ER)	Arrival (AR)	Cleared	# of Personnel
4161 - Engine	4161	9:10:59	9:11:02	9:13:57	9:18:59	4

Authorization

Member Making Report

Member Making Report Brandon Wojnowski	Member Making Assignment Company Officer	Report Completed Date 2/17/2025 10:14:49 AM
--------------------------------------------------	----------------------------------------------------	-------------------------------------------------------

Officer In Charge

Officer In Charge Brandon Wojnowski	Officer In Charge Assignment Company Officer
-----------------------------------------------	--------------------------------------------------------

Review

Report Reviewed By David Johnsen	Report Reviewed Date #####
--------------------------------------------	--------------------------------------



Watertown Fire Department

106 Jones Street, Watertown, WI 53094

Phone: 920-261-3610 | Fax: 920-261-7527

FDID	State	Incident #	Exposure	CAD #	Internal Incident #	Station	Shift
28090	WI	250000615	0	WCD-2500003	25-0000610	Station One	C
Incident Date	Event / Call Time		Emergency / Non Emergency		Incident Action		
02/14/25	13:03:38		Emergency		86 86 Investigate		
Incident Type							
740	740 Unintentional transmission of alarm, other						
Incident Type Plus One				Aid Given or Received: None			

Times

Alarm Time	En Route	Arrival	Last Unit Cleared	Time Controlled
13:04:14	13:04:21	13:08:42	13:15:29	
EMS Unit	EMS Dispatch	EMS En Route	EMS Arrival	With Patient

General

Location Type	Address	Property ID	
1 - Street address	1504 S Church ST Watertown, Jefferson County		
District/Box	State	City	Zip Code
02- Watertown Ci	WI - Wisconsin	Watertown, Jefferson County	53094
Number/Milepost	Street or Highway		Apt./Suit/Room
1504	S Church ST		
Number/Milepost	Crossing street		

Narrative

Dispatched for a fire alarm; while en route, dispatch advised that it was a false alarm and no response was not needed. 4110 On scene single-story strip mall, nothing showing, investigating. Investigation showed that the smoke alarm was due to burnt food; no hazards were noted. The alarm system was in normal operation. E61 cancelled, and 4110 returned to service.

Property

Is Residential Number of Residential Units: 1

Estimated Dollar Value and Losses

PRE-INCIDENT VALUES

Property

Contents

LOSSES (If no loss, leave blank)

Property

Contents

Property Use / HazMat / Detector Status

Property Use

519 519 Food and beverage sales, grocery store

Mixed Property Use

HazMat Release

Detector Status

Response

Apparatus ID	CAD App ID	Dispatch (DP)	Enroute (ER)	Arrival (AR)	Cleared	# of Personnel
4110 - Comma	4110	13:04:25	13:04:27	13:08:42	13:15:29	1
4161 - Engine	4161	13:04:16	13:04:21		13:09:43	4

Authorization

Member Making Report

Member Making Report

Chad Butzine

Member Making Assignment

Battalion Chief

Report Completed Date

02/14/25 20:42:09

Officer In Charge

Officer In Charge

Chad Butzine

Officer In Charge Assignment

Battalion Chief

Review

Report Reviewed By

David Johnsen

Report Reviewed Date

02/23/25 13:07:28



Watertown Fire Department

106 Jones Street, Watertown, WI 53094

Phone: 920-261-3610 | Fax: 920-261-7527

FDID	State	Incident #	Exposure	CAD #	Internal Incident #	Station	Shift
28090	WI	250000482	0	WCD-2500002	25-0000477	Station One	A

Incident Date	Event / Call Time	Emergency / Non Emergency	Incident Action
1/30/2025	14:02:15	Emergency	86 86 Investigate

Incident Type

745 745 Alarm system activation, no fire - unintentional

Incident Type Plus One

Aid Given or Received: None

Times

Alarm Time	En Route	Arrival	Last Unit Cleared	Time Controlled
14:02:32	14:03:39	14:07:12	14:11:19	
EMS Unit	EMS Dispatch	EMS En Route	EMS Arrival	With Patient

General

Location Type	Address	Property ID	
1 - Street address	1504 S Church ST Watertown, Jefferson County		
District/Box	State	City	Zip Code
01- Watertown Ci	WI - Wisconsin	Watertown, Jefferson County	53094
Number/Milepost	Street or Highway	Apt./Suit/Room	
1504	S Church ST		
Number/Milepost	Crossing street		

Narrative

Dispatched to the listed address for a fire alarm. While en route dispatch notified us that the store called them and wanted to cancel the alarm. We continued non emergent. We made contact with the store owner and walked through the store. There was no alarm and no hazards. 4110 and Engine 61 cleared the scene.

Property

Is Residential Number of Residential Units: 1

Estimated Dollar Value and Losses

PRE-INCIDENT VALUES

Property

Contents

LOSSES (If no loss, leave blank)

Property

Contents

Property Use / HazMat / Detector Status

Property Use

519 519 Food and beverage sales, grocery store

Mixed Property Use

HazMat Release

Detector Status

Response

Apparatus ID	CAD App ID	Dispatch (DP)	Enroute (ER)	Arrival (AR)	Cleared	# of Personnel
4110 - Comma	4110	14:02:32	14:04:12	14:07:37	14:11:19	1
4154 - Ambula	4154	14:03:05	14:04:15	14:07:12	14:07:45	2
4161 - Engine	4161	14:03:03	14:03:39	14:07:43	14:11:10	4

Authorization

Member Making Report

Member Making Report

Matthew Pieper

Member Making Assignment

Battalion Chief

Report Completed Date

1/30/2025 5:00:40 PM

Officer In Charge

Officer In Charge

Matthew Pieper

Officer In Charge Assignment

Battalion Chief

Review

Report Reviewed By

David Johnsen

Report Reviewed Date

2/3/2025 7:32:15 PM



Watertown Fire Department

106 Jones Street, Watertown, WI 53094

Phone: 920-261-3610 | Fax: 920-261-7527

FDID	State	Incident #	Exposure	CAD #	Internal Incident #	Station	Shift
28090	WI	250000211	0	WCD-2500001	25-0000207	Station One	C
Incident Date	Event / Call Time		Emergency / Non Emergency	Incident Action			
01/20/25	10:28:21		Emergency	86 86 Investigate			
Incident Type							
745	745 Alarm system activation, no fire - unintentional						
Incident Type Plus One				Aid Given or Received: None			

Times				
Alarm Time	En Route	Arrival	Last Unit Cleared	Time Controlled
10:28:34	10:29:22	10:32:30	10:53:41	
EMS Unit	EMS Dispatch	EMS En Route	EMS Arrival	With Patient

General			
Location Type	Address	Property ID	
1 - Street address	1504 S Church ST Watertown, Jefferson County		
District/Box	State	City	Zip Code
03-Watertown Cit	WI - Wisconsin	Watertown, Jefferson County	53094
Number/Milepost	Street or Highway	Apt./Suit/Room	
1504	S Church ST		
Number/Milepost	Crossing street		

Narrative

Dispatched for a smoke duct detector alarm, while enroute advised by dispatch that they received a call stating no hazards alarm was due to smoke from cooking no fire asking to cancel. Advised dispatch that we would follow in. Upon arrival found two story strip mall restaurant nothing showing alarms present partial evacuation. Confirmed that there were no hazards in the building and attempted system reset. System would not reset and building occupants were advised of the issue that they would need a alarm co to look at the system. No hazards present all WFD units returned to service.

Property

Is Residential Number of Residential Units: 1

Estimated Dollar Value and Losses

PRE-INCIDENT VALUES

Property

Contents

LOSSES (If no loss, leave blank)

Property

Contents

Property Use / HazMat / Detector Status

Property Use

161 161 Restaurant or cafeteria

Mixed Property Use

51 - Row of stores

HazMat Release

Detector Status

Response

Apparatus ID	CAD App ID	Dispatch (DP)	Enroute (ER)	Arrival (AR)	Cleared	# of Personnel
4110 - Comma	4110	10:28:34	10:29:22	10:32:30	10:53:41	1
4161 - Engine	4161	10:28:39	10:30:13	10:33:03	10:53:13	3

Authorization

Member Making Report

Member Making Report

Chad Butzine

Member Making Assignment

Battalion Chief

Report Completed Date

01/20/25 21:43:51

Officer In Charge

Officer In Charge

Chad Butzine

Officer In Charge Assignment

Battalion Chief

Review

Report Reviewed By

David Johnsen

Report Reviewed Date

01/24/25 21:40:35



Watertown Fire Department

106 Jones Street, Watertown, WI 53094

Phone: 920-261-3610 | Fax: 920-261-7527

FDID	State	Incident #	Exposure	CAD #	Internal Incident #	Station	Shift
28090	WI	250000126	0	WCD-2500001	25-0000124	Station One	A
Incident Date	Event / Call Time		Emergency / Non Emergency	Incident Action			
01/12/25	15:25:35		Emergency	86	86 Investigate		
				63	63 Restore fire alarm system		
Incident Type							
745	745 Alarm system activation, no fire - unintentional						
Incident Type Plus One				Aid Given or Received: None			

Times

Alarm Time	En Route	Arrival	Last Unit Cleared	Time Controlled
15:25:48	15:27:18	15:29:56	15:59:58	
EMS Unit	EMS Dispatch	EMS En Route	EMS Arrival	With Patient

General

Location Type	Address	Property ID	
1 - Street address	1504 S Church ST Watertown, Jefferson County		
District/Box	State	City	Zip Code
01- Watertown Ci	WI - Wisconsin	Watertown, Jefferson County	53094
Number/Milepost	Street or Highway	Apt./Suit/Room	
1504	S Church ST		
Number/Milepost	Crossing street		

Narrative

Dispatched 911 for an automatic fire alarm at 1504 S. Church St. at the Latinos Supermarket. On arrival entrance was made into the Latinos Supermarket and no smoke, no fire, and no alarms were going off. There was also no evacuation in progress. The fire alarm panel indicated trouble alarm and WFD was able to reset the alarm system back to normal. The owner of the business, Melissa Olampo, was spoken to with her daughter as an interpreter. This is approximately the 4th trouble alarm or false alarm in the past few weeks and the owner was told she needed to contact the alarm company tomorrow morning when the alarm company opens to try and get a technician out to trouble shoot and fix the alarm system. The remaining strip mall occupancies were inspected, and no hazards were found. All units were released by 4110 (Command).

Property

Is Residential Number of Residential Units: 1

Estimated Dollar Value and Losses

PRE-INCIDENT VALUES

Property

Contents

LOSSES (If no loss, leave blank)

Property

Contents

Property Use / HazMat / Detector Status

Property Use

519 519 Food and beverage sales, grocery store

Mixed Property Use

HazMat Release

Detector Status

1 - Detector alerted occupants

Response

Apparatus ID	CAD App ID	Dispatch (DP)	Enroute (ER)	Arrival (AR)	Cleared	# of Personnel
4110 - Comma	4110	15:25:48	15:27:34	15:29:56	15:59:58	1
4154 - Ambula	4154	15:25:49	15:27:18	15:30:04	15:59:58	2
4161 - Engine	4161	15:25:51	15:27:32	15:30:43	15:59:58	4

Authorization

Member Making Report

Member Making Report

John Duvernell

Member Making Assignment

Company Officer

Report Completed Date

01/12/25 16:23:12

Officer In Charge

Officer In Charge

Brandon Wojnowski

Officer In Charge Assignment

Incident Command

Review

Report Reviewed By

David Johnsen

Report Reviewed Date

01/15/25 09:44:59



Watertown Fire Department

106 Jones Street, Watertown, WI 53094

Phone: 920-261-3610 | Fax: 920-261-7527

FDID	State	Incident #	Exposure	CAD #	Internal Incident #	Station	Shift
28090	WI	250000117	0	WCD-2500001	25-0000115	Station One	C
Incident Date	Event / Call Time		Emergency / Non Emergency	Incident Action			
01/11/25	20:43:33		Emergency	86	86 Investigate		
Incident Type				63	63 Restore fire alarm system		
735	735 Alarm system sounded due to malfunction			84	84 Refer to proper authority		
Incident Type Plus One				Aid Given or Received: None			

Times

Alarm Time	En Route	Arrival	Last Unit Cleared	Time Controlled
20:43:39	20:44:58	20:47:22	21:32:32	
EMS Unit	EMS Dispatch	EMS En Route	EMS Arrival	With Patient

General

Location Type	Address	Property ID	
1 - Street address	1504 S Church ST Watertown, Jefferson County		
District/Box	State	City	Zip Code
03-Watertown Cit	WI - Wisconsin	Watertown, Jefferson County	53094
Number/Milepost	Street or Highway		Apt./Suit/Room
1504	S Church ST		
Number/Milepost	Crossing street		

Narrative

Dispatched for a fire alarm no zone. Upon arrival found strip mall single story nothing showing alarms active. Panel shows communication error no alarm system in trouble mode. Remote panels would not reset the system. Contacted building manager and reset the system from the main panel in rear of building. Advised the manager Josh that the system should be inspected by the alarm company due to the number of false alarms recently. All occupancies check by FD personnel no hazards found and building turned back over to tenants. All fire units returned to service.

Property

Is Residential Number of Residential Units: 1

Estimated Dollar Value and Losses

PRE-INCIDENT VALUES

Property

Contents

LOSSES (If no loss, leave blank)

Property

Contents

Property Use / HazMat / Detector Status

Property Use

161 161 Restaurant or cafeteria

Mixed Property Use

51 - Row of stores

HazMat Release

Detector Status

Response

Apparatus ID	CAD App ID	Dispatch (DP)	Enroute (ER)	Arrival (AR)	Cleared	# of Personnel
4110 - Comma	4110	20:44:53	20:44:58	20:48:48	21:32:32	1
4154 - Ambula	4154	20:43:40	20:45:17	20:47:22	21:32:32	2
4161 - Engine	4161	20:43:39	20:46:09	20:48:45	21:32:32	4

Owner /Involved Person and Entities

Owner Full Name	Owner / Involved	Person / Entity	Phone Number	Entity Name
Anderson, josh	2 - Involved	1 - Person	608-712-5544	

Birth Date: Is Responsible Party

E-Mail:

Mail Address: 1504 S Church ST Watertown WI 53094

Authorization

Member Making Report

Member Making Report	Member Making Assignment	Report Completed Date
Chad Butzine	Battalion Chief	01/11/25 23:18:33

Officer In Charge

Officer In Charge	Officer In Charge Assignment
Chad Butzine	Battalion Chief

Review

Report Reviewed By	Report Reviewed Date
David Johnsen	01/12/25 08:22:45



Watertown Fire Department

106 Jones Street, Watertown, WI 53094

Phone: 920-261-3610 | Fax: 920-261-7527

FDID	State	Incident #	Exposure	CAD #	Internal Incident #	Station	Shift
28090	WI	250000012	0	250000012	25-0000012	Station One	C

Incident Date	Event / Call Time	Emergency / Non Emergency	Incident Action
1/2/2025	9:00:20	Emergency	86 86 Investigate 63 63 Restore fire alarm system

Incident Type
745 745 Alarm system activation, no fire - unintentional

Incident Type Plus One

Aid Given or Received: None

Times

Alarm Time	En Route	Arrival	Last Unit Cleared	Time Controlled
9:00:45	9:01:39	9:02:22	10:01:11	
EMS Unit	EMS Dispatch	EMS En Route	EMS Arrival	With Patient

General

Location Type	Address	Property ID	
1 - Street address	1504 S Church ST Watertown, Jefferson County		
District/Box	State	City	Zip Code
03-Watertown Cit	WI - Wisconsin	Watertown, Jefferson County	53094
Number/Milepost	Street or Highway	Apt./Suit/Room	
1504	S Church ST		
Number/Milepost	Crossing street		

Narrative

Dispatched for a fire alarm zone 31 nothing specific (old pizza hut). Upon arrival found strip mall mixed use with nothing showing. Crew made contact with occupants in (old Pizza hut) at address stated they were cooking in the kitchen and set off smoke detector. No Hazards found with investigation. Gained entry via knox box located at 1512 S. Church St. where the alarm panel is located. Engine crew confirmed no hazards in entire building system was reset and 1512 resecured. No other assistance needed all units returned to service.

Property

Is Residential Number of Residential Units: 1

Estimated Dollar Value and Losses	Property Use / HazMat / Detector Status
<p>PRE-INCIDENT VALUES</p> <p style="padding-left: 20px;">Property</p> <p style="padding-left: 20px;">Contents</p> <p>LOSSES (If no loss, leave blank)</p> <p style="padding-left: 20px;">Property</p> <p style="padding-left: 20px;">Contents</p>	<p>Property Use</p> <p>161 161 Restaurant or cafeteria</p> <p>Mixed Property Use</p> <p>51 - Row of stores</p> <p>HazMat Release</p> <p>Detector Status</p>

Response

Apparatus ID	CAD App ID	Dispatch (DP)	Enroute (ER)	Arrival (AR)	Cleared	# of Personnel
4110 - Comma	4110	9:01:20	9:01:39	9:04:04	10:01:11	1
4154 - Ambula	4154	9:00:50	9:02:30	9:05:06	10:01:11	2
4161 - Engine	4161	9:00:45	9:02:43	9:05:04	10:01:11	4
4181 - Brush T	4181	9:02:19	9:02:22	9:02:22	10:01:11	1

Owner /Involved Person and Entities

Owner Full Name	Owner / Involved	Person / Entity	Phone Number	Entity Name
Roblers, Alex	2 - Involved			
Birth Date:	<input type="checkbox"/> Is Responsible Party			
E-Mail:				
Mail Address: 1504 S Church ST Watertown WI 53094				

Authorization

Member Making Report

Member Making Report	Member Making Assignment	Report Completed Date
Chad Butzine	Battalion Chief	1/2/2025 6:46:37 PM

Officer In Charge

Officer In Charge	Officer In Charge Assignment
Chad Butzine	Battalion Chief

Review

Report Reviewed By	Report Reviewed Date
David Johnsen	2/3/2025 8:56:15 PM