

**From:** [Donna Cesaro](#)  
**To:** [Donna Cesaro](#)  
**Subject:** FW: Christ Fellowship @ Westlake - Engineering Updates  
**Date:** Tuesday, August 10, 2021 2:59:15 PM  
**Attachments:** [image001.png](#)

---

**From:** David Baggett <[davidbaggett@edc-inc.com](mailto:davidbaggett@edc-inc.com)>  
**Sent:** Thursday, June 3, 2021 9:16 AM  
**To:** Donna Cesaro <[dcesaro@coteur-hearing.com](mailto:dcesaro@coteur-hearing.com)>; Don Hearing <[dhearing@coteur-hearing.com](mailto:dhearing@coteur-hearing.com)>; Leo Abdella <[leo.abdella@christfellowship.church](mailto:leo.abdella@christfellowship.church)>  
**Cc:** Matt Blackburn <[Matt.Blackburn@weitz.com](mailto:Matt.Blackburn@weitz.com)>; Gary Ducote <[gary@pipelineutilities.com](mailto:gary@pipelineutilities.com)>; Jessica Whitt <[jessicawhitt@edc-inc.com](mailto:jessicawhitt@edc-inc.com)>  
**Subject:** RE: Christ Fellowship @ Westlake

Donna, the changes were based on your site plan revisions as I used your base. Notable revisions are as follow...

- Limits of brick pavers in the parking lot were reduced as shown.
- Future development areas have been removed from the plans. These areas will be graded down to collect drainage. They will be sodded / landscape in the interim condition until and future development is pursued. Utility stubs for sewer service will be installed now. Water service is available via the Waters Edge and Ilex Right-of-Way.
- Finished floor and parking lot grades revised (lowered slightly, still remain above required minimum elevations per SFWMD Conceptual ERP permit).

I also replied on 5/18 that I don't believe my construction plans were ever reviewed with the initial submittals from 2019-20, just preliminary engineering plans.

Thank you

**David C. Baggett, P.E.**  
**Project Manager | Engineering Division**



**ENGINEERS**  **SURVEYORS**  **ENVIRONMENTAL**

10250 SW Village Parkway - Suite 201  
Port Saint Lucie, Florida 34987

**O:** 772.462.2455 ext 113

[DavidBaggett@EDC-Inc.com](mailto:DavidBaggett@EDC-Inc.com) | [www.EDC-Inc.com](http://www.EDC-Inc.com)

 *Think before you print.*

We ask that you **GO GREEN!** Please consider the environment before printing this email.

**Encryption Statement:** When possible, emails are protected using Transport Layer Security (TLS) on any outgoing or incoming correspondence. TLS does not work with all email providers.

**Privacy Statement:** This e-mail, including any attachments, may contain information that is legally protected from unauthorized disclosure. If you are not the intended recipient, any dissemination, distribution or copying of this communication is strictly prohibited. If you have received this message in error, you should notify the

sender immediately by telephone or by return email and delete this email from your computer.

||