

ROOF PLAN NOTES C	
	(16) GALVANIZED METAL PARAPET CAP. SEE DETAIL 2 & 5/A6.0
<ul> <li>PRIMER.</li> <li>B. TOP NAILING AT PARAPET CAP FLASHING WILL NOT BE ACCEPTED.</li> <li>C. PENETRATIONS IN ROOFING MEMBRANE AND FLASHING SHALL ONLY BE MADE AS INDICATED ON THE DRAWINGS OR SPECS.</li> <li>D. SEE SPECIFICATIONS <u>FOR SEALANT SPECS.</u></li> <li>E. ALL SHEET MTL FLASHING SHALL BE 22 GA MIN.</li> <li><u>MISCELLANEOUS:</u></li> <li>A. ROOF PENETRATIONS CLOSER THAN 12" FROM ANOTHER WILL NOT BE ALLOWED.</li> <li>B. EXHAUST FANS MIN. 10'-0" AWAY FROM ALL AIR INTAKE / SUPPLY.</li> <li>C. LOCATE WALK-IN CONDENSERS ON ROOF ONLY IF REQUIRED BY CODE.</li> </ul>	15 ROOF CRICKET. SEE DETAIL 16/A6.0.
	14 CHANGE IN PARAPET ELEVATION SEE DETAIL 11/A6.2.
	13 ROOF HATCH. SEE SHEET DETAIL 7/A6.0.
	12 NOT USED.
	11 SCUPPER AND DOWNSPOUT. SEE DETAIL D/A3.0.
	10 24x36 WALK MATS. SEE ROOF SPECS.
	9 PIPE HOOD FOR UTILITIES. SEE DETAIL 9/A6.0.
	8 GC SHALL PROVIDE ALUMASTAND EQUIPMENT PLATFORM BY PRECIS PRODUCTS OR OWNER APPROVED EQUAL. SEE DETAIL 15/A6.0.
	7 WALK-IN COOLER / FREEZER CONDENSERS. SEE EQUIPMEN PLAN.
	6 ICE MACHINE CONDENSERS.
	5 BUILT-UP FOAM CRICKETS.
	4 CANOPY. SEE SCOPE OF WORK.
	3 RESTROOM EXHAUST FAN. SEE 18/A6.0.
	2 KITCHEN HOOD EXHAUST FAN. SEE SHEETS M3.0 & DETAIL 19/A6.0.
WATERPROOFING: A. PAINT UNDERSIDE OF PARAPET CAP FLASHING WITH FACTORY BONDED PAINT GRIP OR	1 ROOFTOP UNIT. INSTALL PLUMB AND LEVEL.