## CERTIFICATE OF SUBSTANTIAL COMPLETION

PROJECT: UTILITY EXTENSIONS AT WEST MONROE COMMERCIAL PARK
ENGINEER: LAZENBY & ASSOCIATES, INC.
OWNER:CITY OF WEST MONROE
CONTRACTOR: JABAR CORPORATION
CONTRACT DATE: MAY 11, 2022
DATE OF ISSUANCE: FEBRUARY 8, 2023
This Certificate of Substantial Completion applies to all Work under the Contract Documents or to the following specified parts thereof:
All Work
The Work to which this certificate applies has been inspected by authorized representatives of OWNER, CONTRACTOR and ENGINEER, and that Work is hereby declared to be substantially complete in accordance with the Contract Documents on
<u>February 8, 2023</u> Date of Substantial Completion
A tentative list of items to be completed or corrected is attached hereto. This list may not be all-inclusive, and the failure to include an item in it does not alter the responsibility of CONTRACTOR to complete all the Work in accordance with the Contract Documents. The items in the tentative list shall be completed or corrected by CONTRACTOR within <a href="21 calendar">21 calendar</a> days of the above date of Substantial Completion.
The Date of Substantial Completion is the date upon which all guarantees and warranties begin, except as follows:
The 45-day lien period shall begin upon the date that this document is filed with the Clerk of Court in Ouachita Parish.
This certificate does not constitute an acceptance of Work not in accordance with the Contract Documents nor is it a release of CONTRACTOR's obligation to complete the Work in accordance with the Contract Documents.
Executed by ENGINEER on February 8, 2023
Lazenby & Associates, Inc.  ENGINEER  By:  Dason T. Thornbill, P.E.  CONTRACTOR accepts this Certificate of Substantial Completion on  Date
JABAR Corporation CONTRACTOR  By: John Putnam, President
OWNER accepts this Certificate of Substantial Completion on
By: Staci Albritton Mitchell, Mayor

## FINAL INSPECTION "PUNCH LIST"

## UTILITY EXTENSIONS AT WEST MONROE COMMERCIAL PARK CITY OF WEST MONROE, LOUISIANA L&A, INC. PROJECT NO. 22E017.00

## **FEBRUARY 8, 2023**

- 1. Perform final grading and seeding of disturbed areas once site conditions allow.
- 2. Re-grout Manhole No. 4-A as required to eliminate groundwater infiltration at connection of HDPE gravity main.