

From: [Dan Buckingham](#)
To: [Kevin Boehm](#)
Subject: Fwd: Whitewater aquatic
Date: Friday, March 1, 2024 11:01:07 AM
Attachments: [image001.jpg](#)
[image002.png](#)
[image003.jpg](#)
[image004.jpg](#)
[image005.png](#)

Sent from my U.S.Cellular© Smartphone
Get [Outlook for Android](#)

From: Bowerman, Tom <TBowerman@vyron.com>
Sent: Monday, February 26, 2024 4:28:02 PM
To: Dan Buckingham <DBuckingham@whitewater-wi.gov>
Subject: RE: Whitewater aquatic

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Dan,

It was nice meeting you last week and I appreciate again the opportunity. There are a few items to note:

1. With this being a Pool, the DuctSox factory is telling me that the hardware you have on site (that I took pictures of) does not appear to be pool grade. Knowing that you wish to use the existing hanging hardware, please note that if any issues occurred due to hardware breaking and tearing the DuctSox, the DuctSox product would not be covered under warranty.
 - So our \$17,850 proposal *includes* all new Track & Pool Grade hardware.
 - And based on the pictures, it is very possible that your current track is not compatible with the DuctSox gliders and you may not be able to install the DuctSox product.
 - While I realize that you may want to save some money with the existing hardware, I feel that it is worth paying more upfront for a new pool grade hardware hanging system to save yourself some time and effort down the road.
2. Regarding the listed 36" diameter (from the plans you showed me), if we do not use Internal Hoops for internal fabric support, we would have to use a 2 Row attachment, because a 1 row attachment at 36" could see warranty completely voided.
 - We would also need CFM (perhaps from the AHU's serving the space) to confirm that our inlet velocities are within the 1400 fpm range. If the CFM you provide requires an increase in diameter, we might need to requoteing.

Regards,

 Tom Bowerman
Sales Engineer Vyron Corporation
5315 Wall Street, Madison, WI 53718
m: (608) 572-4896
tbowerman@vyron.com | [website](#) | [line card](#) | [customer portal](#)



From: Troy Hendrickson <Troy.Hendrickson@bassettmechanical.com>
Sent: Tuesday, February 20, 2024 10:54 AM
To: Bowerman, Tom <TBowerman@vyron.com>; dbuckingham@whitewater-wi.gov
Subject: Whitewater aquatic

Good morning, Tom,

Dan Buckingham, 1-920-723-2317, at the City of Whitewater is looking for a vender to supply duct sock for his aquatic center. He will purchase and install. I am just introducing the 2 of you.

I have attached some pictures of what he has and the blueprint says they are 36" but does not give lengths.

Thank you,

Troy Hendrickson, HVAC Sales Representative
Bassett Mechanical | Cell: 608-640-0126

The preceding email message and any attachments may be confidential or contain proprietary information and should be read or used only by the intended recipient. This message should not be transmitted to, or received by, any unauthorized person. If you have received this message in error, please inform us promptly by reply email, then delete this message and destroy any printed copies of this message. Thank you

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.