



Whitewater Fire and EMS Inspection Report

BLDG Beer Here - 617 E Milwaukee ST, Whitewater WI 53190

312 W Whitewater St

INSPECTION DETAILS

Inspection Date	Inspection Type	Inspection Number		
01/15/2026	Fire Prevention Inspection	2735		
Lead Inspector	Shift	Station	Unit	
JACOB MAAS	N/A	N/A	N/A	
Other Inspectors				
N/A				

SUMMARY OF INSPECTION

13 Passed codes | 2 Failed codes | 12 N/A codes

NEXT STEPS

Please direct questions about your Inspection to:

JACOB MAAS

jmaas@whitewater-wi.gov

Reinspection Date

02/14/2026

GENERAL NOTES

JACOB MAAS - 01/15/2026 @ 14:11

Inspection scheduled for business sale and alcohol license transfer purposes.

JACOB MAAS - 01/15/2026 @ 14:23

Signature obtained from Ontaya.

SIGNATURES

Contact signature

John Cordio

Inspector signature

01/15/2026

JACOB MAAS

01/15/2026

CHECKLISTS

General Inspection

Status	Code	Description
Pass ✓	10.1 - Fundamental Requirements General Fire Safety	
Pass ✓	10.12.1.1 - Premises Identification Buildings shall have approved address numbers visible from street	
N/A 🚫	10.13 - Vacant Buildings Vacant buildings shall be secured.	
Pass ✓	10.14.10 - Exterior Vegetation Vegetation shall be removed when determined by the AHJ to present a fire hazard.	
Pass ✓	10.19.3 - Ceiling Clearance Storage shall be 2 feet from the ceiling in non sprinklered buildings, 18" in sprinklered buildings.	
Pass ✓	10.19.4 - Means of Egress Combustible Material Shall not be stored in exits.	
N/A 🚫	101.149 - CO Detectors CO detectors required IAW WI Admin Code 101	
Pass ✓	11.1 - Electrical Fire Safety Panel(s) shall be covered and unobstructed to 36".	
Pass ✓	11.1.3 - Electrical Fire Safety Permanent wiring shall be installed and maintained IAW NFPA 70	

Fail

11.1.7 - Extension Cords

Extension cords shall not be used as permanent wiring.

Location: Closet.

Comments: Extension cord running from stock room to closet across from men's restroom. Powering freezer.



Pass



12.4 - Fire Doors

Fire Doors shall be rated, self-closing, in operable condition, and not wedged open or obstructed from closing.

N/A



13.2 - Standpipe Systems

Standpipe systems shall be maintained IAW NFPA 14.

N/A



13.3 - Automatic Sprinklers

Sprinkler systems shall be maintained and tested IAW NFPA 13.

N/A 	34.10 - Pallet Storage Idle Pallets shall be maintained as per this chapter.
N/A 	50.1 - Commercial Cooking Equipment Hood systems shall be serviced and tested.
N/A 	63.3.1.8.4 - Compressed Gas Storage Compressed gas containers shall be secured
N/A 	66.9 - Flammable Storage Improper storage of flammable/combustible liquid.
Pass 	999 - Other Hazardous Condition See Notes

 **Statement of Fees****FEE**

Invoice Date	Inspection Fee	Date Paid	Amount Paid
<u>N/A</u>			
Invoice Number	Check Number	Transaction Number	
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	