



INSPECTION DETAILS

Inspection Date 12/18/2025	Inspection Type Fire Prevention Inspection	REINSPECTION	Inspection Number 1813-R1
Lead Inspector JACOB MAAS	Shift N/A	Station N/A	Unit N/A
Other Inspectors N/A			

SUMMARY OF INSPECTION

0 Passed codes	2 Resolved violations	0 Failed codes
--------------------------	---------------------------------	--------------------------

NEXT STEPS

Please direct questions about your inspection to:

JACOB MAAS
jmaas@whitewater-wi.gov

Reinspection Date
12/18/2026

GENERAL NOTES

JACOB MAAS - 11/18/2025 @ 15:13

Signature obtained from Tina on managers behalf.

SIGNATURES

Contact signature

Inspector signature

Liz

12/18/2025

JACOB MAAS

12/18/2025

CHECKLISTS

Reinspection

Status	Code	Description
Resolved 	14.13 - Emergency Lighting	Emergency egress lighting shall be maintained and operable where required by code.
		Location: Throughout building. Comments: Majority of emergency lights do not function properly when breaker is thrown.
Resolved 	14.14 - Marking of Means of Egress	Exit lights shall be illuminated and maintained where required by code.
		Location: Throughout building. Comments: Majority of exit lights are not illuminated and do not operational when breaker is thrown.



Statement of Fees

FEE

Invoice Date	Inspection Fee	Date Paid	Amount Paid
N/A			
Invoice Number	Check Number	Transaction Number	
N/A	N/A	N/A	