

Public Works Report

April 2025

80 - Service Orders

56 - Rereads

23 - After Hour Call ins

161- Locates

10 - Shut Offs

15 - Meter/ERTS Replaced

Water Department

1. Finished installation of 8" water main for the Sac River Cowboy Church
2. Replaced meter setter on Lester
3. Replaced meter pit on Farm Rd 136
4. Continued work installing new shelves in shop
5. Took routine & special water samples
6. Completed water tap on Rabbit Hop Ln.
7. Installed grounding grid at Willard Water well #1
8. Changed missions board at Willard water well #1
9. Completed special water samples sent by DNR
10. Dug up and repaired valve at Megan Ln. apartments

Sewer Department

1. Lift Station maintenance
2. Sewer Lagoon Pond maintenance
3. Continuing manhole inspections
4. Lagoon samples & EDMR
5. Continued camming sewers
6. Pulled check valves at B lift station (2 times)
7. Pulled failed pump at Meadows West
8. Pulled failed pump at Meadows East
9. Installed solar charger on Jetter
10. I&I cleanup from Meadows West overflow
11. Finished FOG inspections

12. Overnight sewage haul with pump trucks from Regional
13. Ran ethernet cable in City Hall attic for IT department

Streets Department

1. Replaced driveway culvert on Ross Rd.
2. Dirt work on Hunt, Main, Wright, Cowboy Church, AB sidewalk project
3. Sign work throughout town
4. Cleaned up field on 103 where trees were laid down by contractor
5. Built retaining wall for dumpster at public works shop
6. Installed mailbox at public works shop
7. Finished locker room at public works shop
8. Mowing throughout town
9. Pothole repairs throughout town