

So far this year

We have completed 357 locates .

We completed jetting of gravity sewer for a total footage of 2400 feet.

And cammed a total of 2000 feet of gravity sewer

Next we have I & I repairs. We replaced 1 sewer cap. We sealed cracks in 3 manholes and raised 4 others. I expect to reduce I and I. by 100,000 gallons now

Smoke testing for this year is planned to start in the July - August time frame . This will be focused in the b collection basin .

Next city lagoons. A total of 8 uprights were replaced. Due to cows breaking them .

Fog inspections have been completed totaling 34. And we are ready for the August turn in with city of Springfield .

The sewer department assisted the streets with dirt work on Jackson. As well as on Jeb after an I and I repair back on Jan 21st

My staff and myself helped to fill potholes on farm road 105 as well as farm rd 84 .

My staff and I spent a lot of time unclogging a check valve at our B lift station on avg 2-3 times a week if not more. We are good at it now so it only takes us 25-30ish minutes to clean.

In February we had good weather and were able to go jetting as well as use the camera for inspections of gravity sewer and manholes

Feb 3<sup>rd</sup> we finished the cover for the Kabota so we can inspect sewer lines in the rain.

Feb 17 we found that the pump for B lift station was clogged causing us to have to pull the pump. We found wet wipes to be the main cause of the clog.

Feb 18 reinstalled pump for B Lift station.

Feb 19 We filled in ruts at meadows east and west

February 21<sup>st</sup> We worked with the Willard schools to facilitate the rerouting of a water line and the sampling required afterwards.

We worked on updating our diamond maps for I and I every day that we were not jetting or running the camera in the sewer looking for breaks ,cracks and other issues .

We also needed to fix a tire on the back hoe so we could proceed to work on I and I

March we are also prepping for a manhole install in June This will help add in the cleaning and maintaining of the city sewer system .

I have found 2 manholes that have Severe h2s damage the inside of the manhole its self . we will be looking to have these repaired later this year

We on raising more manholes this month 4 have been done so far and more to come

Thank you for you time and have a grate rest of your day