

Public Works Report

November 2024

74 Service Orders

38 Rereads

10 After Hour Call ins

Locates 81

Shut Offs 4

Meter ERTS Replaced 9

Water Department

1. Repaired water service on Southview
2. Replaced transducer struck by lightning at Willard Well #1
3. Replaced soft start struck by lightning and Meadows Well #2
4. Replaced transducer, and missions board at Meadows Well #1
5. Emergency call in to hook generator up at Meadows Well #1 due to power outage
6. Crawl space inspections for L&C
7. Insulate meter pits as part of winterization program
8. Lead And Copper Data Input
9. Meter reads & Re Reads
10. Flushing
11. Well Checks and Chlorine Maintenance

Sewer Department

1. Lift Station maintenance
2. Repaired sewer break on Miller Rd. caused by Looney Underground
3. Sewer Lagoon Pond maintenance
4. FOG inspections
5. Continuing manhole inspections
6. Organized sewer lagoon cabin
7. Lagoon samples & EDMR

Streets Department

1. Asphalt Miller Rd.
2. Dirt work on Farm Rd. 124
3. Repaired pot holes on New Mellville
4. Repaired skid steer bucket
5. Repaired backhoe window
6. Replaced culvert on New Mellville
7. Replaced ball joints on F-350 crane truck
8. Removed power pole at Meadows West
9. Dug drainage next to shop for internet line
10. Tree trimming on Jeb
11. Plumbing on new offices
12. Built forms for on St Hwy. AB sidewalk
13. New Office drywall work