

Public Works Report

March 2025

84 Service Orders

49 Rereads

16 After Hour Call ins

Locates 219

Shut Offs 34

Meter/ERTS Replaced 12

Water Department

1. Begin installation of 8" water main for the Sac River Cowboy Church
2. Repair 6" water leak at the intersection of Hunt Rd. and Becky st, and addition of another valve to lessen the customers shut off in the event of another break
3. Repair 2" water main that runs across Crighton's field
4. Replaced 2" water meter at pool
5. Continued work installing new shelves in shop
6. Took routine & special water samples

Sewer Department

1. Lift Station maintenance
2. Sewer Lagoon Pond maintenance
3. Continuing manhole inspections
4. Lagoon samples & EDMR
5. Pulled check valves at B lift station (4 times)
6. Pulled clogged pump at B lift station
7. Installed catch pins in two manholes with constant clogging due to non-flushable items being flushed
8. Pulled check valves at D lift station to remove clogging
9. Began repairing sewer lagoon shed that houses spare parts
10. Performed repairs on sewer jetter
11. Replace approximately 60' of sewer main on Main st that was clogged with root infiltration
12. Removed approximately ¼ ton of gravel from sewer main in Stone Creek left behind by contractor with sewer jetter

Streets Department

1. Finished sidewalk project along AB Highway
2. Completed retrofitting of old lagoon cabin into temporary stray dog housing
3. Performed repairs on roller
4. Dirt work on Main st
5. Started mowing
6. Picked up 6 stray dogs