

## **Public Works Report**

February 2025

62 Service Orders

38 Rereads

15 After Hour Call ins

Locates 231

Shut Offs 13

Meter/ERTS Replaced 9

### **Water Department**

1. Insulate meter pits as part of winterization program
2. Repaired leak on Lone Oak
3. Meter reads & Re-Reads
4. Well Checks and Chlorine Maintenance
5. Changed quill at Meadows well #1
6. Repaired Stenner pump @ Meadows well #1
7. Repaired Water leak on New Melville
8. Repaired water leak on Farm Rd 89

### **Sewer Department**

1. Lift Station maintenance
2. Sewer Lagoon Pond maintenance
3. Continuing manhole inspections
4. Lagoon samples & EDMR
5. Repaired uprights at lagoons
6. Began cleanup of 94 lift station to organize parts
7. Pulled check valves at B lift station (6 times)
8. Replaced pump at B lift station
9. Pulled pumps at Meadows West and Park estates to get quotes for spare pumps
10. Pump down test at D lift station

### **Streets Department**

1. Continued replacement of street signs all throughout town

2. Installed culvert pipe extension on Hunt Rd
3. Laid down new asphalt on alleyway behind shop
4. Repaired crane on F-350
5. Tree trimming all around town
6. Jetter training on culvert pipes along Ross Rd.
7. Patch on Hughes Rd, New Melville, Mill St, Hunt Rd
8. 2 days worth of plowing/salting during snow storm on February 17/18
9. Wash all vehicles and equipment
10. Finished installing trim in new offices