

**WILLOWICK CITY ENGINEER'S REPORT
FEBRUARY 16, 2021**

Projects:

Parkland Area Sewers - E. 328th Street Sewer Rehabilitation – United Survey Inc. performed post construction televising of sewers and laterals. Videos are currently being reviewed to determine if any additional improvements are necessary.

Fairway Storm Sewer – CT and the Service Department performed an inspection on 2/11/2021 of the 84" CMP sewer on Fairway Blvd between Forestgrove Rd to W. Willowick Dr. This is in response to the multiple sinkholes in treelawns on Fairway that have become systemic and have required repairs at two different sections to date.

It is expected that one more day will be required to complete the inspection of the final section of sewer that was not completed on the above date. Description and details of defects will be documented in a report once the inspection of the entire sewer is completed. Report will include an analysis of the condition of the sewer, a list of alternative improvements, and recommendations for how the City should proceed.

Manry Park Exercise Trail Improvements - Construction is complete.

Motion authorizing the release of retainage in the amount of \$18,409.44 to Lake County Landscape & Supply Inc. for the Manry Park Exercise Trail Improvements.