CORRECTIONS LIST

Project Type: Final Plat | Project Title: Final Plat ID # 24-000053 | Started: 02/14/2024 at 2:56 PM



Address Haney Complex 000 Haney Complex, Willow Park, TX USA	Legal No legal information	Property Info No property information	
Description Haney Complex Addition, Lot 1	I-6, Block 1		
CORRECTION / ADDED ON	DESCRIPTION		PRIORITY
Miscellaneous			Required: 6 Corrected: 0
ENG - Flood Study By: Gretchen Vazquez 02/16/2024 at 9:08 AM REQUIRED	When can we expect submittal of the flood study so that staff can verify the minimum finished floor elevations and limits of the floodway/floodplain on the plat?		Normal
Label Robyn Dr. By: Toni Fisher 02/15/2024 at 3:04 PM REQUIRED	Please label Robyn Dr and its width where it extends between Lots 3 & 4.		Normal
Building on Lot 1 By: Toni Fisher 02/15/2024 at 2:00 PM REQUIRED	Please remove the building shown on Lot 1; the Final Plat should not show structures, only the Preliminary Plat.		Normal
Zoning designation By: Toni Fisher 02/15/2024 at 1:59 PM REQUIRED	Please remove Zoning designation block on each lot. The zoning change is being done concurrently so this is not yet approved.		Normal
City Limits - Vacinity Map By: Toni Fisher 02/15/2024 at 1:54 PM REQUIRED	In the Vacinity Map on Page 1 and Page 2: Please include the Haney Complex, all Lots 1-6, within the City Limits of Willow Park.		Normal

Add Utility Easement for potential Lift Station By: Toni Fisher 02/15/2024 at 1:42 PM



Per our previous conversation, please add a 30'x30' utility easement on the northeast corner of Lot 5, along E. Bankhead Hwy., for a potential future lift station.

Normal