



Agenda Item Executive Summary

Item Name Goodling and Church Street Water Main Looping
Bidding for In-house Installation Committee or Board Village Board

BUDGET IMPACT

Amount:	\$17,900.00	Budgeted:	Yes
List what fund:	51-44-534		

EXECUTIVE SUMMARY

The Church Street and Goodling Street Water Main Looping Project, originally approved in 2024 under Fehr Graham Task Order 22-837, includes engineering and construction observation as outlined in the 2024 O/M Budget. This project will eliminate two dead-end water mains, replace two fire hydrants, improve water quality, and potentially double fire flow capacity while ensuring compliance with IEPA-required minimum residual water pressure during fire flows.

In addition to the previously approved scope, the Public Works Department is now requesting authorization for in-house construction of this project, with a not-to-exceed budget of \$60,000 to allow for cost-effective completion.

This item is before the Village Board as the project has now extended into FY 2025, and previously approved funds will be expended in 2025 upon project award. The board is being asked to approve both bid acceptance and the in-house construction funding.

ATTACHMENTS (PLEASE LIST)

Fehr Graham task order 22-837, Resolution

ACTION REQUESTED

- ☐ For Discussion Only
- ☐ Resolution
- ☐ Ordinance
- ☐ Motion:

MOTION: I move to approve Resolution No. 2025-XX, a resolution authorizing the Village of Winnebago Public Works Department to construct the Church and Goodling Water Main Loop in-house, including any required bidding or procurement processes, with a not-to-exceed amount of \$60,000.

Staff: Chad Insko Director of Public Works Date: 3/5/2025