

Jon Niermann, *Chairman*
Bobby Janecka, *Commissioner*
Catarina R. Gonzales, *Commissioner*
Kelly Keel, *Executive Director*



PWS_1520005_CO_20240923_Plan Ltr

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

September 23, 2024

Jimmy D. McDaniel, P.E.
AMD Engineering LLC
6515 68th Street, Suite 300
Lubbock, TX 79424

Re: City of Wolfforth - Public Water System ID No. 1520005
Proposed Water Line Distribution Improvements
Engineer Contact Telephone: (806) 771-5976
Plan Review Log No. P-07242024-211
Lubbock County, Texas

CN600645725 RN101387447

Dear Mr. McDaniel:

On July 24, 2024, the Texas Commission on Environmental Quality (TCEQ) received planning material with your letter dated July 24, 2024 for the Proposed Water Line Distribution Improvements. Based on our review of the information submitted, the project generally meets the minimum requirements of Title 30 Texas Administrative Code (TAC) Chapter 290 - Rules and Regulations for Public Water Systems and is **approved for construction**.

The submittal consisted of 10 sheets of engineering drawings and technical specifications. The approved project consists of:

- Approximately 2,034 linear feet of 6-inch American Water Works Association Standard C900, polyvinyl chloride, dimension ratio 18 waterline;
- Approximately 2,881 linear feet of 8 -inch American Water Works Association Standard C900, polyvinyl chloride, dimension ratio 18 waterline;
- Approximately 2,088 linear feet of 10-inch American Water Works Association Standard C900, polyvinyl chloride, dimension ratio 18 waterline;
- Approximately 1,719 linear feet of 12-inch American Water Works Association Standard C900, polyvinyl chloride, dimension ratio 18 waterline; and
- Associated valves, fittings, and appurtenances.

This approval is for the construction of the above listed items only. Any wastewater components contained in this design were not considered. The authorization provided in this letter does not relieve a Public Water System from the need to comply with other applicable state and federal regulations.

This project may have approved the construction of facilities that may require either the creation of or update to an Emergency Preparedness Plan (EPP). Information on EPPs is available at the following website:

https://www.tceq.texas.gov/drinkingwater/homeland_security/disasterprep/epp

If you have additional questions about EPPs, please contact the Emergency Preparedness and Response Section at (512) 239-4691 or PDWEPP@tceq.texas.gov.

The City of Wolfforth public water supply system provides water treatment.

The project is located at East 21st Street and Alcove Avenue in Lubbock County, Texas.

An appointed engineer must notify the TCEQ's Region 2 Office in Lubbock by email at R2PWS@TCEQ.Texas.gov when construction will start. Please keep in mind that upon completion of the water works project, the engineer or owner will notify the commission's Water Supply Division, in writing, as to its completion and attest to the fact that the completed work is substantially in accordance with the plans and change orders on file with the commission as required in 30 TAC §290.39(h)(3). This notification may be sent to PTRS@tceq.texas.gov.

Please refer to the Plan Review Team's Log No. **P-07242024-211** in all correspondence for this project.

Please complete a copy of the most current Public Water System Plan Review Submittal form for any future submittals to TCEQ. Every blank on the form must be completed to minimize any delays in the review of your project. The document is available on TCEQ's website at the address shown below. You can also download the most current plan submittal checklists and forms from the same address.

<https://www.tceq.texas.gov/drinkingwater/udpubs.html>

For future reference, you can review part of the Plan Review Team's database to see if we have received your project. This is available on TCEQ's website at the following address:

<https://www.tceq.texas.gov/drinkingwater/planrev.html/#status>

You can download the latest revision of 30 TAC Chapter 290 - [Rules and Regulations for Public Water Systems](#) from this site.

Jimmy D. McDaniel, P.E.
Page 3
September 23, 2024

If you have any questions concerning this letter or need further assistance, please contact David Smith at (512) 239-4703 or by email at David.Smith@Tceq.Texas.Gov or by correspondence at the following address:

Plan Review Team, MC-159
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

Sincerely,



David T. Smith, P.E.
Plan Review Team
Plan and Technical Review Section
Water Supply Division
Texas Commission on Environmental Quality



For Craig A. Stowell, P.E., Team Leader
Plan Review Team
Plan and Technical Review Section
Water Supply Division
Texas Commission on Environmental Quality

CAS/DTS/vj/av

cc: City of Wolfforth, Attn: Honorable Mayor Charles Addington, P.O. Box 36, Wolfforth,
Texas 79382-0036

Jimmy D. McDaniel, P.E.

Page 4

September 23, 2024

bcc: TCEQ Central Records PWS File 1520005 (P-07242024-211/City of Wolfforth)
TCEQ Region No. 2 Office - Lubbock