



AGENDA ITEM COMMENTARY

MEETING NAME: City Council
MEETING DATE: February 5, 2024
ITEM TITLE: Consider and take appropriate action on award of bid for PAX System Installation for Phase 2 Disinfection Conversion
STAFF INITIATOR: Randy Criswell

BACKGROUND:

We've received final TCEQ approval for Phase 2 of the disinfection conversion process we started about a year ago in conjunction with the Lubbock water interconnect. As you will recall, we are currently operating our chloramine disinfection system with a semi-automated process (Phase 1). We planned all along to fully automate the process, which is Phase 2. This final phase consists of the installation of a PAX mixing/dosing system along with required tank and piping modifications. We've received a Bid Proposal from UCA for the installation, a copy of which is attached. Their price is \$480,375. We've also received a letter from Kimley Horn recommending the award of this bid, a copy also attached.

We anticipate about 60 days to complete the project.

EXHIBITS:

UCA Bid Proposal

Kimley Horn letter of recommendation

COUNCIL ACTION/STAFF RECOMMENDATION:

Staff concurs with the recommendation from Kimley Horn and recommends the bid be awarded to UCA in the amount of \$480,375.