



Sample Info

Sharing

tap score

EVALUATION

84

OUT OF 99

Health: 95

No concerns detected

Aesthetics: 45

3 concerns detected

Plumbing: 60

2 concerns detected

FILTRATION & TREATMENT

Certificate of Analysis: YST82D

Drinking Water | Labs

May 13, 2024

09:25 AM

well head

11 MCNAMARA RD

Not treated

Private Well

All Results

Properties

Health

Aesthetics 3

Plumbing 2

Treatment

Comparisons

Search







Change Evaluation

Glossary

Parameter		Result	Evaluation: HGL ▼	Method, MDL and RL	Analysis Date	Details
	Nitrate (as N)	3.06	HGL: 10 PPM	EPA 300.0	15 May 2024	View
	Inorganics	PPM		MDL 0.005 PPM RL 0.5 PPM		
	Barium	0.232	HGL: 2 PPM	EPA 200.8	15 May 2024	View
	Metals	PPM		MDL 0.0001 PPM RL 0.0051 PPM		
	Boron	0.0309	HGL: 0.5 PPM	EPA 200.7	15 May 2024	View
	Inorganics	PPM		MDL 0.00312 PPM RL 0.0051 PPM		
	Manganese	0.0157	HGL: 0.1 PPM	EPA 200.8	15 May 2024	View
	Metals	PPM		MDL 0.0001 PPM RL 0.001 PPM		
	Strontium	0.0591	HGL: 3 PPM	EPA 200.7	15 May 2024	View
	Metals	PPM		MDL 0.000112 PPM RL 0.0102 PPM		
		15.2		EPA 300.0		

	Sulfate Inorganics	PPM	HGL: 500 PPM	MDL 0.671 PPM	RL 1 PPM	15 May 2024	View
	Alkalinity (as CaCO3) Properties	240 PPM	No HGL exists	SM 2320 B		15 May 2024	View
	Bicarbonate Minerals	▼ 291.23 PPM	No HGL exists	Bicarbonate		15 May 2024	View
	Calcium Minerals	78.8 PPM	No HGL exists	EPA 200.7 MDL 0.0351 PPM	RL 0.05 PPM	15 May 2024	View
	Carbonate Minerals	▼ 0.673 PPM	No HGL exists	Carbonate		15 May 2024	View
	Chloride Inorganics	130 PPM	No HGL exists	EPA 300.0 MDL 1.37 PPM	RL 5 PPM	15 May 2024	View
	Conductivity Properties	980 umhos/cm	No HGL exists	SM 2510 B MDL 1 umhos/cm	RL 1 umhos/cm	15 May 2024	View
	CSMR Properties	▼ 8.55	No HGL exists	CSMR		15 May 2024	View
	Grains per gallon Properties	▼ 18.44 Grains	No HGL exists	GPG		15 May 2024	View
	Hardness (Ca,Mg) Properties	▼ 314.95 PPM	No HGL exists	Hardness (Ca,Mg)		15 May 2024	View
	Hardness (Total) Properties	▼ 315.22 (Total) PPM	No HGL exists	Hardness (Total)		15 May 2024	View
	Langelier Saturation Index Properties	0.54	No HGL exists	Langelier Saturation Index		15 May 2024	View
	Magnesium Minerals	28.7 PPM	No HGL exists	EPA 200.7 MDL 0.00896 PPM	RL 0.051 PPM	15 May 2024	View
	pH Properties	7.7	No HGL exists	SM 4500-H+B		15 May 2024	View
	Potassium Minerals	1.18 PPM	No HGL exists	EPA 200.7 MDL 0.0437 PPM	RL 0.204 PPM	15 May 2024	View
	Silica Inorganics	8.28 PPM	No HGL exists	EPA 200.7 MDL 0.0177 PPM	RL 2.18 PPM	15 May 2024	View
		57.8	No HGL exists	EPA 200.7		15 May 2024	View

	Sodium Minerals Sodium Adsorption Ratio  Properties	PPM 1.42	No HGL exists	SAR	MDL 0.188 PPM RL 1.02 PPM	15 May 2024	View
	Total Dissolved Solids Properties	PPM 571	No HGL exists	SM 2510 B	MDL 1.92 PPM RL 1.92 PPM	15 May 2024	View
	Turbidity Properties	NTU 0.23	No HGL exists	SM 2130 B	MDL 0.039 NTU RL 0.1 NTU	15 May 2024	View
	1,1 Dichloroethane VOCs	Not Detected		EPA 524.2	MDL 0.11 PPB RL 0.5 PPB	15 May 2024	View
	1,1 Dichloroethylene VOCs	Not Detected		EPA 524.2	MDL 0.15 PPB RL 0.5 PPB	15 May 2024	View
	1,1 Dichloropropene VOCs	Not Detected		EPA 524.2	MDL 0.17 PPB RL 0.5 PPB	15 May 2024	View
	1,1,1 Trichloroethane VOCs	Not Detected		EPA 524.2	MDL 0.08 PPB RL 0.5 PPB	15 May 2024	View
	1,1,1,2 Tetrachloroethane VOCs	Not Detected		EPA 524.2	MDL 0.21 PPB RL 0.5 PPB	15 May 2024	View
	1,1,2 Trichloroethane VOCs	Not Detected		EPA 524.2	MDL 0.15 PPB RL 0.5 PPB	15 May 2024	View
	1,1,2,2 Tetrachloroethane VOCs	Not Detected		EPA 524.2	MDL 0.1 PPB RL 0.5 PPB	15 May 2024	View
	1,2 Dichlorobenzene VOCs	Not Detected		EPA 524.2	MDL 0.13 PPB RL 0.5 PPB	15 May 2024	View
	1,2 Dichloroethane VOCs	Not Detected		EPA 524.2	MDL 0.08 PPB RL 0.5 PPB	15 May 2024	View
	1,2 Dichloropropane VOCs	Not Detected		EPA 524.2	MDL 0.13 PPB RL 0.5 PPB	15 May 2024	View
	1,2,3 Trichlorobenzene VOCs	Not Detected		EPA 524.2	MDL 0.28 PPB RL 0.5 PPB	15 May 2024	View
	1,2,3 Trichloropropane VOCs	Not Detected		EPA 524.2	MDL 0.21 PPB RL 0.5 PPB	15 May 2024	View
		Not Detected		EPA 524.2		15 May 2024	View

	1,2,4 Trichlorobenzene VOCs	Not Detected	MDL 0.24 PPB	RL 0.5 PPB		
	1,2,4 Trimethylbenzene VOCs	Not Detected	EPA 524.2 MDL 0.11 PPB	RL 0.5 PPB	15 May 2024	View
	1,3 Dichlorobenzene VOCs	Not Detected	EPA 524.2 MDL 0.12 PPB	RL 0.5 PPB	15 May 2024	View
	1,3 Dichloropropane VOCs	Not Detected	EPA 524.2 MDL 0.14 PPB	RL 0.5 PPB	15 May 2024	View
	1,3,5 Trimethylbenzene VOCs	Not Detected	EPA 524.2 MDL 0.1 PPB	RL 0.5 PPB	15 May 2024	View
	1,4 Dichlorobenzene VOCs	Not Detected	EPA 524.2 MDL 0.1 PPB	RL 0.5 PPB	15 May 2024	View
	2,2 Dichloropropane VOCs	Not Detected	EPA 524.2 MDL 0.21 PPB	RL 0.5 PPB	15 May 2024	View
	Aluminum Metals	Not Detected	EPA 200.7 MDL 0.00618 PPM	RL 0.051 PPM	15 May 2024	View
	Antimony Metals	Not Detected	EPA 200.8 MDL 0.00003 PPM	RL 0.001 PPM	15 May 2024	View
	Arsenic Metals	Not Detected	EPA 200.8 MDL 0.00007 PPM	RL 0.001 PPM	15 May 2024	View
	Benzene Petroleum Compounds	Not Detected	EPA 524.2 MDL 0.13 PPB	RL 0.5 PPB	15 May 2024	View
	Beryllium Metals	Not Detected	EPA 200.8 MDL 0.00005 PPM	RL 0.001 PPM	15 May 2024	View
	Bromobenzene VOCs	Not Detected	EPA 524.2 MDL 0.18 PPB	RL 0.5 PPB	15 May 2024	View
	Bromochloromethane Disinfection Byproducts	Not Detected	EPA 524.2 MDL 0.11 PPB	RL 0.5 PPB	15 May 2024	View
	Bromodichloromethane Disinfection Byproducts	Not Detected	EPA 524.2 MDL 0.09 PPB	RL 0.5 PPB	15 May 2024	View
	Bromoform Disinfection Byproducts	Not Detected	EPA 524.2 MDL 0.11 PPB	RL 0.5 PPB	15 May 2024	View
	Not Detected		EPA 524.2 MDL 0.24 PPB	RL 0.5 PPB	15 May 2024	View

	Bromomethane Cadmium Metals	Not Detected	EPA 200.8 MDL 0.00007 PPM RL 0.001 PPM	15 May 2024	View
	Carbon Tetrachloride VOCs	Not Detected	EPA 524.2 MDL 0.16 PPB RL 0.5 PPB	15 May 2024	View
	Chlorobenzene VOCs	Not Detected	EPA 524.2 MDL 0.08 PPB RL 0.5 PPB	15 May 2024	View
	Chloroethane VOCs	Not Detected	EPA 524.2 MDL 0.18 PPB RL 0.5 PPB	15 May 2024	View
	Chloroform Disinfection Byproducts	Not Detected	EPA 524.2 MDL 0.44 PPB RL 0.5 PPB	15 May 2024	View
	Chloromethane VOCs	Not Detected	EPA 524.2 MDL 0.13 PPB RL 0.5 PPB	15 May 2024	View
	Chlorotoluene 2 VOCs	Not Detected	EPA 524.2 MDL 0.08 PPB RL 0.5 PPB	15 May 2024	View
	Chlorotoluene 4 VOCs	Not Detected	EPA 524.2 MDL 0.12 PPB RL 0.5 PPB	15 May 2024	View
	Chromium (Total) Metals	Not Detected	EPA 200.8 MDL 0.00002 PPM RL 0.001 PPM	15 May 2024	View
	cis 1,2 Dichloroethylene VOCs	Not Detected	EPA 524.2 MDL 0.2 PPB RL 0.5 PPB	15 May 2024	View
	cis 1,3 Dichloropropene VOCs	Not Detected	EPA 524.2 MDL 0.13 PPB RL 0.5 PPB	15 May 2024	View
	Cobalt Metals	Not Detected	EPA 200.8 MDL 0.00001 PPM RL 0.001 PPM	15 May 2024	View
	Copper Metals	Not Detected	EPA 200.8 MDL 0.00004 PPM RL 0.001 PPM	15 May 2024	View
	Dibromochloromethane Disinfection Byproducts	Not Detected	EPA 524.2 MDL 0.14 PPB RL 0.5 PPB	15 May 2024	View
	Dibromochloropropane VOCs	Not Detected	EPA 524.2 MDL 0.39 PPB RL 0.5 PPB	15 May 2024	View
	Dibromomethane Disinfection Byproducts	Not Detected	EPA 524.2 MDL 0.18 PPB RL 0.5 PPB	15 May 2024	View

	Dichlorodifluoromethane VOCs	Not Detected	EPA 524.2 MDL 0.12 PPB RL 0.5 PPB	15 May 2024	View
	Dichloromethane VOCs	Not Detected	EPA 524.2 MDL 0.31 PPB RL 0.5 PPB	15 May 2024	View
	E. coli Bacteria	Not Detected	SM 9223B	15 May 2024	View
	Ethylbenzene Petroleum Compounds	Not Detected	EPA 524.2 MDL 0.08 PPB RL 0.5 PPB	15 May 2024	View
	Ethylene dibromide VOCs	Not Detected	EPA 524.2 MDL 0.1 PPB RL 0.5 PPB	15 May 2024	View
	Fluoride Inorganics	Not Detected	EPA 300.0 MDL 0.005 PPM RL 0.1 PPM	15 May 2024	View
	Hexachlorobutadiene VOCs	Not Detected	EPA 524.2 MDL 0.2 PPB RL 0.5 PPB	15 May 2024	View
	Iron Metals	Not Detected	EPA 200.7 MDL 0.00428 PPM RL 0.05 PPM	15 May 2024	View
	Isopropylbenzene VOCs	Not Detected	EPA 524.2 MDL 0.11 PPB RL 0.5 PPB	15 May 2024	View
	Lead Metals	Not Detected	EPA 200.8 MDL 0.00005 PPM RL 0.0004 PPM	15 May 2024	View
	Lithium Metals	Not Detected	EPA 200.7 MDL 0.00555 PPM RL 0.051 PPM	15 May 2024	View
	m,p Xylene Petroleum Compounds	Not Detected	EPA 524.2 MDL 0.13 PPB RL 0.5 PPB	15 May 2024	View
	Mercury Metals	Not Detected	EPA 200.8 MDL 0.0001 PPM RL 0.0002 PPM	15 May 2024	View
	Methyl Tertiary Butyl Ether Petroleum Compounds	Not Detected	EPA 524.2 MDL 0.24 PPB RL 0.5 PPB	15 May 2024	View
	Molybdenum Metals	Not Detected	EPA 200.8 MDL 0.00004 PPM RL 0.001 PPM	15 May 2024	View
	Naphthalene Petroleum Compounds	Not Detected	EPA 524.2 MDL 0.1 PPB RL 0.5 PPB	15 May 2024	View

	n Butylbenzene VOCs	Not Detected	EPA 524.2 MDL 0.17 PPB RL 0.5 PPB	15 May 2024	View
	Nickel Metals	Not Detected	EPA 200.8 MDL 0.0001 PPM RL 0.001 PPM	15 May 2024	View
	Nitrite (as N) Inorganics	Not Detected	EPA 300.0 MDL 0.002 PPM RL 0.1 PPM	15 May 2024	View
	n Propylbenzene VOCs	Not Detected	EPA 524.2 MDL 0.1 PPB RL 0.5 PPB	15 May 2024	View
	o Xylene Petroleum Compounds	Not Detected	EPA 524.2 MDL 0.11 PPB RL 0.5 PPB	15 May 2024	View
	Phosphorus Inorganics	Not Detected	EPA 200.7 MDL 0.0755 PPM RL 1.02 PPM	15 May 2024	View
	p Isopropyltoluene VOCs	Not Detected	EPA 524.2 MDL 0.11 PPB RL 0.5 PPB	15 May 2024	View
	sec Butylbenzene VOCs	Not Detected	EPA 524.2 MDL 0.06 PPB RL 0.5 PPB	15 May 2024	View
	Selenium Metals	Not Detected	EPA 200.8 MDL 0.0004 PPM RL 0.0051 PPM	15 May 2024	View
	Silver Metals	Not Detected	EPA 200.8 MDL 0.00003 PPM RL 0.001 PPM	15 May 2024	View
	Styrene VOCs	Not Detected	EPA 524.2 MDL 0.14 PPB RL 0.5 PPB	15 May 2024	View
	tert Butylbenzene VOCs	Not Detected	EPA 524.2 MDL 0.16 PPB RL 0.5 PPB	15 May 2024	View
	Tetrachloroethylene VOCs	Not Detected	EPA 524.2 MDL 0.13 PPB RL 0.5 PPB	15 May 2024	View
	Thallium Metals	Not Detected	EPA 200.8 MDL 0.00006 PPM RL 0.0004 PPM	15 May 2024	View
	Tin Metals	Not Detected	EPA 200.8 MDL 0.00004 PPM RL 0.0041 PPM	15 May 2024	View
	Titanium Metals	Not Detected	EPA 200.7 MDL 0.000194 PPM RL 0.00204 PPM	15 May 2024	View

	Toluene Petroleum Compounds	Not Detected	EPA 524.2 MDL 0.12 PPB RL 0.5 PPB	15 May 2024	View
	Total Coliform Bacteria	Not Detected	SM 9223B	15 May 2024	View
	trans 1,3 Dichloropropene VOCs	Not Detected	EPA 524.2 MDL 0.11 PPB RL 0.5 PPB	15 May 2024	View
	Trichloroethylene VOCs	Not Detected	EPA 524.2 MDL 0.17 PPB RL 0.5 PPB	15 May 2024	View
	Trichlorofluoromethane VOCs	Not Detected	EPA 524.2 MDL 0.1 PPB RL 0.5 PPB	15 May 2024	View
	Uranium Metals	Not Detected	EPA 200.8 MDL 0.0000306 PPM RL 0.001 PPM	15 May 2024	View
	Vanadium Metals	Not Detected	EPA 200.8 MDL 0.00003 PPM RL 0.001 PPM	15 May 2024	View
	Vinyl Chloride VOCs	Not Detected	EPA 524.2 MDL 0.07 PPB RL 0.5 PPB	15 May 2024	View
	Zinc Metals	Not Detected	EPA 200.7 MDL 0.00495 PPM RL 0.0051 PPM	15 May 2024	View
	Total THMs Disinfection Byproducts	Not Detected	Total THMs	15 May 2024	View

Add self-test

End of results. [Questions?](#)

Download & share
Share with others



Treatment Tech



Nearby providers
Get help with installation



Re-order the test kit used for this report:



Advanced Home Water Test

Click the button to re-order the same kits that were used in this report.
You can always adjust your order during checkout or add more kits.

Reorder