



Wylie City Council

AGENDA REPORT

Department:	<u>Public Works</u>	Account Code:	<u>100-5411-54230;</u> <u>470-5470-54230</u>
Prepared By:	<u>Glenna Hayes</u>		

Subject

Consider, and act upon, Resolution No. 2022-24(R) of the City Council of the City of Wylie, Texas to approve emergency repairs of a drainage pipe generally located at 403 Bentwood Drive from Moss Utilities in the estimated amount of \$200,000.00.

Recommendation

Motion to approve Item as presented.

Discussion

The homeowner at 403 Bentwood Dr. contacted the City of Wylie Public Works department regarding sinkholes that had developed in their backyard. After further investigation by the Stormwater Division staff, it was determined to be a safety and liability issue that would need to be addressed as soon as possible. The existing concrete pipe sections have separated and are broken and misaligned and will need to be replaced from the storm drain box in the front of the house at 403 Bentwood Dr. which extends through to the back of the property and exits onto the rear of the property at 914 Heatherwood Dr.

Staff contacted three (3) vendors requesting a proposal for repairs with one vendor responding, Moss Utilities LLC. Moss will remove the defective pipe and replace it with a new stormwater pipe, and make all the necessary tie-ins. The scope of work also includes restoring the three (3) properties to “as is” condition with proper grading and vegetation.

Staff recommends the approval of this resolution for the emergency repair and replacement of drainage pipe generally located at 403 Bentwood Drive with Moss Utilities, LLC in the estimated amount of \$200,000. This amount also includes a \$10,000 contingency fee (5.3%). This item is exempt from competitive bidding under Local Government Code 252.022.a.2 to preserve or protect the public health or safety of the municipality’s residents.