



MAYOR
Ken Ritter

CHIEF ADMINISTRATIVE OFFICER
Sally M. Angers

CITY CLERK
Nicole Guidry

CITY ENGINEER
Clint Simoneaux

City of Youngsville
P.O. Box 592
305 Iberia Street
Youngsville, LA 70592
(337) 856-4181 * Fax (337) 856-8863
City Engineer: 337-573-4488

CITY COUNCIL
Kayla Menard Reaux
Lindy Bolgiano
Matt Romero
Kenneth Stansbury
Gary Williams

January 31, 2022

Honorable Ken Ritter
Mayor
City of Youngsville
P.O. Box 592
Youngsville, LA 70592

**Subject: Sabal South
Preliminary Plat Review**

Dear Mayor Ritter:

The above referenced preliminary plat has been submitted and reviewed for general compliance with the requirements for a Single-Family Neighborhood development in the City of Youngsville.

I recommend the City of Youngsville approve this Preliminary Plat with the following comments.

SPECIFIC PLAT REVISIONS

- A. I recommend no waivers to the revisions found the in ADRC report.
- B. Add a note: Garage setback: 25'.
- C. Show location of Pond A top bank on the plat.
- D. Provide access from Street A to Pond A.
- E. Detail bearing and distance on the north boundary of commercial Lot 1.
- F. Show lines of incorporated areas on the plat.
- G. Detail on the plat the extents of the pipeline easement.

PLAT/SUBDIVISION CONDITIONS

- 1. I recommend waving to condition #6 & 16 and replacing with the City of Youngsville requirements.
- 2. I recommend no waivers to the remaining conditions in the ADRC report.

The City of Youngsville is an Equal Opportunity Employer

info@youngsvillela.gov
www.youngsville.us

3. (10) Ten percent green space is required. Aerated detention ponds may only account for 50% of the required common area. 25% of the required green space is required to be unincumbered by easements or servitudes.
4. A 6' perimeter sidewalk is required where a development fronts a public road.
5. The review of this Preliminary Plat is for general conformance with overall development requirements. The developer must submit detailed engineering plans for review and approval by the appropriate authority prior to construction. It is the responsibility of the developer and/or the developer's engineer to notify, coordinate, and ultimately adjudicate any review comments to the satisfaction of the appropriate authority. This would include any individual permits that may be required for construction activities.
6. Approval of the Preliminary Plat does not imply that utility services necessary to serve the development currently exist, or if they do exist have the capacity to serve the planned development. Any such evaluation and determination would take place by the respective utility during the detailed review of the engineering plans.
7. If desired in the future, the owner/developer is responsible for any required sewer infrastructure to convey sewer from the development to the City of Youngsville Sanitary Sewer Treatment Plant or the nearest location with available capacity as determined by the City. The available capacity of the sewer system at the point of discharge from the development into the City sewer system shall be evaluated by the City Engineer during the detailed review of engineering plans. The City reserves the right to require the developer to contribute funds towards the upgrade of existing lift station(s) and collection lines that may result from the addition of the development's sewage discharge to the overall system.
8. If desired in the future, the owner/developer shall utilize the City water system as the source of water for the development. The available capacity of the existing water system in the area relative to the proposed development's consumption of City water shall be evaluated during the detailed review of engineering plans. The City reserves the right to require the owner/developer to contribute funds towards the City's water distribution system to provide the requested water services to the development.
9. Submittal of a drainage impact analysis shall be submitted to the City for review and approval prior to construction. Please note that this subdivision is subject to the 25-year detention requirements.
10. All signage shall conform to the City Sign Ordinance. The proposed signage will be evaluated when the required sign permit application is submitted for review.
11. Any changes to the Preliminary Plat made after this initial review may require a resubmittal of the Preliminary Plat.
12. The owner/developer is reminded that the final design and all construction activities associated with the development of this plat, including required submittals and permits, must comply with the applicable City Ordinances in effect at the time of submittal and the City's Residential Design Development and Resource Guide.
13. The Developer is reminded that inspection services are required in the most recent Unified Development Code.
14. The Developer is reminded that this letter does not permit the initiation of construction activities.

15. The construction plans submitted for detailed review should be a complete set of plans including the Overall Plan, Preliminary Plat, Grading Plan, Streets Design, Water/Sewer Design, Stormwater Design, and Erosion Control Plan. Plans submitted lacking sufficient detail to enable a detailed review will be returned without being reviewed.
16. Additional easements may be required for this development. This will be evaluated during the review of the actual development construction plans.

If you have any questions or need additional information about this, please contact me.

Sincerely,



Clint Simoneaux, P.E.

City Engineer

cc: Nicole Guidry, City Clerk
Walter Comeaux, PE, PLS